

Water Services Planning Report

Register Reference No.: SD22A/0373

Development: A new storage lobby extension to the side/rear of the Eatto building, Unit 220.

Location: Eatto, Unit 220, John F Kennedy Road, John F Kennedy Industrial State, Dublin 12, D12 ED68

Report Date : 14-Nov-22

Surface Water Report:

No objection subject to:

1 Include SuDS (Sustainable Drainage Systems) such as a green roof, planter boxes or other such SuDS in proposed development.

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Brian Harkin SEE.

Date: _____

Endorsed: _____
Juliene Helbert SE

Date: _____