

Water Services Planning Report

Register Reference No.: SD22A/0384

Development: The construction of multi-operator telecommunications infrastructure comprised of a 21m monopole (overall structure height of 22 metres), antennas, dishes and associated equipment, together with new ground level equipment cabinets, new fencing, landscaping and all associated site works.

Location:

Report Date : 18-Nov-22

Surface Water Report:

Further Information required:

1.1 Submit a drawing showing the setback distance from proposed development to nearby public surface water sewers.

Flood Risk

Further Information Required

2.1 Submit a letter and drawing CFRAM flood risk map to

- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Brian Harkin SEE.

Date: _____

Endorsed: _____

Date: _____

Juliene Helbert SE