

User input indicated by **Orange fields**

User Input	
Zoning lookup	Minimum GI Score
VC	0.5

1. Enter Development Site Area m ² HERE ▶			
		569	
Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m ²	Factor Values
1. Short Lawn	0.3	104	31.2
2. Tall Lawn (wild, not mown)	0.5	0	0
Permeable Paving	0.3	219	65.7
Vegetation		0	0
4a. Vegetation-Shrub below 3m	0.4	25.5	10.2
4b. Vegetation-Shrub / Hedgerow above 3m	0.5	0	0
4c. Vegetation-Pollinator friendly perennial planting	0.5	13.4	6.7
4d. Vegetation-Preserved hedgerow	1.2	0	0
Trees		0	0
5a. New trees	0.6	3	1.8
5b. Preserved trees	1.2	0	0
7. SuDS intervention (rain garden, bioswale)	0.6	0	0
Green Roof		0	0
9a. Green Roofs - Intensive green roof (substrate is 200-1200mm in depth)	0.7	0	0
9b. Green Roofs - Extensive green roof (substrate is 80-200mm in depth)	0.6	0	0
10. Green wall	0.4	0	0
11. Retained Open Water	2	0	0
12. New open water	1.5	0	0
Total Equivalent Surface Area of Greening Factors		364.90	

Green Factor Numerator	115.60
-------------------------------	---------------

Minimum Required GI score	Final GI score	Result
0.5	0.20	Fail