

Patrick Kavanagh,
Kavanagh Burke Consulting Engineers
Unit F3, Calmount Park
Calmount Avenue
Dublin 12
D12 PX28

**NOTIFICATION OF DECISION TO GRANT PERMISSION & GRANT RETENTION
PLANNING & DEVELOPMENT ACT 2000 (as amended) AND
PLANNING REGULATIONS THEREUNDER**

Decision Order Number:	1475	Date of Decision:	24-Nov-2022
Register Reference:	SD22A/0298	Date:	28-Oct-2022

Applicant:

St. Finians GAA Club

Development:

St. Finians GAA Club, intend to apply for the following retention permission and planning permission at an existing GAA pitch facility at Rathcreedan, Newcastle, Co Dublin. Retention permission is sought for 1, 550m² unmetalled drop-off area/carpark ancillary to the GAA pitch use and planning permission is sought for:

GAA pitch goal posts (2No. standard 8m high) coupled with 8m high ballstop nets to the rear of each goal post. Entrance improvements from the existing Newcastle Road (R120) to the site including widening existing gate from 4.2m to 6m with setback gate arrangement to improve sightlines.

Location:

Rathcreedan, Newcastle, Co. Dublin

Floor Area:

Time extension(s) up to and including:

Additional Information Requested/Received:

29-Aug-2022 /28-Oct-2022

Clarification of Additional Information Requested/Received:

DECISION TO: Pursuant to the Planning & Development Act 2000 (as amended), it is hereby decided, for the reasons set out in the First Schedule hereto, to **GRANT PERMISSION & GRANT RETENTION** for the said development in accordance with the

said plans and particulars, subject to the conditions specified in the Second Schedule hereto, the reasons for the imposition of the said conditions being as set out in the said Second Schedule and the said decision is subject to the said conditions.

FIRST SCHEDULE

It is considered that the proposed development accords with the policies and objectives of South Dublin County Council, as set out in the South Dublin County Council Development Plan 2022 - 2028 and subject to the condition(s) set out hereunder is thereby in accordance with the proper planning and sustainable development of the area.

SECOND SCHEDULE

Conditions and Reasons:

1. Development to be in accordance with submitted plans and details.
The development shall be retained and completed fully in accordance with plans, particulars and specifications lodged with the application, and as amended by Further Information received on 28 October 2022 , save as may be required by other conditions attached hereto.
REASON: To ensure that the development is in accordance with the permission and that effective control is maintained.
2. Gates.
No gate to be installed or erected shall be capable of opening across any public footpath, cycle-track, roadway or right of way, and any front entrance pillars shall be a maximum height of 1.2m .
REASON: In the interests of visual amenity and pedestrian safety.
3. Minimise Air Blown Dust.
During the construction and or demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances. The applicant/developer shall comply with British Standard B.S. 5228 Noise Control on Construction and Open sites and British Standard B.S. 6187 Code of Practice for demolition.
REASON: In the interest of public health and to uphold the Council's policies set out in the South Dublin County Council Development Plan.
4. Construction Noise and Hours.
To control, limit and prevent the generation of unacceptable levels of Environmental Noise Pollution from occurring during construction activity, no Equipment or Machinery (to include pneumatic drills, on-site construction vehicles, generators, etc.) that could give rise to unacceptable levels of noise pollution as set out generally for evening and night-time in S.I. No. 140/2006 - Environmental Noise Regulations 2006 shall be operated on the site before 7.00 hours on weekdays and 9.00 hours on Saturdays nor after 19.00 hours on weekdays and 13.00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.
Any construction work outside these hours that could give rise to unacceptable levels of noise pollution shall only be permitted following a written request to the Planning

Authority and the subsequent receipt of the written consent of the Planning Authority, having regard to the reasonable justification and circumstances and a commitment to minimise as far as practicable any unacceptable noise outside the hours stated above. In this respect, the applicant or developer shall also comply with BS 5228:2009 Noise and Vibration Control on Construction and Open Sites, and have regard to the World Health Organisation (WHO) – Guidelines for Community Noise (1999).

The applicant or developer shall also endeavour to engage in local consultation in respect of any noise sensitive location within 30 metres of the development as approved prior to construction activity commencing on site. Such noise sensitive locations should be provided with the following:

- Schedule of works to include approximate timeframes
- Name and contact details of contractor responsible for managing noise complaints
- Hours of operation- including any scheduled times for the use of equipment likely to be the source of significant noise.

REASON: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

5. Landscape Plan

i) The Landscape Plan as submitted shall be implemented in full, within the first planting season following completion of the development. The Landscape Plan to include a detailed Planting Plan and Planting Schedule stating species/varieties, indicative quantities, sizes, rootball presentation and spacings. Planting mixes should contain pollinator-friendly native species (in accordance with the All-Ireland Pollinator Plan 2015-2020).

ii) The applicant shall ensure the boundary planting of an appropriate scale as submitted is implemented to provide screening around the car park. The boundary planting shall consist of semi mature tree and hedge species to provide screening and to soften the built form. The planting shall contain predominantly native species.

iii) Prior to development, the applicant shall submit drawings indicating the hedgerows to the east and west of the vehicular entrance allow vehicles to exit safely whilst allowing drivers to see pedestrians.

REASON: In the interests of amenity, compliance with Development Plan policy, the provision, establishment and maintenance of a reasonable standard of landscape and the proper planning and sustainable development of the area.

6. Sustainable Urban Drainage Systems (SuDS)

The applicant shall include SuDS (Sustainable urban Drainage Systems) features for the proposed development such as but not limited to the following:

- Rain Gardens , Planter boxes with overflow connection to the public surface water sewer.
- Permeable Paving
- Grasscrete
- Green Roofs,
- Rain gardens
- Swales
- Permeable Paving

- Grasscrete
- Channel Rills
- Planter Boxes water butts
- Other such SuDS

The applicant should reference the SDCC Sustainable Drainage Explanatory Design & Evaluation Guide prior to submission.

REASON: To ensure the adequate provision of SuDS

7. Services to be Underground.

All public services to the proposed development, including electrical, information and communications technology (ICT) telephone and street lighting cables and equipment shall be located underground throughout the entire site. There shall also be provision for broadband throughout the site in accordance with the Planning Authority's policy and requirements.

REASON: In the interests of the visual amenities of the area, the proper planning and sustainable development of the area and compliance with the Council's Development Plan.

8. Separation of Foul and Surface Water Drainage.

There shall be complete separation of the foul and surface water drainage systems, both in respect of installation and use. All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.

REASON: In the interest of public health.

9. The use of the pitch shall not extend beyond 9.00 PM weekdays and weekends.

Reason: To protect the amenities of the area.

10. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes in a noise sensitive location, shall not exceed the background level for the night time.

REASON: In the interest of public health.

NOTE: The applicant is advised that under the provisions of Section 34 (13) of the Planning and Development Act 2000 (as amended) a person shall not be entitled solely by reason of a permission to carry out any development.

NOTE: The applicant or developer should ensure that all necessary measures shall be taken by the contractor to prevent the spillage or deposit of clay, rubble or other debris on adjoining roads during the course of the works and to ensure that any such instances arising are remedied immediately.

The Developer is advised that under the provisions of the Construction Products Regulation 2013 (No.305/2011-CPR) All products sourced for use in building process must conform with the statutory requirements of the CPR. For more information on these responsibilities see <http://ec.europa.eu/enterprise/sectors/construction/legislation>.

From March 1, 2014, the Building Control (Amendment) Regulations 2013 (SI 80 of 2013) come into effect. All Commencement Notices for works greater than 40sq.m are obliged to be accompanied by a number of certified undertakings as described by these Regulations.

Please note that upon receipt of this document you are obliged to remove the planning site notice in compliance with Article 20 of the Planning and Development Regulations 2001, as amended.

Please note that any valid submissions or observations received in accordance with the provisions of the Planning and Development Regulations 2001, as amended, have been considered in the determination of this application.

Signed on behalf of the South Dublin County Council.

Pamela Hughes 24-Nov-2022
for **Senior Planner**

NOTES

(A) REFUND OF FEES SUBMITTED WITH A PLANNING APPLICATION

Provision is made for a partial refund of fees in the case of certain repeat applications submitted within a period of twelve months where the full standard fee was paid in respect of the first application and where both applications related to developments of the same character or description and to the same site. An application for a refund must be made in writing to the Planning Authority and received by them within a period of two months beginning on the date of the Planning Authority's decision on the second application. For full details of fees, refunds and exemptions the Planning & Development Regulations, 2001 should be consulted.

(A) APPEALS

1. An appeal against the decision may be made to An Bord Pleanála. The applicant or ANY OTHER PERSON who made submissions or observations to the Local Authority may appeal within FOUR WEEKS beginning on the date of this decision. (N.B. Not the date on which the decision is sent or received).
1. Every appeal must be made in writing and must state the subject matter and full grounds of appeal. It must be fully complete from the start. In the case of a third party appeal it must be accompanied by the acknowledgement by the Planning Authority of receipt of the submissions/observations. Appeals should be sent to:
 2. The Secretary, An Bord Pleanála, 64 Marlborough Street, Dublin 1.
3. An Appeal lodged by an applicant/ agent or by a third party with An Bord Pleanála will be invalid unless accompanied by the prescribed fee. A schedule of fees is at 7 below.
4. A party to an appeal making a request to An Bord Pleanála for an Oral Hearing of an appeal must, in addition to the prescribed fee, pay to An Bord Pleanála a further fee (see 7 (g) below).
5. A person who is not a party to an appeal must pay a fee to An Bord Pleanála when making submissions or observations to An Bord Pleanála in relation to an appeal.
6. If the Council makes a decision to grant permission/grant permission consequent on a grant of outline permission and there is no appeal to An Bord Pleanála against this decision, PERMISSION/PERMISSION CONSEQUENT ON A GRANT OF OUTLINE PERMISSION will be granted by the Council as soon as may be after the expiration of the period for the taking of such an appeal. If any appeal made in accordance with the Acts has been withdrawn, the Council will grant the PERMISSION/PERMISSION CONSEQUENT ON A GRANT OF OUTLINE PERMISSION/RETENTION as soon as may be after the withdrawal.
7. Fees payable to An Bord Pleanála from 10th December 2007 are as follows:
 - (a) Appeal against a decision of a Planning Authority on a planning application relating to commercial development made by the person by whom the planning application was made.
where the application relates to unauthorised development €4,500.00 or €9,000 if an E.I.A.R. is involved
 - (b) Appeal against a decision of a planning authority on a planning application relating to commercial development made by the person by whom the planning application was made.
other than an appeal mentioned at (a)..... €1,500.00 or €3,000.00 if an E.I.A.R. is involved
 - (c) Appeal made by the person by whom the planning application was made, where the application relates to unauthorised development other than an appeal mentioned at (a) or (b) €660.00
 - (d) Appeal other than an appeal mentioned at (a), (b), (c) or (f) €220.00
 - (e) Application for leave to appeal €110.00
 - (f) Appeal following a grant of leave to appeal €110.00
 - (g) Referral..... €220.00
 - (h) Reduced fee (payable by specified bodies)..... €110.00
 - (i) Submission or observations (by observer) €50.00
 - (j) Request from a party for an Oral Hearing €50.00

If in doubt regarding any of the above appeal matters, you should contact An Bord Pleanála for clarification at

Telephone 01-858 8100