

**Irish Water's Statutory  
Response to**

**South Dublin**

**Planning Authority**



**Uisce Éireann**  
Bosca OP 6000  
Baile Átha Cliath 1  
Éire

**Irish Water**  
PO Box 6000  
Dublin 1  
Ireland

T: +353 1 89 25000  
F: +353 1 89 25001  
[www.water.ie](http://www.water.ie)

**Planning Application No.**

SD22A/0395

**Date Lodged with Planning Authority:**

20/10/2022

**Development:**

Retention for carwash facility.

**Location :**

Old Bawn Shopping Centre, Old Bawn Road, Tallaght, Dublin 24

**IW Recommendation:** **Further Information Required**

**IW Observations:**

1 Water (Further Information Required)

1.1 The applicant has not submitted any drawings showing water connections for the proposed development. Submit a drawing showing proposed water connections for the proposed development.

1.2 Prior to the commencement of development the applicant or developer shall enter into a water connection agreement(s) with Irish Water.

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul (No Objection)

2.1 Prior to the commencement of development the applicant or developer shall enter into a wastewater connection agreement(s) with Irish Water.

Reason: In the interest of public health and to ensure adequate waste water facilities.

Signed on Behalf of Irish Water: Yvonne Harris

Date: 25/11/2022

