

Turnpike Business Park, Turnpike Lane, Dublin 22. Tel: 01-460 0214 | Web; www.winthrop.ie | Email: info@winthrop.ie

Planning Department

Re: Planning Application

(Reg Ref SD19A/0042, SD22A/0105, ABP-305948-19)

Condition 3

South Dublin County Council

County Hall Town Centre Tallaght

Dublin 24, D24YNN5

Date: Client: 21st November 2022

EdgeConnex Ireland Limited

Project no:

1205

Dear Sir/Madam,

As the Main Contractor engaged by EdgeConnex Ireland Limited, We Winthrop Engineering Limited (WEC) submit the required information to the planning authority as required under Condition 3 of planning permission conditions under Reg Ref SD19A/0042, SD22A/0105, ABP-305948-19.

Condition 3:

Minimise Air Blown Dust.

During the construction and or demolition phase of the development, Best Practicable Means shall be employed to minimize air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances. The applicant/developer shall comply with British Standard B.S. 5228 Noise Control on Construction and Open sites and British Standard B.S. 6187 Code of Practice for demolition.

See below outlined response, WEC will undertake to ensure compliance with the above condition.

During Construction and or demolition phase of the development, Best Practicable Means will be employed to minimize air blown dust emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances, WEC will comply with British Standard B.S. 5228 Code of Practice Noise Control on Construction and Open sites and British Standard B.S. 6187 Code of Practice for Demolition.

In Support of Condition 3 we enclose.

Construction Management Plan: Section 21.3 refers.

Yours faithfully,

Project Manager