




LEGEND




SITE PLAN (1:250)


#	Name	Parameter	Min	Max	Average	Min/average	Min/max
1	Lidl Carpark	Perpendicular Illuminance	.4 lx	34 lx	5.0 lx	0.04	0.126



VEELITE DUROSTAR



VEELITE CHI SERIES



VEELITE MARGEN WALL LIGHT

DUROSTAR SERIES FORWARD THROW OPTIC 2, 30 W LED (SDRS09LGA-FT2) 2700K, ON 4M POLES (WITHOUT RAM PROTECTION)
 DUROSTAR SERIES FORWARD THROW OPTIC 2, 30 W LED (SDRS09LGA-FT2) 2700K, ON 4M POLES WITH PIR DETECTION AND ON BMS
 VEELITE CHI SERIES, 36W LED (SCH15LGA-C6) 2700K, 4 M HIGH
 VEELITE MARGEN RECESSED WALL LIGHT 13 WATT LED 2700K

REAR COWL

NOTE :
 1. REFER TO 'VEELITE' LIGHTING SPEC FOR FURTHER DETAILS.
 2. COLOR TEMPERATURE OF EXTERNAL LIGHTING TO BE 2700K.
 3. EXACT LOCATIONS OF EXTERNAL LIGHTING T.B.C. ON SITE.
 4. ALL LIGHTING COLUMNS TO BE LOCATED MINIMUM 750 FROM KERB.
 5. ALL FITTINGS TO BE CENTERED WITH CAR PARK LINE MARKINGS.

Isolines

- 1.0 lx
- 2.5 lx
- 5.0 lx
- 10.0 lx
- 20.0 lx
- 25.0 lx

Rev	Date	Amendments
03	09.11.22	ISSUED FOR F.I.R.
02	01.11.22	ISSUED FOR F.I.R.
01	13.07.22	ISSUED FOR PLANNING
00	07.07.22	ISSUED FOR INFORMATION PURPOSES



7 Patrick Street
 Kilkenny

Telephone: 056 7721115
 Email: info@lawlerconsulting.com
 Web: www.lawlerconsulting.com

LAWLER CONSULTING

Title

LIDL NEWCASTLE
 AT MAIN STREET UPPER, NEWCASTLE, CO. DUBLIN
 SITE PLAN
 NEW LIDL STORE SITE LIGHTING LAYOUT

Drawn by:	Scale:	Date:
A.S	AS NOTED @ A1	NOV 22
Checked by:	Drawing no.	Rev.
J.C	5197-S100	03