

ENVIRONMENTAL HEALTH - PLANNING MEMO

Date: 15-Nov-2022
Register Reference: SDZ22A/0014
Development: Development on 2 sites separated by the permitted Celbridge Link Road with a total area of 6.36 Ha; The south-western site (5.39 Ha) is generally bound to the east by Celbridge Link Road, to the south and west by undeveloped land and an electrical substation and to the north by the Tubber Lane Development Area. The north-eastern site (0.97 Ha) is generally bound to the east by the undeveloped Primary School site and Aderrig Park Avenue, to the south by Airlie Park Road West and the undeveloped Primary School site, to the west by Celbridge Link Road and the Tubber Lane Development Area and to the north by the Tubbermaclugg Village Development Area.
This application is being made in accordance with the Adamstown Planning Scheme 2014 (as amended) and relates to a proposed development within the Aderrig Development Area of the Adamstown Strategic Development Zone; The proposed development will principally consist of: the demolition and removal of derelict hardstanding and walls; and the construction of 207 residential units (64 two bed, 127 three bed and 16 four bed), ranging in height from 2 storeys to 4 storeys, comprising 75 houses (59 three bed and 16 four bed) and 132 duplexes (64 town bed and 68 three bed); The development will also include: vehicular junctions to access the development from Celbridge Link Road (2 No.) and Adamstown Way (3No.); internal road, cycle and footpath network; 314 car parking spaces; cycle parking; bin storage areas; public, communal and private open space areas, with balconies and terraces facing all aspects; hard and soft landscaped areas; boundary treatments; public lighting; 2 sub-stations; and all associated site and development works above and below ground.

Location: In the townland of Aderrig, Adamstown, Lucan, Co. Dublin
Applicant: Quintain Developments Ireland Limited
App. Type: SDZ Application
Planning Officer: SARAH WATSON
Date Received: 26-Oct-2022
Decision Due Date: 20-Dec-2022

The proposal is **acceptable** to Environmental Health subject to the following conditions set out below:

1. No heavy / noisy construction equipment or machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 hours on Saturdays nor after 19:00 hours on weekdays and 13:00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.
2. Noise levels arising from construction activities shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give rise to a noise nuisance affecting a person in any premises in the neighbourhood.
3. During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.
4. A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.
5. The applicant shall put in place a pest control contract for the site for the duration of the construction works.
6. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level by more than 10 dB(A).
7. Any connections to the main sewer must be connected so as not to give rise to a public health nuisance.
8. Signage or lighting to be used on site during both construction and the on-going operation of the development must not be intrusive to any light sensitive location including residential properties in close proximity to the development.
9. Clearly audible or impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.

Mark Whelan

Mark Whelan
Environmental Health Officer



Kieran Groarke
Environmental Health Officer