

Water Services Planning Report

Register Reference No.: *SD22A/0330 AI*
Development: Construction of a single storey valeting building and canopy and associated site works and services.

Location: Units 5, (Nissan) and Volkswagen Valley Motor Mall,
Dublin 22

Report Date : 22nd December 2022

Surface Water Report:

No objection subject to:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Zsolt Szombatfalvi EE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____