

# Water Services Planning Report

**Register Reference No.:** SD22A/0422

**Development:** Amendments to the residential development permitted under An Bord Pleanála Reference ABP-305556-19 comprising of the omission of a permitted vehicular access ramp from ground to basement level of the existing Citywest Shopping Centre along the southern elevation; The permitted entrance to the ramp is proposed to be replaced at surface level with 5 car parking spaces, with associated amendments to the parking layout, pedestrian paths and landscaping in the immediate vicinity; An increase in the area of a permitted surface to basement level circulation core in the south-eastern corner of the existing Citywest Shopping Centre (to incorporate a lift and revised stairwell design), together with associated amendments to pedestrian paths and landscaping in the immediate vicinity; The relocation of permitted demountable bollards further eastwards along a permitted roadway to the south-east of the Citywest Shopping Centre; The enlargement of a permitted hammerhead circulation area to the south-east of the Citywest Shopping Centre and the provision of a standalone ESB Substation to the south-east of Block D; These amendments are provided to reprove the operational efficiency of the vehicle circulation and parking arrangement to service the permitted apartment buildings and to meet the requirements of ESB to serve the site.

**Location:** Citywest Shopping Centre, Fortunestown, Dublin 24

**Report Date :** 20-Dec-22

---

## Surface Water Report:

**No objection subject to:**

1. Include SuDS (Sustainable Drainage Systems) such as green area, swales, permeable paving and other such SuDS

## **Flood Risk**

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
  - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
- 

## Water Report:

**Referred to IW**

**Water Services Planning Report**

**Foul Drainage Report:**

**Referred to IW**

Signed: \_\_\_\_\_  
          Brian Harkin SEE.

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
          Juliene Helbert SE

Date: \_\_\_\_\_