

Water Services Planning Report

Register Reference No.: SD22A/0437

Development: New single storey prefabricated building containing a classroom of 79.5sqm and associated site works located on the eastern boundary of Riverview Educate Together's external play area.

Location: Riverview Educate Together National School, Limekiln Road, Greenhills, Dublin 12

Report Date : 06-Jan-23

Surface Water Report:

Additional Information Required:

- 1.1 The applicant is required to submit drawings of the existing and proposed plan for Surface Water Layout on site.
- 1.2 There are no SuDS (Sustainable Drainage Systems) features proposed for the development. Submit a drawing in plan and cross-sectional views showing proposed Sustainable Drainage Systems (SuDS) features for the development.
- 1.3 Show in a report calculations of how much surface water attenuation is required in m³ and show how much surface water attention is provided in m³.
- 1.4 Show on a drawing where surface water attenuation is provided and how much surface water attenuation is provided in m³.

Flood Risk

No Objection:

- 1.1 The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- 1.2 All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Zsolt Szombatfalvi EE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____