

Water Services Planning Report

Register Reference No.: SD22A/0438

Development: New stainless steel and glass bus shelter, 5.2m x 1.85m x 2.8m high with 2 internally illuminated advertising panels each of 2sqm area on the public footpath.

Location: Bus stop 1320, Grange Road (near junction with Nutgrove), Rathfarnham, Dublin 14

Report Date : 11-Jan-23

Surface Water Report:

Further Information required:

1. Submit a drawing showing the setback distance from the foundation of proposed development to adjacent 450mm surface water sewer.

Flood Risk

No Objection:

1. All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Zsolt Szombatfalvi EE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____