

User input indicated by **Orange fields**


User Input	
Zoning lookup	Minimum GI Score
EE	0.5

1. Enter Development Site Area m ² HERE ▶		16708	
Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m ²	Factor Values
1. Short Lawn	0.3	5081	1524.3
2. Tall Lawn (wild, not mown)	0.5	0	0
Permeable Paving	0.3	227	68.1
Vegetation		0	0
4a. Vegetation-Shrub below 3cm	0.4	0	0
4b. Vegetation-Shrub / Hedgerow above 3cm	0.5	293	146.5
4c. Vegetation-Pollinator friendly perennial planting	0.5	0	0
4d. Vegetation-Preserved hedgerow	1.2	4366	5239.2
Trees		0	0
5a. New trees	0.6	21	12.6
5b. Preserved trees	1.2	1510	1812
7. SuDS intervention (rain garden, bioswale)	0.6	299	179.4
Green Roof		0	0
9a. Green Roofs- Intensive green roof (substrate is 1 metre or greater in depth)	0.7	0	0
9b. Green Roofs - Extensive green roof (less than 1 metre in depth)	0.6	0	0
10. Green wall	0.4	0	0
11. Retained Open Water	2	0	0
12. New open water	1.5	0	0
Total Equivalent Surface Area of Greening Factors		11,797.00	

**Green Factor
Numerator**
8982.10

Minimum Required GI score	Final GI score	Result
0.5	0.54	Pass

JANE MCCORKELL
DESIGN

 13 Churchfield Grove, Churchfield, Ashbourne, Co. Meath.
Ph: 087 6839520 Email: jane@janemccorkell.com

The Irish Landscape Institute 2022 - 2023
**Registered
Landscape
Architect**

Title: Proposed landscape Green Factor

Client: Origo Distribution Limited

 Project: 23 Magna Drive, Magna Business Park,
Citywest, Dublin 24.

Dwg ref: PP394-03

Scale: - Size: A4

Date: JAN 2023

Drawn by: SH

Checked by: JMC

Rev: