

ENVIRONMENTAL HEALTH - PLANNING MEMO

Date: 17-Jan-2023
Register Reference: SD22A/0342
Development: Construction of a four-storey apartment block (4224 sq.m) consisting of 58 age friendly residential units comprising 20 one bedroom units and 38 two bedroom units with associated private balconies, associated lift and stair cores, entrance lobby, and circulation space; Provision of a community facility (99.3 sq.m) and ancillary accommodation including refuse store (26.9 sq.m), cycle store (36 sq.m), plant room (46.2 sq.m), sub-station (14 sq.m), switch room (16 sq.m), landscaped public open space (907.4 sq.m) and communal open space (1225.6 sq.m), and 30 car parking spaces and 80no. cycle parking spaces to serve the development; Vehicular access to the development will be provided via an upgraded entrance from Tay Lane with a minor pedestrian access provided from Eaton Drive to facilitate direct linkages to the town centre; Planning permission is also sought for all ancillary site and development works above and below ground to facilitate the development including the provision of internal access roads and pedestrian / cycle pathways and linkages, boundary treatment, public lighting, hard and soft landscaping, services, rooftop PV panels and associated signage.

Location: Lands located to the east of Tay Lane, Newcastle Road, Rathcoole, Dublin 24

Applicant: Riverside Projects Limited
App. Type: Permission
Planning Officer: AOIFE O'CONNOR MASSINGHAM
Date Received: 20-Dec-2022
Decision Due: 25-Jan-2023

The proposal is **acceptable** to Environmental Health subject to the following conditions set out below:

1. No heavy / noisy construction equipment or machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 hours on Saturdays nor after 19:00 hours on weekdays and 13:00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.

2. Noise levels arising from construction activities shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give rise to a noise nuisance affecting a person in any premises in the neighbourhood.
3. During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.
4. A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.
5. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level by more than 10 dB(A).
6. Any connections to the main sewer must be connected so as not to give rise to a public health nuisance.
7. Clearly audible or impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.
8. The applicant shall put in place a pest control contract for the site for the duration of the construction works.
9. Signage or lighting to be used on site during both construction and the on-going operation of the development must not be intrusive to any light sensitive location including residential properties in close proximity to the development.

Mark Whelan

Mark Whelan

Environmental Health Officer

Nate De

Senior Environmental Health Officer