

An Rannóg Talamhúsaíde, Pleanála agus Iompair
Land Use, Planning & Transportation Department
Telephone: 01 4149000 Fax: 01 4149104

Email: Planningdept@sdublincoco.ie

IIPS - Integrated Project Services
2nd Floor
Block 43B, Yeats Way
Park West Business Park
Dublin 12

**NOTIFICATION TO GRANT PERMISSION
PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING
REGULATIONS THEREUNDER**

Final Grant Order No.:	0873	Date of Final Grant:	13-Jul-2022
Decision Order No.:	0687	Date of Decision:	01-Jun-2022
Register Reference:	SD21A/0346	Date:	05-May-2022

Applicant: Pfizer Ireland Pharmaceuticals

Development: New external Freezer Plant Platform Structure; single storey MRO Stores building within the existing construction compound; external Data Centre unit to the south of the existing Manufacturing Suites Building; airlock extension & relocated external double emergency exit doors to the south of the existing Manufacturing Suites Building; Pallet Storage building adjacent to the existing Drum Store West building within the Utility Yard and boiler Water Chemical Dosing Unit within the CUB yard and all associated site works.

Location: Grange Castle Business Park, New Nangor Road, Clondalkin, Dublin 22

Time extension(s) up to and including:

Additional Information Requested/Received: 22-Feb-2022 / 05-May-2022

A Permission has been granted for the development described above, subject to the following conditions.

Conditions and Reasons:

1. Development to be in accordance with submitted plans and details.

The development shall be carried out and completed in its entirety in accordance with the plans, particulars and specifications lodged with the application, and as amended by Further Information received on 5th May 2022, save as may be required by the other conditions attached hereto.

REASON: To ensure that the development shall be in accordance with the permission, and that effective control be maintained.

2. Conditions

All conditions of the previously permitted development on this subject site, to which this application will have the effect of creating modifications to shall apply, save as may be required by the other conditions attached hereto.

REASON: In the interest of the proper planning and sustainable development of the area.

3. (i) The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
(ii) All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
(iii) All works for this development shall comply with the requirements of Irish Water's Standards, Codes and Practices.

REASON: In the interest of the proper planning and sustainable development of the area.

4. Minimise Air Blown Dust.

During the construction and or demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances. The applicant/developer shall comply with British Standard B.S. 5228 Noise Control on Construction and Open sites and British Standard B.S. 6187 Code of Practice for demolition.

REASON: In the interest of public health and to uphold the Council's policies set out in the South Dublin County Council Development Plan.

5. Construction Noise and Hours.

To control, limit and prevent the generation of unacceptable levels of Environmental Noise Pollution from occurring during construction activity, no Equipment or Machinery (to include pneumatic drills, on-site construction vehicles, generators, etc.) that could give rise to unacceptable levels of noise pollution as set out generally for evening and night-time in S.I. No. 140/2006 - Environmental Noise Regulations 2006 shall be operated on the site before 7.00 hours on weekdays and 9.00 hours on Saturdays nor after 19.00 hours on weekdays and 13.00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays. Any construction work outside these hours that could give rise to unacceptable levels of noise pollution shall only be permitted following a written request to the Planning Authority and the subsequent receipt of the written consent of the Planning Authority, having regard to the reasonable justification and circumstances and a commitment to minimise as far as practicable any unacceptable noise outside the hours stated above. In this respect, the applicant or developer shall also comply with BS 5228:2009 Noise and Vibration Control on Construction and Open Sites, and have regard to the World Health Organisation (WHO) – Guidelines for Community Noise (1999).

The applicant or developer shall also endeavour to engage in local consultation in respect of any noise sensitive location within 30 metres of the development as approved prior to construction activity commencing on site. Such noise sensitive locations should be provided with the following:

- Schedule of works to include approximate timeframes
- Name and contact details of contractor responsible for managing noise complaints
- Hours of operation- including any scheduled times for the use of equipment likely to be the source of significant noise.

REASON: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

6. Operational Noise.

(a) Noise due to the normal operation of the proposed development, expressed as L_{Aeq} over 15 minutes at the façade of any noise sensitive location, shall not exceed the daytime background level i.e. 0700 – 1900 by more than 10 dB(A) and shall not exceed the background level for evening and night time (currently 19:00 – 07:00) as determined in S.I. No. 140/2006 - Environmental Noise Regulations 2006 .

Clearly audible and impulsive tones at noise sensitive locations during evening and night as determined in S.I. No. 140/2006 - Environmental Noise Regulations 2006 shall be avoided irrespective of the noise level.

(b) Noise levels from the proposed development shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give reasonable cause for annoyance to a person in any residence, adjoining premises or public place in the vicinity.

(c) All mechanical plant and ventilation inlets and outlets should be sound insulated and/or fitted with sound attenuators as necessary to ensure that the noise level as expressed as L_{Aeq} over 15 minutes at 1 meter from the façade of any noise sensitive location does not exceed the background level by more than 10 dB(A) for daytime and shall not exceed the background level for evening and night time (currently 19:00 – 07:00) as determined in S.I. No. 140/2006 - Environmental Noise Regulations 2006.

REASON: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

7. (i) No heavy construction equipment/machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 on Saturdays nor after 19:00 hours on weekdays and 1300 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays. Any work outside of these hours shall only be permitted following a written request to the Planning Authority and subsequent receipt of the written consent of the Planning Authority, having regard to the reasonable justification and circumstances and a commitment to minimise as far as practicable any unwanted noise outside the hours stated above.

(ii) A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.

(iii) The development shall be so operated that there will be no emissions of malodours, gas, dust, fumes or other deleterious materials, no noise vibration on site so as would give reasonable cause for annoyance to any person in any adjoining unit or public place in the vicinity.

REASON: In the interest of the proper planning and sustainable development of the area.

8. Financial Contribution.

The developer shall pay to the Planning Authority a financial contribution of €61,329.96 (sixty one thousand three hundred and twenty nine euros and ninety six cents), in respect of public infrastructure and facilities benefiting development within the area of the Planning Authority, that is provided, or intended to be provided by or on behalf of the authority, in accordance with the terms of the Development Contribution Scheme 2021 - 2025, made under Section 48 of the Planning and Development Acts 2000-2011 (as amended).

The contributions under the Scheme shall be payable prior to commencement of development or as otherwise agreed in writing by the Council. Contributions due in respect of permission

for retention will become payable immediately on issue of the final grant of permission. Contributions shall be payable at the index adjusted rate pertaining to the year in which implementation of the planning permission is commenced.

REASON: The provision of such facilities will facilitate the proposed development. It is considered reasonable that the payment of a contribution be required, in respect of public infrastructure and facilities benefiting development in the area of the Planning Authority and that is provided, or that is intended will be provided, by or on behalf of the Local Authority.

NOTE RE: CONDITION - Please note that with effect from 1st January 2014, Irish Water is now the statutory body responsible for water services. Further details/clarification can be obtained from Irish Water at Tel. 01 6021000 or by emailing customerservice@water.ie.

NOTE: The applicant is advised that under the provisions of Section 34 (13) of the Planning and Development Act 2000 (as amended) a person shall not be entitled solely by reason of a permission to carry out any development.

NOTE: The applicant is advised that in the event of encroachment or oversailing of adjoining property, the consent of the adjoining property owner is required.

NOTE: The applicant or developer should ensure that all necessary measures shall be taken by the contractor to prevent the spillage or deposit of clay, rubble or other debris on adjoining roads during the course of the works and to ensure that any such instances arising are remedied immediately.

NOTE: Waste, arising from the site, must be kept to a minimum, segregated where appropriate, and disposed in accordance with the Waste Management Regulations 2007, as amended. Transport of such waste, must be by an authorised waste permit holder. Waste disposal records must be maintained and made available, for inspection by Authorised Persons appointed under the Waste Management Act 1996, as amended. A Waste Transfer Form shall accompany the transportation of all hazardous waste arising from the construction works.

NOTE: The applicant is advised that where industrial effluent is produced or stored a licence may be required under the provisions of the Waste Management Act.

NOTE: A Roads Opening Licence must be obtained from South Dublin County Council prior to the commencement of any works in the public domain in order to comply with the Roads Act 1993, Section 13, paragraph 10. Under this Act, non-compliance constitutes an offence.

NOTE: Notwithstanding any grant of planning permission; if an applicant requires permission to access local authority land (e.g. public footpaths, public open space or roadways) in order to access utilities, or for any other reason; please apply via <https://maproadroadworkslicensing.ie/MRL/> for a licence from the Local Authority to carry out those works.

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1997.
- (2) Building Control Regulations require a Commencement Notice. Please log onto www.localgov.ie and click on BCMS link.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.

- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1: Structural use of reinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

M. Dodrill

_____13-Jul-2022
for Senior Planner