

Register Reference: SD22A/0455

Development: Demolish existing structures and construct three detached, storey and a half dwelling houses and connect to public sewer, widening of existing vehicular entrance and a new gate together with all ancillary site works and services.

Location: Perrystown (laneway of Perrystown avenue), Perrystown, Dublin 12

Applicant: Kristian Hogan, Ciara, Jarlath and Kevin Dolan

Application Type: Permission

Planning Officer:

Development Summary: As development summary

Decision:

Noise pollution and air pollution restrictions will be necessary for the construction phase.

The above proposal **is acceptable** to the Environmental Health Department subject to the following conditions:

Construction Phase

Noise

1. To control, limit and prevent the generation of Environmental Noise Pollution from occurring the Environmental Health Department of South Dublin County Council, hereby informs you that :

The use of machinery, plant, or equipment (which includes pneumatic drills, generators and the movement on and off the site of construction vehicles) is NOT PERMITTED outside the following hours

- Before 07.00 hours on weekdays, Monday to Friday
- Before 09.00 hours on Saturdays.
- After 19.00 hours on weekdays, Monday to Friday.
- After 13.00 hours on Saturdays.

- Not permitted at any time on Sundays, Bank Holidays or Public Holidays.

Reason: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

Air Quality

During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.

Reason: To contain dust arising from construction / demolition in the interests of public health and to prevent nuisance being caused to occupiers of buildings in the vicinity.

Gillian Wynne

Senior Environmental Health Officer

21st December 2022

David OBrien

Principal Environmental Health Officer

21st December 2022

