

Water Services Planning Report

Register Reference No.: *SD22A/0345 AI*

Development: Alterations, extension and upgrades to the existing terminal building and all ancillary site development works; The proposed development, resulting in an increase of c. 313sq.m. GFA to the existing terminal building, will comprise; Removal of an existing canopy and construction of an extended entrance foyer, provision of ancillary cafe and outdoor seating area and segregated arrivals/departures vestibules at Ground Floor level; construction of an outdoor terrace with access from existing restaurant including overhead brise soleil sun shade and upgrades to existing WC block at first floor level; Construction of additional offices, plant room and provision of additional window openings at second floor level; Construction of a fire escape stairwell adjacent to the existing terminal with connecting walkway and access doorway at first floor level, covered walkway between the existing terminal building and the existing National Flight Centre building at ground level, erection of new signage, relocation of surface water / wastewater infrastructure and enhancements to the existing set down area and car park to include landscaping, paved pedestrian zones and a proposed gated service entrance to the airside apron. Car park enhancements to result in reduction in car parking spaces from existing 219 to proposed 191.

Location: Weston Airport, Backweston Park, Leixlip, Dublin, W23 XHF8

Report Date : 23rd Jan 2023

Surface Water Report:

No Objection Subject To:

1.1 Include SuDS (Sustainable Drainage Systems) in proposed development.

Examples of SuDS which may be suitable include but are not limited to:

- Permeable paving
- Green roofs
- Grasscrete
- Rain garden
- Planter box
- Tree pits
- Other such SuDS

Water Services Planning Report

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
 Brian Harkin SEE

Date: _____

Endorsed: _____
 Juliene Helbert SE

Date: _____