

Water Services Planning Report

Register Reference No.: SD22A/0453

Development: Amend previously permitted application Ref. SD21A/0230 consisting of the installation of two external water tanks and associated concrete slabs, guardrails and access ladders, to the north-east of Units F & G (currently under construction) and all associated landscaping, infrastructure and site development works to facilitate the development.

Location: Unit F & G, In the townland of Collegeland, Baldonnell Business Park, Dublin 22.

Report Date : 30-Jan-23

Surface Water Report:

No Objection:

Flood Risk

No Objection:

1.1 The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.

1.2 All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Zsolt Szombatfalvi EE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____