

Water Services Planning Report

Register Reference No.: *SD22A/0410 AI*
Development: Retention of construction of canopy structure to the west of the main school building.
Location: Lucan East Educate Together N.S, Kishogue Cross, Lucan, Co Dublin
Report Date : 9th February 2023

Surface Water Report: **No objection subject to:**

1.1 The applicant shall consider the use of planter boxes or water butts to deal with surface water from the proposed development.

- Flood Risk** **No Objection**
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report: **Refer to IW**

Foul Drainage Report: **Refer to IW**

Signed: _____ Date: _____
 Brian Harkin SEE

Endorsed: _____ Date: _____
 Juliene Helbert SE