

Water Services Planning Report

Register Reference No.: *SD22A/0266 AI*
Development: Retention of existing building A1 with new direct link to existing family home providing extra living accommodation; Retention and completion of existing building B to rear North Boundary for use as private family Gym and general store; Retention of single storey shed E in side garden South for storage of equipment used by applicant in relation to his work; Retention and completion of building F located on North side of Land to accommodate the storage of Vintage Cars owned by applicant together with required storage of associated materials; Installation of new on-site treatment system to service proposed development; Completion of all ancillary works in relation to proposed development.
Location: Glenside House, Glassamucky, Bohernabreena, Dublin 24
Report Date : 10/02/2023

Surface Water Report:

No Objection Subject To:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Refer to EHO

Signed: _____
Brian Harkin SEE

Date: _____

Endorsed: _____
Juliene Helbert SE

Date: _____