



General Notes:

1. This drawing is to be read in conjunction with all relevant architectural drawings, indicative survey drawings and mechanical & electrical specifications & schedules.
2. Electrical services to be co-ordinated with all other trades, and to be agreed on site prior to installation.
3. The complete installation shall satisfy ET101:2008, all relevant standards, contract drawings and specification requirements.
4. Access chambers to be provided at every duct junction & every 30m straight run.

Symbols Reference:

Telecom Ducting	TELECOM
ESB Ducting	ESB
Existing ESB Overhead Line	
Public Lighting Ducting	
Landlord Lighting Ducting	
LV Ducting	
ELV Ducting	
Fire Alarm Ducting	
Mini Pillar	

P01	14.06.22	ISSUED FOR CONTRACT	EH	RM
REV	DATE	AMENDMENT	DRN	CHK

Issued for Contract

axiseng
consulting engineers

47 Mount Street Upper
Dublin 2 Ireland
D02 AC55
t: +353 1 491 0044
f: +353 1 491 3155
e: info@axiseng.ie
www.axiseng.ie

Client:	Exeter Ireland Property IVC Limited				
Architect:	Kavanagh Burke				
Project:	Site R – Aerodrome Business Park Site Layout Site Services Layout				
Drg. No.:	SRABP-ST-L00-DR-AXE-E-60102				
Job No.:	21054	Status:	D3	Revision:	P01
Scale:	1:1000 @ A1				

This drawing is the property of axiseng. Copyright is reserved by axiseng and the drawing shall not be copied, reproduced or otherwise used without the consent of axiseng ©.