

Henry J Lyons Architecture & Interiors
51-54 Pearse Street
Dublin 2

**NOTIFICATION TO GRANT PERMISSION FOR RETENTION
PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING
REGULATIONS THEREUNDER**

Final Grant Order No.:	0260	Date of Final Grant:	10-Mar-2023
Decision Order No.:	0101	Date of Decision:	30-Jan-2023
Register Reference:	SD22A/0109	Date:	18-Jan-2023

Applicant: Xilinx Ireland Unlimited Company

Development: Retention of the generator compound (391sq.m) consisting of three generators along with three transformers and ancillary 3 diesel tanks and perimeter treatment on a permanent basis on the southern perimeter of the site with Orchard Avenue; The development also consists of the retention of 3 signs (10.94sq.m) as follows: retention of 1 sign (0.57sq.m) on plinth at the corner of Bianconi Avenue and the N82/Citywest Road; retention of 1 sign (4.58sq.m) on the eastern elevation of Block D facing the N82/Citywest Road and retention of 1 sign (5.79sq.m) on the northern elevation of Block M facing Bianconi Avenue. The development will include retention of all revisions to the permitted landscaping and site development works required.

Location: Bianconi Avenue, Citywest Business Campus, Saggart, Co. Dublin

Time extension(s) up to and including:

Additional Information Requested/Received: 13-Jun-2022 / 18-Jan-2023

A Permission has been granted for the development described above, subject to the following conditions.

Conditions and Reasons:

1. Development to be in accordance with submitted plans and details.
 - a) The development shall be retained and completed fully in accordance with plans, particulars and specifications lodged with the application, save as may be required by other conditions attached hereto.
 - b) Permission is only granted for items specified in the description of development.
REASON: To ensure that the development is in accordance with the permission and that effective control is maintained and to clarify the extent of the permission.
2. Signage Not Internally Lit.
The signage shall not be internally illuminated.
REASON: In the interest of residential amenity, and the proper planning and sustainable development of the area.
3. Signage.
Other than as set out in the description of development, no other advertising sign(s) or structure(s) (including any signs installed to be visible through windows), banners, canopies, flags, or other projecting elements shall be erected except those, which are exempted development, without the prior approval of the Planning Authority or An Bord Pleanála on appeal.

REASON: In the interest of visual amenity, compliance with development plan policies and the proper planning and sustainable development of the area.

4. Operational Noise.

(a) Noise due to the normal operation of the proposed development, expressed as LAeq over 15 minutes at the façade of any noise sensitive location, shall not exceed the daytime background level i.e. 0700 – 1900 by more than 10 dB(A) and shall not exceed the background level for evening and night time (currently 19:00 – 07:00) as determined in S.I. No. 140/2006 - Environmental Noise Regulations 2006 .

Clearly audible and impulsive tones at noise sensitive locations during evening and night as determined in S.I. No. 140/2006 - Environmental Noise Regulations 2006 shall be avoided irrespective of the noise level.

(b) Noise levels from the proposed development shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give reasonable cause for annoyance to a person in any residence, adjoining premises or public place in the vicinity.

(c) All mechanical plant and ventilation inlets and outlets should be sound insulated and/or fitted with sound attenuators as necessary to ensure that the noise level as expressed as LAeq over 15 minutes at 1 meter from the façade of any noise sensitive location does not exceed the background level by more than 10 dB(A) for daytime and shall not exceed the background level for evening and night time (currently 19:00 – 07:00) as determined in S.I. No. 140/2006 - Environmental Noise Regulations 2006.

REASON: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

NOTES :

NOTE: The applicant is advised that under the provisions of Section 34 (13) of the Planning and Development Act 2000 (as amended) a person shall not be entitled solely by reason of a permission to carry out any development.

NOTE: The applicant or developer should ensure that all necessary measures shall be taken by the contractor to prevent the spillage or deposit of clay, rubble or other debris on adjoining roads during the course of the works and to ensure that any such instances arising are remedied immediately.

NOTE: The applicant is advised that where industrial effluent is produced or stored a licence may be required under the provisions of the Waste Management Act or other relevant legislation.

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1997.
- (2) Building Control Regulations require a Commencement Notice. Please log onto www.localgov.ie and click on BCMS link.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.
- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1: Structural use of reinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

M. Crowley

10-Mar-2023

_____ *for Senior Planner*