


SITE PLAN (1:250)

#	Name	Parameter	Min	Max	Average	Min/average	Min/Max
1	Lidl Carpark	Perpendicular Illuminance	.4 lx	34 lx	5.55 lx	0.04	0.024



DUROSTAR SERIES FORWARD THROW OPTIC 2, 30 W LED (SORS09.GA- FT2) 2700K, ON 4M POLES (WITHOUT RAM PROTECTION)
 DUROSTAR SERIES FORWARD THROW OPTIC 2, 30 W LED (SORS09.GA- FT2) 2700K, ON 4M POLES WITH PIR DETECTION AND ON BMS
 VEELITE CHI SERIES, 36W LED (SCH15LGA-08) 2700K, 4 M HIGH
 VEELITE MARGEN RECESSED WALL LIGHT 13 WATT LED 2700K


ZUMTOBEL 20 WATT LED 2700K
 THORN PIAZZA BUILDING MOUNTED 15 WATT LED

NOTE :
 1. REFER TO 'VEELITE' LIGHTING SPEC FOR FURTHER DETAILS.
 2. COLOR TEMPERATURE OF EXTERNAL LIGHTING TO BE 2700K.
 3. EXACT LOCATIONS OF EXTERNAL LIGHTING T.B.C. ON SITE.
 4. ALL LIGHTING COLUMNS TO BE LOCATED MINIMUM 750 FROM KERB.
 5. ALL FITTINGS TO BE CENTERED WITH CAR PARK LINE MARKINGS.

Isolines

- 1.0 lx
- 2.5 lx
- 5.0 lx
- 10.0 lx
- 20.0 lx
- 25.0 lx

Rev	Date	Amendments
06	27.02.23	ISSUED FOR PLANNING
05	18.02.23	ISSUED FOR PLANNING
04	26.01.23	ISSUED FOR PLANNING
03	09.11.22	ISSUED FOR PLANNING
02	01.11.22	ISSUED FOR PLANNING
01	13.07.22	ISSUED FOR PLANNING
00	07.07.22	ISSUED FOR INFORMATION PURPOSES



7 Patrick Street
 Kilkenny
 Telephone: 056 7721115
 Email: info@lawlerconsulting.com
 Web: www.lawlerconsulting.com

LAWLER CONSULTING

Title
 LIDL NEWCASTLE
 AT MAIN STREET UPPER, NEWCASTLE, CO. DUBLIN
 SITE PLAN
 NEW LIDL STORE SITE LIGHTING LAYOUT

Drawn by	Scale	Date
AS	AS NOTED @ A1	FEB 23
Checked by	Drawing no.	Rev.
J.C	5197-S100	06