

Space Plus
Willow Cottage
Dixon Lane
Ballycorus Road
Kiltarnan
Co. Dublin

**NOTIFICATION TO GRANT PERMISSION
PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING
REGULATIONS THEREUNDER**

Final Grant Order No.:	0319	Date of Final Grant:	27-Mar-2023
Decision Order No.:	0162	Date of Decision:	14-Feb-2023
Register Reference:	SD22B/0526	Date:	13-Dec-2022

Applicant: David and Joan Milligan

Development: Single storey flat roof ancillary garden structure to side of existing building with associated site works.

Location: Willow Lodge, Banshee, Straffan, Dublin, W23YW82

Time extension(s) up to and including:

Additional Information Requested/Received:

A Permission has been granted for the development described above, subject to the following conditions.

Conditions and Reasons:

1. Development in accordance with submitted plans and details.
The development shall be carried out and completed in its entirety fully in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.
REASON: To ensure that the development shall be in accordance with the permission and that effective control be maintained.
2. Amendments.
Prior to the commencement of development the applicant, owner or developer shall submit the following for the written agreement of the Planning Authority:
Revised plans that incorporate all of the following amendments-
(a) Omit the WC from the garden room/gym structure.
REASON: To protect the amenities of the area and in the interests of the proper planning and sustainable development of the area.
3. Restriction on Use of the Shed/Garden Room/Gym.
The Shed/Garden Room/Gym shall be used solely for purposes incidental to the enjoyment of the dwelling house as such and shall not be used for habitation or the carrying on of any trade or business, and shall not be sold, let or otherwise transferred or conveyed, save as part of the dwelling.

REASON: In the interest of orderly development and the proper planning and sustainable development of the area.

4. The external walls of the home office shall be finished cement render and painted.

REASON To ensure an acceptable standard of development

5. Surface Drainage.

Within 6 months of the issuance of the Final Grant, the applicant shall install water butts in connection with the approved detached garden soom as a sustainable drainage system measure and thereafter the water butts shall function to infiltrate surface water from the detached structure within the site.

REASON: In the interests of public health, the proper planning and sustainable development of the area and in order to ensure adequate water supply and drainage provision.

6. (a) External Finishes.

All external finishes shall harmonise in colour or texture that is complementary to the house or its context.

REASON: In the interest of visual amenity.

- (b) Restriction on Use.

The house and the proposed extension shall be jointly used as a single dwelling unit for residential purposes and shall not be sub-divided or used for any commercial purposes, and the extension shall not be sold, let (including short-term letting), leased or otherwise transferred or conveyed, by way of sale, letting or otherwise save as part of the single dwelling unit.

REASON: To prevent unauthorised development.

- (c) Minimise Air Blown Dust.

During the construction and or demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances. The applicant/developer shall comply with British Standard B.S. 5228 Noise Control on Construction and Open sites and British Standard B.S. 6187 Code of Practice for demolition.

REASON: In the interest of public health and to uphold the Council's policies set out in the South Dublin County Council Development Plan.

- (d) Construction Noise and Hours.

To control, limit and prevent the generation of unacceptable levels of Environmental Noise Pollution from occurring during construction activity, Equipment or Machinery (to include pneumatic drills, on-site construction vehicles, generators, etc.) that could give rise to unacceptable levels of noise pollution as set out generally for evening and night-time in S.I. No. 140/2006 - Environmental Noise Regulations 2006 shall only be operated on the site between 7.00 hours and 19.00 hours weekdays and between 9.00 hours and 13.00 hours on Saturdays. No works shall take place at any time on Sundays, Bank Holidays or Public Holidays.

Any construction work outside these hours that could give rise to unacceptable levels of noise pollution shall only be permitted following a written request to the Planning Authority and the subsequent receipt of the written consent of the Planning Authority, having regard to the reasonable justification and circumstances and a commitment to minimise as far as practicable any unacceptable noise outside the hours stated above. In this respect, the applicant or developer shall also comply with BS 5228:2009 Noise and Vibration Control on Construction

and Open Sites, and have regard to the World Health Organisation (WHO) – Guidelines for Community Noise (1999).

The applicant or developer shall also endeavour to engage in local consultation in respect of any noise sensitive location within 30 metres of the development as approved prior to construction activity commencing on site. Such noise sensitive locations should be provided with the following:

- Schedule of works to include approximate timeframes
- Name and contact details of contractor responsible for managing noise complaints
- Hours of operation- including any scheduled times for the use of equipment likely to be the source of significant noise.

REASON: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

NOTES :

NOTE: The applicant is advised that under the provisions of Section 34 (13) of the Planning and Development Act 2000 (as amended) a person shall not be entitled solely by reason of a permission to carry out any development.

NOTE: The applicant or developer should ensure that all necessary measures shall be taken by the contractor to prevent the spillage or deposit of clay, rubble or other debris on adjoining roads during the course of the works and to ensure that any such instances arising are remedied immediately.

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1997.
- (2) Building Control Regulations require a Commencement Notice. Please log onto www.localgov.ie and click on BCMS link.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.
- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1: Structural use of reinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

M. Crowley

27-Mar-2023
for Senior Planner