

User input indicated by **Orange fields**

User Input	
Zoning lookup	Minimum GI Score
RES-N	0.5

1. Enter Development Site Area m ² HERE ▶		3139.8	
Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m ²	Factor Values
1. Short Lawn	0.3	96	28.8
2. Tall Lawn (wild, not mown)	0.5	27.5	13.75
Permeable Paving	0.3	1165	349.5
Vegetation		0	0
4a. Vegetation-Shrub below 3m	0.4	0	0
4b. Vegetation-Shrub / Hedgerow above 3m	0.5	134	67
4c. Vegetation-Pollinator friendly perennial planting	0.5	740	370
4d. Vegetation-Preserved hedgerow	1.2	0	0
Trees		0	0
5a. New trees	0.6	163	97.8
5b. Preserved trees	1.2	0	0
7. SuDS intervention (rain garden, bioswale)	0.6	136.8	82.08
Green Roof		0	0
9a. Green Roofs - Intensive green roof (substrate is 200-1200mm in depth)	0.7	0	0
9b. Green Roofs - Extensive green roof (substrate is 80-200mm in depth)	0.6	324	194.4
10. Green wall	0.4	0	0
11. Retained Open Water	2	259	518
12. New open water	1.5	0	0
Total Equivalent Surface Area of Greening Factors		3,045.30	

Green Factor Numerator	1721.33
-------------------------------	----------------

Minumum Required GI score	Final GI score	Result
0.5	0.55	Pass