

Date: 14-Apr-2023**Register Reference:** SDZ22A/0010

Development: Kelland Homes Ltd. intends to apply for permission for development on a site area of 6.3Ha, on lands within the townland of Cappagh, Dublin 22. The proposed development is located west of the Ninth Lock Road, south of the Dublin-Cork railway line, north of Cappaghmore housing estate and Whitton Avenue, and east of an existing carpark / park & ride facility at the Clondalkin Fonthill train station and the R113 (Fonthill Road). The proposed development is located within the Clonburris Strategic Development Zone (SDZ), within the development areas of (i) Clonburris South East (i.e. CSE-S1 & CSE-S2) and (ii) part of Clonburris Urban Centre (i.e. CUC-54), as identified in the Clonburris SDZ Planning Scheme 2019. The proposed development consists of the construction of 294 no. dwellings, creche and retail / commercial unit, which are comprised of: 118 no. 2, 3 & 4 bed, 2 storey semi-detached and terraced houses, 104 no. 2 & 3 bfd duplex units accommodated in 10 no. 3 storey buildings, 72 no. 1 & 2 bedroom apartments in 2 no. 4 & 6 storey buildings, 1 no. 2 storey creche (c.520.2m²), 1 no. 2 storey retail /commercial unit (c.152.1m²). Access to the development will be via the permitted road network (under Ref. SDZ20A/0021) which provides access from the Ninth Lock Road to the east and the R113 (Fonthill Road) to the west. The proposed development will connect into the permitted Infrastructural works as approved under the Clonburris Strategic Development Zone Planning Scheme (2019) and permitted under Ref. SDZ20A/0021, with the proposed development connecting into the permitted surface water drainage attenuation systems i.e. 1 no. pond, 3 no. modular underground storage systems and 1 no. detention basin combined with modular underground systems. The proposed wastewater infrastructure will connect into a permitted foul pumping station and pipe network within proposed road corridors to facilitate drainage connections to future wastewater drainage infrastructure within the adjoining SOZ lands (Including future Irish Water pumping station permitted under SDZ21A/0006). The proposed development also provides for all associated site development works above and below ground, public & communal open spaces, hard & soft landscaping and boundary treatments, surface car parking (401 no. spaces), bicycle parking (797 no. spaces), bin & bicycle storage, public

lighting, plant (M&E), utility services & 4 no. ESB sub-stations. This application is being made in accordance with the Clonburris Strategic Development Zone Planning Scheme 2019 and relates to a proposed development within the Clonburris Strategic Development Planning Scheme Area, as defined by Statutory Instrument No. 604 of 2015.

Location: The proposed development is located west of the Ninth Lock Road, south of the Dublin-Cork railway, line, north of Cappaghmore housing estate and whitton Avenue, and east of an existing carpark/park, & ride facility at the Clondalkin, Fonthill train ststio

Applicant: Kelland Homes Ltd
App. Type: Permission
Planning Officer: CAITLIN O'SHEA
Date Received: 14-Apr- 2023
Decision Due Date: 23-Apr-2023

After reviewing the Additional Information regarding the proposed design and structural noise mitigation measures incorporated in the Acoustic Design Statement submitted by Byrne Environmental Consulting Limited to reduce the potential noise impact on residential properties the development is acceptable to the Environmental Health Service provided the following conditions are adhered to:


1. The houses and apartments of this development are constructed, as appropriate, using the Glazing and Ventilation specified in the Acoustic Design Statement they have submitted, to ensure the required noise mitigation and minimise the potential for adverse effects to the occupants. It must be ensured that these mitigation measures include all relevant noise sensitive properties, where the proximity to the adjacent rail line may have adverse effects on the occupants of the properties.
2. No heavy / noisy construction equipment or machinery (to include pneumatic drills, construction vehicles, generators, etc) shall be operated on or adjacent to the construction site before 07:00 hours on weekdays and 09:00 hours on Saturdays nor after 19:00 hours on weekdays and 13:00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays.
3. Noise levels arising from construction activities shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give rise to a noise nuisance affecting a person in any premises in the neighbourhood.
4. During the construction phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.

5. A suitable location for the storage of refuse shall be provided during the construction and operational phase of the development so as to prevent a public health nuisance.
6. Noise due to the normal operation of the proposed development, expressed as Laeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level by more than 10 dB(A).
7. Clearly audible or impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.
8. Signage or lighting to be used on site during the construction of the development must not be intrusive to any light sensitive location including residential properties in close proximity to the development.
9. The applicant shall ensure that the development shall be operated so that there will be no emissions of malodours, gas, dust, fumes or other deleterious materials on site as would give reasonable cause for annoyance to any person in any residence, adjoining unit or public place in the vicinity.

Yours sincerely,



Kate Kivlehan
Senior Environmental Health Officer



Patricia Doonan
Principal Environmental Health Officer

