



ON ORIGINAL

© COPYRIGHT OF THIS DRAWING IS RESERVED BY DBFL CONSULTING ENGINEERS. NO PART SHALL BE REPRODUCED OR TRANSMITTED WITHOUT THEIR WRITTEN PERMISSION.

NO CHANGES OF WHATSOEVER NATURE ARE TO BE MADE TO ANY DETAILS SET OUT OR CONTAINED IN ANY DBFL SPECIFICATIONS OR DRAWINGS UNLESS THE EXPRESS CONSENT HAS BEEN OBTAINED IN ADVANCE, IN WRITING, FROM DBFL.

NOTES:

GENERAL NOTES:

1. ALL DRAWINGS TO BE CHECKED BY CONTRACTOR ON SITE AND ENGINEER INFORMED OF DISCREPANCIES BEFORE WORK COMMENCES.
2. THE CONTRACTOR SHALL SATISFY HIMSELF AS TO THE ACCURACY OF EXISTING DRAINAGE LEVELS AND LOCATION OF EXISTING SERVICES ON SITE PRIOR TO COMMENCEMENT OF WORKS ON SITE.
3. ALL DIMENSIONS AND LEVELS ARE IN METERS AND ARE RELATED TO ORDINANCE DATUM. CO-ORDINATES RELATE TO IRISH NATIONAL GRID.
4. ALL WATERMANS VALVES AND FITTINGS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE IRISH WATER STANDARD DETAILS AND IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE.
5. ALL WATERMANS SHALL BE HDPE, PE100, SDR17 TO IS EN 12201 PART 2:2011 AND IS EN 12201-3:2011.
6. CONNECTION BETWEEN EXISTING AND PROPOSED WATERMANS TO BE CARRIED OUT IN ACCORDANCE WITH IRISH WATER STANDARD DETAILS STD-W-03 TO STD-W-10.
7. ANCHOR BLOCKS TO BE POSITIONED AT DEAD ENDS, TEES, BENDS AND AT EACH SIDE OF HYDRANTS AND VALVES IN ACCORDANCE WITH THE REQUIREMENTS OF IRISH WATER STANDARD DETAIL STD-W-23 (WATER MAIN THURST AND SUPPORT BLOCKS). DISMANTLING JOINTS TO BE INSTALLED AT EACH SLUICE VALVE AS PER IRISH WATER STANDARD DETAIL STD-W-15.
8. CONNECTION TO INDIVIDUAL HOUSES IN ACCORDANCE WITH IRISH WATER STD-W-03.
9. INSTALLATION OF SLUICE VALVES, AIR VALVES AND HYDRANTS SHALL BE IN ACCORDANCE WITH IRISH WATER STANDARD DETAILS STD-W-14 TO STD-W-23.
10. MARKER POSTS AND PLATES ARE TO BE PROVIDED IN ACCORDANCE WITH IRISH WATER STANDARD DETAIL STD-W-27.
11. CONNECTION TO EXISTING WATERMANS TO BE COORDINATED BY THE CONTRACTOR WITH IRISH WATER AND/OR THE LOCAL AUTHORITY.
12. CONTRACTOR TO LIASE WITH IRISH WATER AND / OR THE LOCAL AUTHORITY AS REQUIRED REGARDING TESTING, CLEANSING AND STERILISATION OF WATERMANS.
13. WATERMANS TO BE PRESSURE TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF IRISH WATER AND IS 4-01-03, GUIDE TO TESTING OF PRESSURE PIPES AND FITTINGS FOR USE BY PUBLIC WATER SUPPLIERS, OCTOBER 2015. A FORMAL TEST REPORT SHALL BE SUBMITTED TO THE ENGINEER DETAILING THE TEST CARRIED OUT.
14. METERS FOR APARTMENTS OR SIMILAR PROPERTIES WILL BE INSTALLED ON THE PREMISES IN ACCORDANCE WITH THE BUILDING CONTROLS AUTHORITY REQUIREMENTS AND SUBJECT TO REVIEW BY IRISH WATER.

LEGEND

- SITE BOUNDARY
- - - CHANGE IN BUILDING FLOOR LEVELS
- - - EXISTING WATERMAIN CONSTRUCTED AS PART OF SEPARATE CONTRACT
- PROPOSED Ø180mm OD PE 100 SDR17 WATERMAIN
- PROPOSED Ø125mm OD PE 100 SDR17 WATERMAIN
- M PROPOSED WATER METER
- SV PROPOSED SLUICE VALVE (W STD-W-14) STD-W-15
- H PROPOSED HYDRANT (W STD-W-18) STD-W-19
- BOUNDARY BOX AND 20mm OD PE100 SERVICE CONNECTION (W STD-W-03)

| | | | | |
|-----|----------|--------------------------------|-----|-------|
| 4 | 12-04-23 | ISSUED FOR FURTHER INFORMATION | RMC | DCB |
| 3 | 25-11-22 | ISSUED FOR PLANNING | DKE | DCB |
| 2 | 04-11-22 | ISSUED FOR PLANNING | DKE | DCB |
| 1 | 21-10-22 | FINAL PLANNING DRAFT | BS | DCB |
| 0 | 10-10-22 | ISSUED FOR PLANNING | BS | DCB |
| rev | date | description | by | chkd. |

STATUS CODES

purpose P1 - INFORMATION acceptance S - ISSUED

DBFL Consulting Engineers
Civil, Structural & Transportation Engineering
www.dbfl.ie

DUBLIN OFFICE: Ormeau House, Upper Ormeau Quay, Dublin 7, D07 WPT4
PHONE: +353 1 206 4000

CORK OFFICE: 14 South Mall, Cork, T12 DT91
PHONE: +353 21 206450

WATERFORD OFFICE: Suite 10 The Arkham, Mathews Gate, Canada Street, Waterford, X91 W028
PHONE: +353 51 309 100

project ref.

CLONBURRIS TILE 3

drawing title
WATERMAIN LAYOUT

client
CAIRN HOMES PROPERTIES LTD

ORDNANCE SURVEY IRELAND LICENCE
No CYAL50276885
© ORDNANCE SURVEY IRELAND
GOVERNMENT OF IRELAND

| | | | |
|----------------------------------|----------|-------|------------|
| designed by | author | scale | sheet size |
| DCB | BS | 1:500 | A1 |
| drawing no. | revision | | |
| CLB-T3-93-SW-DTM-DR-DBFL-CE-1351 | 4 | | |