

Water Services Planning Report

Register Reference No.: *SD22A/0445 AI*

Development: Erect a 24 meter high lattice telecommunications support structure together with antennae, dishes and associated telecommunications equipment, all enclosed in security fencing; The proposed development is located within the curtilage of a Protected Structure.

Location: Esker House, Esker Road, Esker, Co. Dublin

Report Date: **17-May-2023**

Surface Water Report: **Clarification of Additional Information Required:**

1.1 The applicant shall submit a revised drawing in plan and cross-sectional views showing the distance between the proposed foundation and the top of the bank of river. The drawing in cross-sectional view shall include elevation, the distance between the proposed foundation and the river bank, and the river bed. The required setback from the top of the bank of any watercourse is 10m.

Flood Risk

No Objection:

Water Report:

N/A

Foul Drainage Report:

N/A

Signed: _____
 Zsolt Szombatfalvi EE

Date: _____

Endorsed: _____
 Brian Harkin SEE

Date: _____