Water Services Planning Report

Register Reference No.: SD22A/0323 AI

Development: Demolition of a shed & workshop at rear of the Protected

Structure to facilitate the provision of 18 car parking spaces; Construction of 12 dwellings comprising of 8 two storey with attic level accommodation, 4 bedroom semi-detached dwellings (c. 146sq.m each and 4 two storey with attic level accommodation, 3 bedroom semi-detached dwellings (c. 126 sq.m each) with vehicular access at main street; A pedestrian access to Forest Hills

at the southern end of the site and ancillary site

development works all within the curtilage of a Protected

Structure.

Location: Main Street, Rathcoole, Co. Dublin

Report Date: 20th July 2022

Surface Water Report: Clarification of Further Information required:

- **1.1** The applicant is required to submit a drawing a plan, cross-section and longitudinal section of proposed detention basin. Show the dimensions of proposed detention basin, the depth, length and width of same.
- **1.2** Show the capacity in m³ of attenuation volume of detention basin on drawing.
- **1.3** Submit a report to show the surface water attenuation calculations for proposed development. Include the surface type such as roofs, green roofs, roads, permeable paving, grass and size of same in m² and their respective run off coefficients.
- **1.4** Prior to submission of revised documents contact water services in South Dublin County Council to discuss above issues.

Flood Risk No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Report:			Referred to IW	
Foul Drain	age Report:		Referred to IW	
Signed:	Brian Harkin SEE	Date:	Date:	
Endorsed:	Juliene Helhert SE	Date:		