



User input indicated by Orange fields

User Input	
Zoning lookup	Minimum GI Score
Res	0.5

1. Enter Development Site Area m ² HERE ▶		780	
Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m ²	Factor Values
1. Short Lawn	0.3	88.41	26.523
2. Tall Lawn (wild, not mown)	0.5	0	0
Permeable Paving	0.3	253.47	76.041
Vegetation		0	0
4a. Vegetation-Shrub below 3m	0.4	0	0
4b. Vegetation-Shrub / Hedgerow above 3m	0.5	73.8	36.9
4c. Vegetation-Pollinator friendly perennial planting	0.5	49.87	24.935
4d. Vegetation-Preserved hedgerow	1.2	0	0
Trees		0	0
5a. New trees	0.6	55	33
5b. Preserved trees	1.2	0	0
7. SuDS intervention (rain garden, bioswale)	0.6	113.72	68.232
Green Roof		0	0
9a. Green Roofs - Intensive green roof (substrate is 200-1200mm in depth)	0.7	0	0
9b. Green Roofs - Extensive green roof (substrate is 80-200mm in depth)	0.6	171.32	102.792
10. Green wall	0.4	58.62	23.448
11. Retained Open Water	2	0	0
12. New open water	1.5	2.456	3.684
Total Equivalent Surface Area of Greening Factors		866.67	

Green Factor
Numerator

395.56

Minimum Required GI score	Final GI score	Result
0.5	0.51	Pass