

NOT drop calculation for the most open area circuit

NO	SCALE	SHEET	SHEET COUNT	SCALE	COUNT	SCALE	NO. T. PAGES
51	1:1	1	1/29	29x48	200	10	1/31

**TYPE A COLUMN DETAILS**

HEIGHT 6m  
INCLINATION 0 Degrees  
LANTERN QUANTITY 13  
LANTERN DETAILS CU/Phosco P852-12-F24-WK-C80000

**TYPE B COLUMN DETAILS**

HEIGHT 5m  
INCLINATION 0 Degrees  
LANTERN QUANTITY 5  
LANTERN DETAILS CU/Phosco P852-12-F24-WK-C80000


**TYPE C COLUMN DETAILS**

HEIGHT 6m  
INCLINATION 0 Degrees  
LANTERN QUANTITY 51  
LANTERN DETAILS CU/Phosco P852-12-F24-WK-C80000

**TYPE D COLUMN DETAILS**

HEIGHT 10m  
INCLINATION 0 Degrees  
LANTERN QUANTITY 36  
LANTERN DETAILS CU/Phosco P852-256-F4-WK-C80000

Notes:  
All LED lighting must have Constant Light Output (CLO).  
All luminaires to have 7 year minimum warranty.  
All columns to be installed at least 1.5m from any wall.  
All columns to be installed at least 1.5m from any wall.  
All columns to be installed at least 1.5m from any wall.



**NOTES**  
THE DRAWING IS THE INTELLECTUAL PROPERTY OF SABRE ELECTRICAL SERVICES LTD. AND IS CONFIDENTIAL. IT IS NOT TO BE REPRODUCED OR USED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF SABRE ELECTRICAL SERVICES LTD.  
NO ACCOUNT IS TAKEN FOR THE ECONOMIC EFFECT CAUSED BY RAINFALL, THUNDER, ETC. THE CLIENT MUST PROVIDE THE DRAWING ASSUMES THAT THE LOCAL AUTHORITY HAS APPROVED THE LIGHTING PLAN AND THAT THE LOCAL AUTHORITY HAS APPROVED THE LIGHTING PLAN.  
The drawing is based on information provided by the client. Sabre Electrical Services Ltd. accepts no liability for any errors or omissions in the drawing. All work is subject to local authority specifications. This is a general layout and not a final specification of work to be done.  
Public Lighting Plan (based at least on ESB 1000) Public Lighting Code (number as per Local Authority T.Y. Type Specification).

**Sabre**  
ELECTRICAL SERVICES LTD.  
Specialist Contractors  
PUBLIC LIGHTING - FLOOD LIGHTING - SPORTS LIGHTING

UNIT 11,  
BELLEVUE INDUSTRIAL ESTATE,  
FINGLAS,  
DUBLIN 11.  
E - MAIL: [graham@sabrelighting.ie](mailto:graham@sabrelighting.ie) PH: 01-811 0875

NO	DESCRIPTION	DATE	INTS	CHKD
1	Issue for client approval	25-02-22	GR	GR
2	Issue for client approval	25-02-22	GR	GR
3	Issue for client approval	25-02-22	GR	GR
4	Issue for client approval	25-02-22	GR	GR
5	Issue for client approval	25-02-22	GR	GR
6	Issue for client approval	25-02-22	GR	GR
7	Issue for client approval	25-02-22	GR	GR

PROJECT  
Adamstown Boulevard Residential  
TITLE  
Public Lighting Layout  
DRAWN  
G.S.  
SCALE  
1:750@A1  
DATE  
25-02-22  
DRAWING NUMBER  
SES 025222  
ISSUE  
7  
BASE DRAWING NUMBER  
001  
DRAWING ORIGIN  
001  
DO NOT SCALE FROM THIS DRAWING

