

Cairn Homes Properties Limited 45 Mespil Road Dublin 4 D04 W2F1

+353 1 696 4600 www.cairnhomes.com

Planning Compliance Land Use, Planning & Transportation Department South Dublin County Council County Hall Tallaght Dublin 24

By email

18th September 2023

Dear Sir/Madam,

RE: CONDITION 25 – DEVELOPMENT OF 569 DWELLINGS AT CLONBURRIS SOUTH WEST DEVELOPMENT AREA WITHIN THE CLONBURRIS SDZ AT TOWNLANDS OF CAPPAGH, CLONBURRIS LITTLE AND KISHOGE, CO. DUBLIN.

REG REF: SDZ21A/0022

I write on behalf of Cairn Homes Properties Ltd in respect of Reg Ref: SDZ21A/0022 and to discharge the following condition as required.

Condition 25:

Prior to the commencement of development, the applicant/owner shall submit the following for the writtem agreement of the Planning Authority.

- (i) a revised site layout plan clearly setting out full details of the location of all proposed facilities and equipment in the public realm (whether to be offered for taking in charge or not) for charging electric vehicles, including details of the overall height, design, colour and all safety features of such equipment including isolation of power supply, and measures to provide for suitable pedestrian safety, along with completed Electrical designs to serve the development as approved prepared by competent electrical design consultants all of which have been agreed with the Council's Roads Section, and
- (ii) Agreed arrangements for the operation and management of such facilities for charging electric vehicles, along with:

All facilities for charging electric vehicles should be clearly marked as being designated for Electric Vehicle charging. Appropriate signage clearly indicating the presence of a Charge Point or Points should also be erected. All Charge Points fitted in publicly accessible areas should be capable of communicating usage data with the National Charge Point Management System and use the latest version of the Open Charge Point Protocol (OCCP). The facilities for charging electric vehicles should also support a user identification system such as Radio Frequency Identification (RFID).

Response

Please see enclosed drawing no. CLB-1-02-SW-ZZ-DR-CWO-AR-1020 'EV Car Parking Layout' prepared by C+W O'Brien Architects in respect of the permitted development site.

Yours Sincerely

L.Son

Lianna Slowey Town Planner

