

User input indicated by **Orange fields**

| User Input | |
|---------------|------------------|
| Zoning lookup | Minimum GI Score |
| VC | 0.5 |

| 1. Enter Development Site Area m ² HERE ▶ | | 569 | |
|---|--------|--------------------------------------|---------------|
| Surface Type (see tab for detailed descriptions) | Factor | Proposed Surface Area m ² | Factor Values |
| 1. Short Lawn | 0.3 | 113 | 33.9 |
| 2. Tall Lawn (wild, not mown) | 0.5 | 0 | 0 |
| Permeable Paving | 0.3 | 193.15 | 57.945 |
| Vegetation | | 0 | 0 |
| 4a. Vegetation-Shrub below 3m | 0.4 | 39 | 15.6 |
| 4b. Vegetation-Shrub / Hedgerow above 3m | 0.5 | 0 | 0 |
| 4c. Vegetation-Pollinator friendly perennial planting | 0.5 | 48 | 24 |
| 4d. Vegetation-Preserved hedgerow | 1.2 | 0 | 0 |
| Trees | | 0 | 0 |
| 5a. New trees | 0.6 | 3 | 1.8 |
| 5b. Preserved trees | 1.2 | 0 | 0 |
| 7. SuDS intervention (rain garden, bioswale) | 0.6 | 0 | 0 |
| Green Roof | | 0 | 0 |
| 9a. Green Roofs - Intensive green roof (substrate is 200-1200mm in depth) | 0.7 | 0 | 0 |
| 9b. Green Roofs - Extensive green roof (substrate is 80-200mm in depth) | 0.6 | 0 | 0 |
| 10. Green wall | 0.4 | 0 | 0 |
| 11. Retained Open Water | 2 | 0 | 0 |
| 12. New open water | 1.5 | 0 | 0 |
| Total Equivalent Surface Area of Greening Factors | | 396.15 | |

| | |
|-------------------------------|---------------|
| Green Factor Numerator | 133.25 |
|-------------------------------|---------------|

| Minumum Required GI score | Final GI score | Result |
|---------------------------|----------------|--------|
| 0.5 | 0.23 | Fail |