

From: tom@once.co <tom@once.co>

Sent: Tuesday, March 19, 2024 9:00 AM

To: Planning Department <planningdept@sdublincoco.ie>

Subject: FW: 5859 - 13 Wainsfort Avenue Condition 6 of Planning Register Reference SD22B/0268

CAUTION: [EXTERNAL EMAIL] Do not click links or open attachments unless you recognise the sender and know the content is safe.

Dear Sir/Madam

In compliance with Condition 6 of Planning Register Reference SD22B/0268 please find attached a copy of the revised BRE 365 report and drainage layout.

To accommodate the reduced infiltration rate of the site, an additional Raingarden has been provided to the layout.



Regards

Thomas O' Neill

Managing Director

ONCE Consultant Engineers.

Email: tom@once.co

Phone: 01 426 4883 Mobile: 086 821 7522

4 Bridgecourt Office Park, Walkinstown
Avenue, Dublin D12 Y981

www.once.co
