

Thomas O'Neill,
Once Consultant Engineers
4 Bridgecourt Office Park
Walkinstown Avenue
Dublin 12

Date : 13-May-2024

Reg. Ref. : SD22B/0268/C6-1
Proposal : Removal of garage to side of existing dwelling; construction of 2 storey extension to side of existing dwelling maintaining front roof slope and existing ridge height; single storey extension with new entrance porch to ground floor to front of dwelling plus alterations to existing fenestration; widening of existing dormer window to front of dwelling; part single storey part 2 storey extension to rear of dwelling with rooflights; widening of existing vehicular entrance to 3.5m; provision for solar panels to west facing slope of rear extension and all associated site works.

Condition 6:

Drainage - Surface Water.

The disposal of surface water, shall fully comply with all of the technical requirements of the Council's Water Services Section. In this regard, prior to the commencement of development, the applicant/developer shall submit the following for the written agreement of the Planning Authority:

- (a) Fully detailed foul and surface water drainage plans for the proposed development as approved showing location of all manholes, AJs etc located within the site boundary up to and including point of connection to the public sewer that fully accords with the requirements Council's Water Services Section and or Irish Water,
- (b) There shall be complete separation of the foul and surface water drainage systems, both in respect of installation and use. All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
- (c) All drainage works for this development shall comply fully with the Greater Dublin Regional Code of Practice for Drainage Works.
- (d) The soakaway design to be submitted shall be certified to BRE Digest 365 standard by a suitably qualified person carrying professional indemnity insurance and shall include

documented evidence of infiltration test results to demonstrate that the soakaway complies with the requirements of BRE Digest 365. The revised plans shall provide for a soakaway to be located within the curtilage of the property and this shall be:

(i) at least 5m from any buildings, public sewers or structures and not in such a position that the ground below foundations is likely to be adversely affected.

(ii) at least 5m from the nearest road boundary and not within 3m of the boundary of the adjoining site.

(iii) a minimum of 10m from any sewage treatment percolation area.

(iv) at least 10m from any stream / river / flood plain.

In addition only rainwater shall be discharged to soakaways.

REASON: In the interests of public health, safety, the proper planning and sustainable development of the area and in order to ensure adequate and appropriate surface water drainage provision.

Location : 13, Wainsfort Avenue, Dublin 6W, D6W X974

Applicant : Brian and Breda Kearney

Application Type: Compliance with Conditions

Dear Sir/Madam,

I refer to your submission received on 19-Mar-2024 to comply with Condition No 6 of Grant of Permission Order No. SD22B/0268/C6, in connection with the above.

In this regard I wish to inform you that the submission received is deemed **Compliant**.

Yours faithfully,

CB

for Senior Planner