



**Greener Ideas Ltd  
C/O Bord Gáis Energy Ltd  
No1 Warrington Place  
Dublin  
D02 HH27  
Ireland**

Land Use, Planning & Transportation Dept.  
South Dublin County Council  
County Hall  
Tallaght  
Dublin 24  
D24 A3XC

**Ref: SD21A/0167/C3(3)**

**Subject: Greener Ideas Ltd (GIL): Planning Compliance Update  
Construction of a Gas Fired Power Plant at Profile Park, Baldonnel, Dublin D22 C7W4  
Register Reference SD21A/0167**

Dear Sir/Madam,

With regard to South Dublin County Council's (SDCC) Grant of Permission SD21A/0167 giving approval with conditions for the construction of a gas fired power plant at Profile Park, Baldonnel, Dublin D22 C7W4.

Greener Ideas Ltd (GIL) refer to your letter of 23<sup>rd</sup> October 2024 regarding compliance submission SD21A/0167/C3(3) which states the following:

SDCC Public Lighting have reviewed the compliance submission and state in their report that '*what has been submitted is not a lighting design and, therefore, does not comply. A light level calculation and electrical calculations are required*'.

In response to the request, we provide the documentation listed in Table 1 below.

<b>File Name</b>	<b>Description</b>
PRF-EL-CR-00-YP-0006	Outdoor Lighting Calculation report
PRF-EL-CR-00-YP-0010(1)	LV Cable Sizing Calculation report
PRF-EL-TS-00-YP-005	Lighting System Technical Specification

Should you have any comments or queries, please do not hesitate to contact the undersigned.

Yours sincerely

p.p. 

Thomas Lawlor  
Bord Gáis Energy | Upstream Lead  
Greener Ideas | Planning & Consents Manager

CLIENT



CONTRACTOR



SITE / PROJECT

## 100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT

REV	DATE	DESCRIPTION	DONE	CHECKED	APPROVED
1	21.02.2024	For Construction	BS	AG	CK
0	25.09.2023	For Review	BS	AG	CK
STATUS	FOR INFORMATION FOR REVIEW FOR APPROVAL FOR TENDER FOR COORDINATION FOR CONSTRUCTION	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/>	ISSUE OWNER <b>YÜKSEL PROJE</b>	SIGN 21.02.2024	DATE
DOCUMENT NUMBER	PRF-EL-CR-00-YP-0006	DOCUMENT NAME	OUTDOOR LIGHTING CALCULATION REPORT		

## Table of Contents

<b>1.</b>	<b>INDRODUCTION .....</b>	<b>3</b>
1.1.	General.....	3
1.2.	The Aim and Scope of The Project.....	3
1.3.	Definitions.....	3
1.4.	Abbreviations.....	3
<b>2.</b>	<b>CODES AND STANDARTS .....</b>	<b>4</b>
<b>3.</b>	<b>REFERENCE DOCUMENTS.....</b>	<b>6</b>
<b>4.</b>	<b>DESIGN CONDITIONS.....</b>	<b>7</b>
<b>5.</b>	<b>PROFILE PARK POWER PLANT UNIT LISTS .....</b>	<b>9</b>
<b>6.</b>	<b>LIGHTING CALCULATIONS OF OUTDOOR LIGHTING .....</b>	<b>10</b>
6.1.	Lighting Values .....	10
6.2.	Average Illumination Levels .....	10
<b>7.</b>	<b>SIMULATION RESULTS .....</b>	<b>11</b>

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No:	1
Document Name:	Outdoor Lighting Calculation Report	Document No:	PRF-EL-CR-00-YP-0006		

## 1. INTRODUCTION

### 1.1. General

Centrica Business Solutions (CBS) is a provider of energy insights, optimisation, and on-site generation solutions for its customers, as well as owning and operating energy solutions across the UK, Ireland and North America while continually in the process of identifying new sites for development.

CBS is currently in the process of supporting the development of a circa 100 MW dualfuel generation asset (Athlone Power Project) in Monksland, Athlone and Profile Park, Baldonnel, Ireland. CBS are delivering the project on an Engineering, Procurement and Construction (EPC) basis on behalf of Greener Ideas Ltd.

The Project will consist of five (5) gas reciprocating engines exporting power to the grid via an adjacent 110 kV connection. The Project will use natural gas as its primary fuel with gas oil as a back-up in the event of interruption to the gas supply.

### 1.2. The Aim and Scope of The Project

The purpose of this document is to specify the design and calculations of the Lighting System of Outdoor Lighting of the 100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT to be located near Dublin, Ireland.

In this document are defined the minimum requirements for the lighting and building services design to ensure efficient construction, proper functionality, and high reliability of the production plant.

### 1.3. Definitions

Project	: 100 MW Profile Park Reciprocating Power Plant
Employer	: GIL
Contractor	: GCIL

### 1.4. Abbreviations

EN	: European Norm
IEC	: International Electrotechnical Commission
W	: Watt
LED	: Light Emitting Diode
UV	: Ultraviolet
cm	: Centimeter
K	: Kelvin

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No:	1
Document Name:	Outdoor Lighting Calculation Report	Document No:	PRF-EL-CR-00-YP-0006		

## 2. CODES AND STANDARDS

As a minimum, the following codes and standards shall be considered:

I.S. 10101:2020	National Rules for Electrical Installations
EN 12464-1	Light and lighting - Lighting of workplaces - Part 1: Indoor workplaces
EN 12464-2	Light and lighting - Lighting of workplaces - Part 2: Outdoor workplaces
EN 50172	Emergency escape lighting systems
EN 60079	Electrical apparatus for explosive gas atmospheres
EN 15193	Energy performance of buildings - Energy requirements for lighting
EN 1838	Lighting applications- Emergency lighting
EN 50262	Metric cable glands for electrical installations
EN ISO 9001	Quality Management System
IEC 60529	Degrees of protection provided by enclosures (IP Code)
IEC 60598	Luminaires General requirements and tests
IEC 60079	Explosive atmospheres
IEC 62612	Self-ballasted LED lamps for general lighting services with supply voltages > 50 V - Performance requirements
IEC 60423	Conduit systems for cable management - Outside diameters of conduits for Electrical installations and threads for conduits and fittings
IEC 60502	Power cables with extruded insulation and their accessories for rated voltages from 1 kV ( $U_m = 1,2 \text{ kV}$ ) up to 30 kV ( $U_m = 36 \text{ kV}$ )
IEC 60669	Switches for household and similar fixed electrical installations
ATEX certifications	Hazardous Area Classification

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No.:	1
Document Name:	Outdoor Lighting Calculation Report	Document No.:	PRF-EL-CR-00-YP-0006		

Equipment shall be supplied in accordance with all applicable European Union Directives.  
Particular attention should be paid to:

- Safety
- Electromagnetic Compatibility
- Machinery
- CE marking

Therefore, the Supplier shall be responsible for supplying the product with its CE marking and all the corresponding documentation."

The units of measure shall be the SI unit of measure.

All arrangement drawings, schematics, wiring diagrams, instructions and operating and maintenance manuals, etc. shall designate systems, equipment, piping, instruments, etc. using the power plant identification system.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No:	1
Document Name:	Outdoor Lighting Calculation Report	Document No:	PRF-EL-CR-00-YP-0006		

### 3. REFERENCE DOCUMENTS

- PRF-EL-DW-00-YP-0001      Overall Single Line Diagram
- PRF-EL-DW-00-YP-0004      LV Distribution Layout
- PRF-EL-LS-00-YP-0002      Overall Electrical Cable List
- PRF-EL-DW-00-YP-0007      Outdoor Lighting Layout
- PRF-EL-CR-00-YP-0010      LV Cable Sizing Calculation Report
- PRF-EL-DW-00-YP-0008      Outdoor/Site Cable Routing Layouts (Incl. Cable Tray and Conduits)
- PRF-EL-LS-00-YP-0003      Outdoor/site Cable Schedule
- PRF-EL-CR-00-YP-0008      Outdoor Cable Tray Capacity Calculation Report
- PRF-EL-TS-00-YP-0005      Lighting System Technical Specification

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No:	1
Document Name:	Outdoor Lighting Calculation Report	Document No:	PRF-EL-CR-00-YP-0006		

#### 4. DESIGN CONDITIONS

##### Ambient Air Conditions: Statistical Data

Minimum Recorded (°C)	-7.6
Mean Recorded (°C)	10.0
Maximum Recorded (°C)	27.5
Mean Wet Bulb Temperature (°C)	8.6
Maximum Wet Bulb Temperature (°C)	21.5
Minimum Humidity	20%
Average Humidity	82%
Maximum Humidity	100%

##### Ambient Air Temperature: Design Data

Winterisation Temperature (°C)	-10
Max Ambient Design Temperature (°C)	30
Max Wet Bulb Temperature (°C)	22

##### Wind, Rainfall and Snowfall Data

Average Wind Velocity km/h (m/s)	18.1 (5)
Maximum Wind Velocity km/h (m/s)	74.1 (20.6)
Average Daily Rainfall (mm)	2.1
Maximum Daily Rainfall (mm)	45.4

##### Site Conditions

Altitude above sea level (m)	69
Maximum wet bulb temperature (°C)	21.5
Minimum ambient air temperature (°C)	-10
Maximum ambient air temperature (°C)	30

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No.:	1
Document Name:	Outdoor Lighting Calculation Report	Document No.:	PRF-EL-CR-00-YP-0006		

Performance Data Reference Conditions

Parameter	Unit	Value
Air inlet temperature (before air inlet filter)	°C	15
Air inlet pressure (before air inlet filter)	mbar	1005
Wet Bulb Temperature	°C	7
Relative Humidity	%	28
Charge Air Temperature Before Cylinder:		
Gas Operation	°C	50
Diesel Operatin	°C	45
Exhaust Gas Bask Pressure	mbar	<=50
Intake Air Pressure Loss	mbar	<=20

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No:	1
Document Name:	Outdoor Lighting Calculation Report	Document No:	PRF-EL-CR-00-YP-0006		

**5. PROFILE PARK POWER PLANT UNIT LISTS**

- ENGINE HALL
- ELECTRICAL ANNEX
- WORKSHOP & STOREROOM
- TANK FARM BUILDING
- SECURITY HUT BUILDING

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No:	1
Document Name:	Outdoor Lighting Calculation Report	Document No:	PRF-EL-CR-00-YP-0006		

## 6. LIGHTING CALCULATIONS OF OUTDOOR LIGHTING

In this document,

- The lighting fixtures have been placed according to the architectural layout plans.
- The lighting design have made based on safety, comfort, working areas and the difference of luminous intensity which is decreased.
- LED fixtures which are convenient for Lighting Technical Specification according to safety, energy efficiency have been used in room and environmental lighting.

### 6.1. Lighting Values

The essential factors of lighting design are specified as the size and qualification of surfaces, preserves of colors, the needs of luminousness. Besides that, the elements that are suitability for architecture, safe, ease of maintenance repair and providing were based on design. The luminousness levels were determined with EN 12464-1, EN 12464-2, Electrical Installation in Buildings standards and the values of them given below.

### 6.2. Average Illumination Levels

NAME OF LOCATION	STANDART Em (lx)	SIMULATION RESULTS Em (lx)	FIXTURE HEIGHT (m)	FIXTURE TYPE
GENERAL AREA	20	21.2	6	38 W LIGHTING POLE, 6000 Lumen, 4000K
OUTSIDE AREA	15	16.9	6	41 W PROJEKTOR, 7000 Lumen, 4000K
PLATFORM AREA	50	71.6	4,2	15 W LINEER LED LIGHTING FIXTURE, 2300 Lumen, 4000K
RADIATOR PLATFORM	50	60.5	8,5	25 W LINEER LED LIGHTING FIXTURE, 4200 Lumen, 4000K
TANK AREA	20	25.2	13	41 W PROJEKTOR, 7000 Lumen, 4000K
UPPER PLATFORM AREA	20	34.5	7	41 W PROJEKTOR, 7000 Lumen, 4000K
TRANSFORMATION AREA	20	32	7,5	41 W PROJEKTOR, 7000 Lumen, 4000K


The fixtures used in lighting calculations are not binding on product selection in the application phase.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	21.02.2024	Rev. No:	1
Document Name:	Outdoor Lighting Calculation Report	Document No:	PRF-EL-CR-00-YP-0006		

---

**7. SIMULATION RESULTS**

Project:	<b>100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT</b>	Date:	21.02.2024	Rev. No:	1
Document Name:	<i>Outdoor Lighting Calculation Report</i>	Document No:	<b>PRF-EL-CR-00-YP-0006</b>		



## PROFILE PARK OUTDOOR LIGHTING CALCULATION REPORT

## Table of Contents

Cover .....	1
Table of Contents .....	2
Images .....	3
Luminaire list .....	8

## Product data sheets



Philips - BGP292 T25 1 xLED60-4S/740 DX10 (1x LED60-4S/740) .....	9
Philips - BVP650 T25 1 xLED70-4S/740 OFA52 (1x LED70-4S/740) .....	10
Philips - WT490C PSU L700 1 xLED23S/840 WB (1x LED23S/840) .....	11
Philips - WT490C PSU L1200 1 xLED42S/840 WB (1x LED42S/840) .....	12

## Site 1


Calculation objects / Light scene 1 .....	13
GENERAL AREA / Light scene 1 / Perpendicular illuminance .....	15
PLATFORM AREA / Light scene 1 / Perpendicular illuminance .....	16
TANK AREA / Light scene 1 / Perpendicular illuminance .....	17
UPPER PLATFORM AREA / Light scene 1 / Perpendicular illuminance .....	18
RADYATOR PLATFORM / Light scene 1 / Perpendicular illuminance .....	19
TRANSFORMATION AREA / Light scene 1 / Perpendicular illuminance .....	20
OUTSIDE AREA / Light scene 1 / Perpendicular illuminance .....	21

## Images



1



2




3




## Images

4



5




6




## Images


7



8




9




## Images


10



11




12




## Images

13



14



## Luminaire list

$\Phi_{\text{total}}$	$P_{\text{total}}$	Luminous efficacy
433177 lm	2956.4 W	146.5 lm/W


pcs.	Manufacturer	Article No.	Article name	P	$\Phi$	Luminous efficacy
28	Philips	BGP292 T25 1 xLED60-4S/740 DX10		38.0 W	5061 lm	133.2 lm/W
33	Philips	BVP650 T25 1 xLED70-4S/740 OFA52		41.0 W	6213 lm	151.5 lm/W
14	Philips	WT490C PSU L1200 1 xLED42S/840 WB		25.5 W	4202 lm	164.8 lm/W
12	Philips	WT490C PSU L700 1 xLED23S/840 WB		15.2 W	2301 lm	151.4 lm/W

## Product data sheet

Philips - BGP292 T25 1 xLED60-4S/740 DX10



P	38.0 W
$\Phi_{Lamp}$	6000 lm
$\Phi_{Luminaire}$	5061 lm
$\eta$	84.34 %
Luminous efficacy	133.2 lm/W
CCT	3000 K
CRI	100




Polar LDC

## Product data sheet

Philips - BVP650 T25 1 xLED70-4S/740 OFA52



P	41.0 W
$\Phi_{Lamp}$	7000 lm
$\Phi_{Luminaire}$	6213 lm
$\eta$	88.75 %
Luminous efficacy	151.5 lm/W
CCT	3000 K
CRI	100




Polar LDC

## Product data sheet

Philips - WT490C PSU L700 1 xLED23S/840 WB



P	15.2 W
$\Phi_{Lamp}$	2300 lm
$\Phi_{Luminaire}$	2301 lm
$\eta$	100.04 %
Luminous efficacy	151.4 lm/W
CCT	3000 K
CRI	100



Polar LDC

Glare evaluation according to UGR												
$\rho$	Ceiling	70	70	50	50	30	70	70	50	50	30	30
$\rho$	Walls	50	30	50	30	30	50	30	50	30	30	30
$\rho$	Floor	20	20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis										Viewing direction parallel to lamp axis
2H	2H	19.0	20.0	19.3	20.3	20.5	18.6	19.7	18.9	19.9	20.2	
3H	3H	19.0	19.9	19.3	20.2	20.5	18.6	19.6	19.0	19.8	20.1	
	4H	18.9	19.8	19.3	20.1	20.4	18.6	19.5	19.0	19.8	20.1	
	6H	18.9	19.7	19.2	20.0	20.3	18.6	19.5	19.0	19.8	20.1	
	8H	18.8	19.6	19.2	19.9	20.3	18.6	19.4	19.0	19.7	20.1	
	12H	18.8	19.5	19.2	19.9	20.2	18.6	19.4	19.0	19.7	20.1	
4H	2H	18.9	19.7	19.2	20.0	20.4	18.5	19.4	18.9	19.7	20.0	
3H	3H	18.9	19.6	19.3	20.0	20.3	18.6	19.3	19.0	19.7	20.0	
	4H	18.9	19.5	19.3	19.9	20.3	18.6	19.3	19.1	19.7	20.1	
	6H	18.8	19.4	19.3	19.8	20.2	18.7	19.3	19.1	19.7	20.1	
	8H	18.8	19.3	19.3	19.8	20.2	18.7	19.2	19.2	19.7	20.1	
	12H	18.8	19.3	19.2	19.7	20.2	18.7	19.2	19.2	19.7	20.1	
8H	4H	18.8	19.3	19.3	19.8	20.2	18.6	19.1	19.0	19.5	20.0	
6H	6H	18.8	19.2	19.3	19.7	20.2	18.7	19.1	19.2	19.6	20.1	
	8H	18.8	19.2	19.3	19.6	20.2	18.7	19.1	19.2	19.6	20.1	
	12H	18.8	19.1	19.3	19.6	20.1	18.8	19.1	19.3	19.6	20.1	
12H	4H	18.8	19.3	19.2	19.7	20.2	18.5	19.0	19.0	19.5	19.9	
	6H	18.8	19.2	19.3	19.6	20.1	18.7	19.0	19.2	19.5	20.0	
	8H	18.8	19.1	19.3	19.6	20.1	18.7	19.0	19.2	19.5	20.1	
Variation of the observer position for the luminaire distances S												
S = 1.0H		+1.7	/ -3.8				+1.5	/ -3.0				
S = 1.5H		+3.8	/ -5.7				+3.3	/ -4.4				
S = 2.0H		+5.7	/ -6.6				+5.1	/ -5.1				
Standard table		BK00					BK01					
Correction summand		0.7					0.8					
Corrected glare indices referring to 2300lm Total luminous flux												


UGR diagram (SHR: 0.25)

## Product data sheet

Philips - WT490C PSU L1200 1 xLED42S/840 WB



P	25.5 W
$\Phi_{Lamp}$	4200 lm
$\Phi_{Luminaire}$	4202 lm
$\eta$	100.04 %
Luminous efficacy	164.8 lm/W
CCT	3000 K
CRI	100




Polar LDC

Glare evaluation according to UGR												
$\rho$	Ceiling	70	70	50	50	30	70	70	50	50	30	30
$\rho$	Walls	50	30	50	30	30	50	30	50	30	30	30
$\rho$	Floor	20	20	20	20	20	20	20	20	20	20	20
X	Y	Viewing direction at right angles to lamp axis										Viewing direction parallel to lamp axis
2H	2H	18.6	19.6	18.9	19.9	20.1	18.2	19.2	18.5	19.5	19.7	
3H	3H	18.5	19.5	18.9	19.7	20.0	18.2	19.1	18.5	19.4	19.7	
4H	4H	18.5	19.4	18.8	19.7	20.0	18.2	19.1	18.5	19.4	19.7	
6H	6H	18.4	19.3	18.8	19.6	19.9	18.2	19.0	18.6	19.3	19.6	
8H	8H	18.4	19.2	18.8	19.5	19.9	18.2	19.0	18.6	19.3	19.6	
12H	12H	18.4	19.1	18.8	19.5	19.8	18.2	18.9	18.6	19.3	19.6	
4H	2H	18.4	19.3	18.8	19.6	19.9	18.1	18.9	18.4	19.2	19.5	
3H	3H	18.5	19.2	18.8	19.5	19.9	18.1	18.9	18.5	19.2	19.6	
4H	4H	18.4	19.1	18.9	19.5	19.9	18.2	18.8	18.6	19.2	19.6	
6H	6H	18.4	19.0	18.9	19.4	19.8	18.2	18.8	18.7	19.2	19.6	
8H	8H	18.4	18.9	18.8	19.3	19.8	18.3	18.8	18.7	19.2	19.7	
12H	12H	18.3	18.8	18.8	19.3	19.7	18.3	18.7	18.8	19.2	19.7	
4H	4H	18.4	18.9	18.8	19.3	19.8	18.1	18.7	18.6	19.1	19.5	
6H	6H	18.4	18.8	18.9	19.3	19.8	18.2	18.7	18.7	19.1	19.6	
8H	8H	18.4	18.8	18.9	19.2	19.7	18.3	18.7	18.8	19.1	19.6	
12H	12H	18.3	18.7	18.9	19.2	19.7	18.3	18.7	18.9	19.2	19.7	
4H	18.3	18.8	18.8	19.3	19.7	18.1	18.6	18.6	19.0	19.5		
6H	18.4	18.7	18.9	19.2	19.7	18.2	18.6	18.7	19.1	19.6		
8H	18.4	18.7	18.9	19.2	19.7	18.3	18.6	18.7	19.1	19.6		
12H	18.3	18.7	18.9	19.2	19.7	18.3	18.6	18.8	19.1	19.6		
Variation of the observer position for the luminaire distances S												
S = 1.0H		+1.6	/ -3.8				+1.5	/ -3.0				
S = 1.5H		+3.8	/ -5.6				+3.3	/ -4.4				
S = 2.0H		+5.7	/ -6.6				+5.1	/ -5.1				
Standard table		BK00					BK01					
Correction summand		0.3					0.4					
Corrected glare indices referring to 4200lm Total luminous flux												

UGR diagram (SHR: 0.25)

Site 1 (Light scene 1)

## Calculation objects



Site 1 (Light scene 1)



## Calculation objects

### Calculation surfaces

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
GENERAL AREA Perpendicular illuminance Height: 0.000 m	21.2 lx	6.00 lx	58.2 lx	0.28	0.10	CG1
PLATFORM AREA Perpendicular illuminance Height: 2.300 m	71.6 lx	34.0 lx	106 lx	0.47	0.32	CG2
TANK AREA Perpendicular illuminance Height: 0.000 m	25.2 lx	10.4 lx	47.1 lx	0.41	0.22	CG3
UPPER PLATFORM AREA Perpendicular illuminance Height: 6.600 m	34.5 lx	23.6 lx	44.4 lx	0.68	0.53	CG4
RADYATOR PLATFORM Perpendicular illuminance Height: 0.000 m	60.5 lx	45.5 lx	73.4 lx	0.75	0.62	CG5
TRANSFORMATION AREA Perpendicular illuminance Height: 0.000 m	32.0 lx	20.3 lx	41.0 lx	0.63	0.50	CG6
OUTSIDE AREA Perpendicular illuminance Height: 0.000 m	16.9 lx	11.0 lx	30.1 lx	0.65	0.37	CG7

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))


Site 1 (Light scene 1)

**GENERAL AREA**

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
GENERAL AREA Perpendicular illuminance Height: 0.000 m	21.2 lx	6.00 lx	58.2 lx	0.28	0.10	CG1

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))


Site 1 (Light scene 1)

**PLATFORM AREA**

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
PLATFORM AREA Perpendicular illuminance Height: 2.300 m	71.6 lx	34.0 lx	106 lx	0.47	0.32	CG2

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))


Site 1 (Light scene 1)

**TANK AREA**

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
TANK AREA Perpendicular illuminance Height: 0.000 m	25.2 lx	10.4 lx	47.1 lx	0.41	0.22	CG3

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))


Site 1 (Light scene 1)

**UPPER PLATFORM AREA**

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
UPPER PLATFORM AREA Perpendicular illuminance Height: 6.600 m	34.5 lx	23.6 lx	44.4 lx	0.68	0.53	CG4

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))



Site 1 (Light scene 1)

**RADYATOR PLATFORM**

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
RADYATOR PLATFORM Perpendicular illuminance Height: 0.000 m	60.5 lx	45.5 lx	73.4 lx	0.75	0.62	CG5

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))


Site 1 (Light scene 1)

**TRANSFORMATION AREA**

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
TRANSFORMATION AREA Perpendicular illuminance Height: 0.000 m	32.0 lx	20.3 lx	41.0 lx	0.63	0.50	CG6

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))

Site 1 (Light scene 1)

**OUTSIDE AREA**

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$g_1$	$g_2$	Index
OUTSIDE AREA Perpendicular illuminance Height: 0.000 m	16.9 lx	11.0 lx	30.1 lx	0.65	0.37	CG7

Utilisation profile: DIALux presetting (5.1.4 Standard (outdoor transportation area))

CLIENT



CONTRACTOR



SITE / PROJECT

## 100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT

REV	DATE	DESCRIPTION	DONE	CHECKED	APPROVED
0	14.03.2024	For Construction	BS	AG	CK
STATUS	FOR INFORMATION FOR REVIEW FOR APPROVAL FOR TENDER FOR COORDINATION FOR CONSTRUCTION	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/>	ISSUE OWNER <b>YÜKSEL PROJE</b>	SIGN	DATE 14.03.2024
DOCUMENT NUMBER	PRF-EL-CR-00-YP-0010	DOCUMENT NAME	LV CABLE SIZING CALCULATION REPORT		

## Table of Contents

<b>1.</b>	<b>INDRODUCTION .....</b>	<b>3</b>
1.1.	General.....	3
1.2.	The Aim and Scope of The Project.....	3
1.3.	Definitions.....	3
1.4.	Abbreviations.....	4
<b>2.</b>	<b>CODES AND STANDARTS .....</b>	<b>5</b>
<b>3.</b>	<b>REFERENCE DOCUMENTS.....</b>	<b>6</b>
<b>4.</b>	<b>DESIGN CONDITIONS.....</b>	<b>7</b>
<b>5.</b>	<b>PROFILE PARK POWER PLANT UNIT LISTS .....</b>	<b>8</b>
<b>6.</b>	<b>MAIN LOW VOLTAGE CABLES SELECTION.....</b>	<b>9</b>
6.1.	Low Voltage Power Distribution Installation .....	9
6.2.	Converstion Factor Selection According To In Cable Tray&Ladder .....	9
6.3.	Cable Cross Section Determination According To The Voltage Drop .....	14
6.4.	Appendix.....	21

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

## 1. INTRODUCTION

### 1.1. General

Centrica Business Solutions (CBS) is a provider of energy insights, optimisation, and on-site generation solutions for its customers, as well as owning and operating energy solutions across the UK, Ireland and North America while continually in the process of identifying new sites for development.

CBS is currently in the process of supporting the development of a circa 100 MW dualfuel generation asset (Athlone Power Project) in Monksland, Athlone and Profile Park, Baldonnel, Ireland. CBS are delivering the project on an Engineering, Procurement and Construction (EPC) basis on behalf of Greener Ideas Ltd.

The Project will consist of five (5) gas reciprocating engines exporting power to the grid via an adjacent 110 kV connection. The Project will use natural gas as its primary fuel with gas oil as a back-up in the event of interruption to the gas supply.

### 1.2. The Aim and Scope of The Project

The aim of the present document is to define the low voltage cable selection criteria that have to be fulfilled in the design and calculations of all electrical design and building services works for the 100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT that is going to be constructed in near Dublin, Ireland.

In this document are defined the minimum requirements for the electrical design to ensure efficient construction, proper functionality and high reliability of the production plant.

### 1.3. Definitions

Project	:100 MW Profile Park Reciprocating Power Plant
Employer	: GIL
Contractor	: GCIL
Shall	: Indicates a mandatory requirement
Should	: Indicates a strong recommendation

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

## 1.4. Abbreviations

AC	: Alternative Current
XLPE	: Cross-linked polyethylene
PVC	: Polyvinyl chloride
LSZH	: Low Smoke Zore Halogen
EN	: European Norm
V	: Voltage
A	: Current
W	: Active Power
VAR	: Reactive Power
VA	: Apparent Power
m	: Meters
cm	: Centimeters
mm	: Millimeters
IEC	: International Electromechanical Commission
IEEE	: Institute of Electrical and Electronics Engineers
ISO	: International Organization for Standardization
HV	: High Voltage
LV	: Low Voltage
MV	: Medium Voltage
MV SWGR	: Medium Voltage Switchgear
LV SWGR	: Low Voltage Switchgear

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

## 2. CODES AND STANDARDS

As a minimum, the following codes and standards shall be considered:

I.S. 10101:2020	National Rules for Electrical Installations
IEC 60364-5-52	Low-voltage electrical installations-Selection and erection of electrical equipment-Wiring systems
IEC 63364-4-43	Low-voltage electrical installations-Protection for safety- Protection against overcurrent
IEC 60909	Short-circuit currents in three-phase a.c. systems
IEC 60947-2	Low voltage switchgear and controlgear
IEC 60947-4-1	Low voltage switchgear and controlgear contactors and motor starters electromechanical contactors and motor starters
DIN VDE 0271	Power cables-specifications for power cables 0.6/1kV and above for special applications

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

### 3. REFERENCE DOCUMENTS

PRF-EL-DW-00-YP-0001	Overall Single Line Diagram
PRF-EL-DW-00-YP-0002	MV/LV Electrical Equipment Arrangement Layout (Consumer Layout)
PRF-EL-DW-00-YP-0004	LV Distribution Layout
PRF-EL-DW-00-YP-0008	Outdoor/Site Cable Routing Layouts (Incl. Cable Tray and Conduits)
PRF-EL-DW-01-YP-0003	Engine Hall LV Distribution Layout
PRF-EL-DW-02-YP-0003	Electrical Annex LV Distribution Layout
PRF-EL-DW-05-YP-0002	Workshop & Stora Room LV Distribution Layout
PRF-EL-DW-17-YP-0002	Tank Farm Building LV Distribution Layout
PRF-EL-DW-38-YP-0002	Security Hut LV Distribution Layout
PRF-EL-CR-00-YP-0001	Load Flow Study Report
PRF-EL-CR-00-YP-0002	Short Circuit Study Report
PRF-EL-CR-00-YP-0003	GSUT Sizing Calculation Report
PRF-EL-LS-00-YP-0001	Electrical Consumer List
PRF-EL-LS-00-YP-0002	Overall Electrical Cable List
PRF-EL-LS-00-YP-0003	Outdoor/site Cable Schedule
PRF-EL-TS-00-YP-0004	Low Voltage Cable Technical Specification
PRF-EL-TS-00-YP-0011	Low Voltage Busduct Technical Specification
5305170_5305446_FA 0	Overview_Single Line Diagram_RevE
0129074-P00-EP-XX-RP-E-1001	Electrical Basis of Design Report
5305170_5305446	Consumer List_AFC_RevC_Cust

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

#### 4. DESIGN CONDITIONS

##### Ambient Air Conditions: Statistical Data

Minimum Recorded (°C)	-7.6
Mean Recorded (°C)	10.0
Maximum Recorded (°C)	27.5
Mean Wet Bulb Temperature (°C)	8.6
Maximum Wet Bulb Temperature (°C)	21.5
Minimum Humidity	20%
Average Humidity	82%
Maximum Humidity	100%

##### Ambient Air Temperature: Design Data

Winterisation Temperature (°C)	-10
Max Ambient Design Temperature (°C)	30
Max Wet Bulb Temperature (°C)	22

##### Wind, Rainfall and Snowfall Data

Average Wind Velocity km/h (m/s)	18.1 (5)
Maximum Wind Velocity km/h (m/s)	74.1 (20.6)
Average Daily Rainfall (mm)	2.1
Maximum Daily Rainfall (mm)	45.4

##### Site Conditions

Altitude above sea level (m)	69
Maximum wet bulb temperature (°C)	21.5
Minimum ambient air temperature (°C)	-10
Maximum ambient air temperature (°C)	30

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No.:	0
Document Name:	LV Cable Sizing Calculation Report	Document No.:	PRF-EL-CR-00-YP-0010		

### Performance Data Reference Conditions

Parameter	Unit	Value
Air inlet temperature (before air inlet filter)	°C	15
Air inlet pressure (before air inlet filter)	mbar	1005
Wet Bulb Temperature	°C	7
Relative Humidity	%	28
Charge Air Temperature Before Cylinder:		
Gas Operation	°C	50
Diesel Operatin	°C	45
Exhaust Gas Bask Pressure	mbar	<=50
Intake Air Pressure Loss	mbar	<=20

### 5. PROFILE PARK POWER PLANT UNIT LISTS

- ENGINE HALL
- ELECTRICAL ANNEX
- WORKSHOP & STOREROOM
- TANK FARM BUILDING
- SECURITY HUT BUILDING

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:		PRF-EL-CR-00-YP-0010	


## 6. MAIN LOW VOLTAGE CABLES SELECTION

### 6.1. Low Voltage Power Distribution Installation

The result of the calculations which are made referring to the criteria and methods given below, are given in enclosure section "6.4" Appendix.

### 6.2. Conversion Factor Selection According To In Cable Tray&Ladder

Cables that are used in the system are operating temperature 90°C. The current carrying capacity and reduction factors are given in IEC 60364-5-52. Installation methods E and F are to be used in the system.



Single or multi core cables:

In corrugated trays&ladders installed horizontal or vertical

IEC 60364-5-52 Table 52-3

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

Current carrying capacity of the cables will be referred to the Table B.52.1/B.52-2 of the mentioned standard, for Method D,E and F, at 90°C cable operating temperature and 30°C ambient temperature.

Table B.52-1 (A.52-1) – Current-carrying capacity in amperes

Reference methods in table A.52-1	Number of loaded conductors and type of insulation											
	A1		Three PVC	Two PVC		Three XLPE	Two XLPE					
A2	Three PVC	Two PVC		Three XLPE	Two XLPE							
B1				Three PVC	Two PVC		Three XLPE		Two XLPE			
B2			Three PVC	Two PVC		Three XLPE	Two XLPE					
C					Three PVC		Two PVC	Three XLPE		Two XLPE		
E						Three PVC		Two PVC	Three XLPE		Two XLPE	
F							Three PVC		Two PVC	Three XLPE		Two XLPE
1	2	3	4	5	6	7	8	9	10	11	12	13
<b>Size (mm<sup>2</sup>)</b>												
<b>Copper</b>												
1,5	13	13,5	14,5	15,5	17	18,5	19,5	22	23	24	26	-
2,5	17,5	18	19,5	21	23	25	27	30	31	33	36	-
4	23	24	26	28	31	34	36	40	42	45	49	-
6	29	31	34	36	40	43	46	51	54	58	63	-
10	39	42	46	50	54	60	63	70	75	80	86	-
16	52	56	61	68	73	80	85	94	100	107	115	-
25	68	73	80	89	95	101	110	119	127	135	149	161
35	-	-	-	110	117	126	137	147	158	169	185	200
50	-	-	-	134	141	153	167	179	192	207	225	242
70	-	-	-	171	179	196	213	229	246	268	289	310
95	-	-	-	207	216	238	258	278	298	328	352	377
120	-	-	-	239	249	276	299	322	346	382	410	437
150	-	-	-	-	285	318	344	371	395	441	473	504
185	-	-	-	-	324	362	392	424	450	506	542	575
240	-	-	-	-	380	424	461	500	538	599	641	679
<b>Aluminium</b>												
2,5	13,5	14	15	16,5	18,5	19,5	21	23	24	26	28	-
4	17,5	18,5	20	22	25	26	28	31	32	35	38	-
6	23	24	26	28	32	33	36	39	42	45	49	-
10	31	32	36	39	44	46	49	54	58	62	67	-
16	41	43	48	53	58	61	66	73	77	84	91	-
25	53	57	63	70	73	78	83	90	97	101	108	121
35	-	-	-	86	90	96	103	112	120	126	135	150
50	-	-	-	104	110	117	125	136	146	154	164	184
70	-	-	-	133	140	150	160	174	187	198	211	237
95	-	-	-	161	170	183	195	211	227	241	257	289
120	-	-	-	186	197	212	226	245	263	280	300	337
150	-	-	-	-	226	245	261	283	304	324	346	389
185	-	-	-	-	256	280	298	323	347	371	397	447
240	-	-	-	-	300	330	352	382	409	439	470	530

NOTE Tables B.52-2 to B.52-3 must be consulted to determine the range of conductor sizes for which the above current-carrying capacities are applicable, for each installation method.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No.:	0
Document Name:	LV Cable Sizing Calculation Report	Document No.:	PRF-EL-CR-00-YP-0010		

**Table B.52-2 (A.52-2) – Current-carrying capacities (in amperes)**

Installation method	Size mm <sup>2</sup>	Number of loaded conductors and type of insulation			
		Two PVC	Three PVC	Two XLPE	Three XLPE
D	Copper				
	1,5	22	18	26	22
	2,5	29	24	34	29
	4	38	31	44	37
	6	47	39	56	46
	10	63	52	73	61
	16	81	67	95	79
	25	104	86	121	101
	35	125	103	146	122
	50	148	122	173	144
	70	183	151	213	178
	95	216	179	252	211
	120	246	203	287	240
	150	278	230	324	271
	185	312	258	363	304
D	Aluminium				
	2,5	22	18,5	26	22
	4	29	24	34	29
	6	36	30	42	36
	10	48	40	56	47
	16	62	52	73	61
	25	80	66	93	78
	35	96	80	112	94
	50	113	94	132	112
	70	140	117	163	138
	95	166	138	193	164
	120	189	157	220	186
	150	213	178	249	210
	185	240	200	279	236
	240	277	230	322	272
	300	313	260	364	308

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

### Conversation Factor Selection:

➤ **For XLPE Insulation Cables:**

F<sub>1</sub> : Conversion factor = **0.91** (According to IEC 60364-5-52 Table A.52-14)

**Table A.52-14 (52-D1) – Correction factor for ambient air temperatures other than 30 °C to be applied to the current-carrying capacities for cables in the air**

Ambient temperature <sup>a</sup> °C	Insulation			
	PVC	XLPE and EPR	Mineral <sup>a</sup>	
			PVC covered or bare and exposed to touch 70 °C	Bare not exposed to touch 105 °C
10	1,22	1,15	1,26	1,14
15	1,17	1,12	1,20	1,11
20	1,12	1,08	1,14	1,07
25	1,06	1,04	1,07	1,04
35	0,94	0,96	0,93	0,96
40	0,87	0,91	0,85	0,92
45	0,79	0,87	0,87	0,88
50	0,71	0,82	0,67	0,84
55	0,61	0,76	0,57	0,80
60	0,50	0,71	0,45	0,75
65	–	0,65	–	0,70
70	–	0,58	–	0,65
75	–	0,50	–	0,60
80	–	0,41	–	0,54
85	–	–	–	0,47
90	–	–	–	0,40
95	–	–	–	0,32

<sup>a</sup> For higher ambient temperatures, consult manufacturer.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

F2 : Conversion factor = **0.66** (According to IEC 60364-5-52-Table A.52-20)

**Table A.52-20 (52-E4) – Reduction factors for group of more than one multi-core cable to be applied to reference ratings for multi-core cables in free air – Method of installation E in tables A.52-8 (52-C7) to A.52-13 (52-C12)**

Method of installation in table 52-B2			Number of trays	Number of cables					
				1	2	3	4	6	9
Perforated trays (note 3)	31	Touching	1	1,00	0,88	0,82	0,79	0,76	0,73
			2	1,00	0,87	0,80	0,77	0,73	0,68
			3	1,00	0,86	0,79	0,76	0,71	0,66
	31	Spaced	1	1,00	1,00	0,98	0,95	0,91	-
			2	1,00	0,99	0,96	0,92	0,87	-
			3	1,00	0,98	0,95	0,91	0,85	-
Vertical perforated trays (note 4)	31	Touching	1	1,00	0,88	0,82	0,78	0,73	0,72
			2	1,00	0,88	0,81	0,76	0,71	0,70
	31	Spaced	1	1,00	0,91	0,89	0,88	0,87	-
			2	1,00	0,91	0,88	0,87	0,85	-
Ladder supports, cleats, etc. (note 3)	32	Touching	1	1,00	0,87	0,82	0,80	0,79	0,78
			2	1,00	0,86	0,80	0,78	0,76	0,73
			3	1,00	0,85	0,79	0,76	0,73	0,70
	33	Spaced	1	1,00	1,00	1,00	1,00	1,00	-
			2	1,00	0,99	0,98	0,97	0,96	-
			3	1,00	0,98	0,97	0,96	0,93	-
<p>NOTE 1 Values given are averages for the cable types and range of conductor sizes considered in tables A.52-8 to A.52-13. The spread of values is generally less than 5 %.</p> <p>NOTE 2 Factors apply to single layer groups of cables as shown above and do not apply when cables are installed in more than one layer touching each other. Values for such installations may be significantly lower and must be determined by an appropriate method.</p> <p>NOTE 3 Values are given for vertical spacings between trays of 300 mm and at least 20 mm between trays and wall. For closer spacing the factors should be reduced.</p> <p>NOTE 4 Values are given for horizontal spacing between trays of 225 mm with trays mounted back to back. For closer spacing the factors should be reduced.</p>									

Thus the conversion factor is calculated as; (For XLPE Insulation Cables)

### Conversion Factors:

F<sub>1</sub>= 0.91 as per Table A.52-14

F<sub>2</sub>= 0.66 as per Table A.52-20

$$F_{\text{overall}}= F_1 \times F_2 = 0.91 \times 0.66 = \mathbf{0.60}$$

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

### 6.3. Cable Cross Section Determination According To The Voltage Drop

System voltage drop will be calculated from the transformer L.V. terminal to the end user. The percentage distribution of this voltage drop with respect to the system sections is given in the Maximum Voltage Drop Criteria Table.

The relative voltage drop (expressed as a percentage of the line to neutral voltage) is calculated using the following equation:

$$\Delta u = 100 \cdot \frac{b \cdot (R_{1\text{ ph}} \cdot \cos \varphi + X_{\text{ph}} \cdot \sin \varphi) \cdot I_B \cdot 10^{-3}}{U_0} \%$$

$b$  = being equal to 1 for three phase circuits, equal to 2 for single phase circuits

$U_0$  = Facilities line to neutral nominal voltage [V]

$$U_0 = \frac{U_n}{\sqrt{3}}$$

$U_n$  = Facilities line to neutral nominal voltage [V]

$I_B$  = Design current of the circuit [A]

$R_{1\text{ ph}}$  = Resistance of the line [ $\text{m}\Omega$ ] at operating temperature ( $90^\circ\text{C}$ )

For insulated conductors and cables  $R_{1\text{ ph}} = R_{c1\text{ ph}} \cdot l_1$

$R_{c1\text{ ph}}$  = cable/conductor resistance per meter [ $\text{m}\Omega/\text{m}$ ] at conductor operating temperature ( $90^\circ\text{C}$ )

$l_1$  = length of the line (cable/conductor) [m]




$X_{\text{ph}}$  = Line reactance [ $\text{m}\Omega$ ]

For insulated conductors and cables  $X_{\text{ph}} = X_{c\text{ ph}} \cdot l_1$




$X_{c\text{ ph}}$  = cable/conductor reactance per meter [ $\text{m}\Omega/\text{m}$ ]

$l_1$  = length of the line (cable/conductor) [m]





Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

**Voltage Drop Limit Selection:**

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		




Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		




Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:		PRF-EL-CR-00-YP-0010	


## EDG PANEL






## HV SWITCHYARD PANEL



## IPP COMPOUND PANEL




Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		




Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		


## AUX BOILER PANEL



## EDG AUX PANEL



## GAS PRESSURE REDUCTION STATION PANEL



Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

#### 6.4. Appendix

- 00BFA01 (LV Main Busbar 1) Cable Selection Calculation
- 00BFB01 (LV Main Busbar 2) Cable Selection Calculation
- 00BHA01 (LV Main Common Busbar) Cable Selection Calculation

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	14.03.2024	Rev. No:	0
Document Name:	LV Cable Sizing Calculation Report	Document No:	PRF-EL-CR-00-YP-0010		

# CALCULATION SHEET 3C

NETWORK				Normal			Standby		CALCULATION SHEET 3C										
Earthing Syst		TN		I Total		1872.38 A													
Voltage		400 V		I installed		4546.63 A													
DISTRIBUTION				I Avail		2674.25 A													
Upstream N	TRANSFORMER-1			Ik3 max		55050 A													
Upstream S	LV BUSBAR-1			$\Delta U$		0.51 %													
CIRCUIT				Circuit OK			Circuit OK			Circuit OK									
				IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>				
Upstream		LV BUSBAR-1				LV BUSBAR-1				LV BUSBAR-1									
Ref mark				00CDP01GS011				01CDG01GS011				02CDG01GS011							
Upstream BB		D.origin																	
Style		Board						Board				Board							
Content		ΔU Regulator		3P+N+PE				3P+N+PE				3P+N+PE							
Designation																			
CABLES INFORMATIONS/EQUIPM.				CVP-1			ERP1			ERP2									
N°	Consump	K Coincid	Geog.location	1	90kW	1		1	190kW	1		1	190kW	1					
Downst BB				Modif.												A			
Cos φ	K Use	UL		0.85	1			0.85	1			0.85	1		A				
Cos φ Start.	ID/IN	ΔU Start																	
η	Supply			1.00	Normal			1.00	Normal			1.00	Normal						
Equip. Pole	Type			3P+N				3P+N				3P+N							
CABLE				00CDP01GS011				01CDG01GS011				02CDG01GS011							
Type				N2XRH (90°C) Dca				N2XRH (90°C) Dca				N2XRH (90°C) Dca							
Install. method	Core	Pole		31	Copper		Single Trefoil	31	Copper		Single Trefoil	31	Copper		Single Trefoil				
Length	1st equipit.	L. Max		61 m			598 m (DU)	85 m			165 m (DU)	95 m			165 m (DU)				
ΔU Max	ΔU Circuit	ΔU Total		4 %	0.36 %		0.86 %	4 %	1.79 %		2.30 %	4 %	2 %		2.51 %				
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	1.00	0.60	1.00 (30°C)	0.61	1.00	1.00	0.61				
PROTECTION				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked							
Type	Prot. IC		MCCB	Basis Prot			MCCB	Basis Prot			MCCB	Basis Prot							
<b>RESULTS FIXING</b>																			
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	2	150 mm²		fixed <input checked="" type="checkbox"/>	1 X	185 mm²		fixed <input checked="" type="checkbox"/>	1	185 mm²						
	N°	Neutral		1	150 mm²			1	185 mm²			1	185 mm²						
	N°	PE/PEN		1	150 mm²			1	185 mm²			1	185 mm²						
Harm. Rate	Loaded N			HR <= 15%			No	HR <= 15%			No	HR <= 15%			No				
Protection				NSX630H Micrologic 2.3 4P4T				NSX630H Micrologic 2.3 4P4T				NSX630H Micrologic 2.3 4P4T							
Rating	Ir	Im/Isd/IN Fus.		630 A	252 A		756 A	630 A	325.5 A		1627.5 A	630 A	325.5 A		1627.5 A				
K on rating.	Tr	Tempo		1	16 s		20 ms	1	16 s		20 ms	1	16 s		20 ms				
Magnetic	Li off	IΔn	Electronic					Electronic				Electronic							
Downs.Ther.	Li	Δt	On circuit	6930 A				On circuit	6930 A			On circuit	6930 A						
<b>RESULTS</b>																			
Cable	Neutral	PE/PEN	2X3X(1x150)		1x150		1x150	3X(1x185)		1x185		1x185	3X(1x185)		1x185				
Criteria	IB		IMPOS			152.83 A			IMPOS			322.64 A			IMPOS				
S Th.	Iz		48.576 mm²			532.17 A			198.284 mm²			310.87 A			198.284 mm²				
Im / Isd Max	Ik Up/Dn		9031 A			55.1 kA / 31.3 kA			6287 A			55.1 kA / 17.7 kA			5744 A		55.1 kA / 16.3 kA		
Discrimination	Backup		Total			Without			Total			Without			Total		Without		
<b>IK INFORMATIONS / PROTECTION</b>																			
Icu / Icm	Icu Backup	Ip	70 kA	70 kA	29.65 kA		70 kA	70 kA	21.68 kA		70 kA	70 kA	20.72 kA						
Icu S-pole	Icu S-pole backup																		
Tmax. Prot.	Release		157 ms	4P4T			231 ms	4P4T			231 ms	4P4T							
Contactor	Thermal relay																		
Manufacturer				mg19in1.dug			mg19in1.dug			mg19in1.dug			mg19in1.dug						
<b>DISCRIMINATION</b>																			
Limit	From																		
Thermal	Differential		With			Not Applicable			With			Not Applicable			With		Not Applicable		
Logical Discrim.			<input type="checkbox"/>						<input type="checkbox"/>						<input type="checkbox"/>				
T1	T2																		
<b>IK END</b>																			
Ik3 Max	Ik2 Min	If	31309 A	20104 A	9934 A		17661 A	11410 A	6916 A		16252 A	10491 A	6318 A						
Ik2 Max	Ik1 Min	Ik1 Max	27114.7 A	11105 A	15084 A		15295.0 A	7462 A	10029 A		14074.9 A	6773 A	9114 A						
LOGO Entreprise				MODIFICATIONS								Calculation sheet 3 circuits LV BUSBAR-1 00CDP01GS011..02CDG01GS011							
				PROJECT: 2304								Folio							
				DRAWING:								1							
				Date: 11/08/2023 Standard: IEC364-17								3							

**CALCULATION SHEET 3C**

NETWORK																												
Earthing Syst		TN			I Total		Normal		Standby																			
Voltage		400 V			I installed		4546.63 A																					
DISTRIBUTION					I Avail		2674.25 A																					
Upstream N		TRANSFORMER-1			Ik3 max		55050 A																					
Upstream S		LV BUSBAR-1			ΔU		0.51 %																					
CIRCUIT					Circuit OK		Circuit OK		Circuit OK																			
					IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>																
Upstream			LV BUSBAR-1		LV BUSBAR-1			LV BUSBAR-1																				
Ref mark			00BTW01GS011		00BRU01GS011			01CDC01GS011																				
Upstream BB		D.origin																										
Style		Board				Board				Board																		
Content		ΔU Regulator		3P+N+PE		3P+PE				3P+N+PE																		
Designation																												
CABLES INFORMATIONS/EQUIPM.					DCDP			UPSDP-1			EAP1																	
N°	Consump	K Coincid	Geog.location	1	8kW	1		1	40kW	1		1	225kW	1														
Downst BB		Modif.																										
Cos φ		K Use		UL		0.95		1				0.95		1														
Cos φ Start.		ID/IN		ΔU Start																								
η	Supply			1.00		Normal			1.00		Normal			1.00		Normal												
Equip. Pole	Type			3P+N					3P					3P+N														
CABLE					00BTW01GS011				00BRU01GS011				01CDC01GS011															
Type			N2XRH (90°C) Dca					N2XRH (90°C) Dca					N2XRH (90°C) Dca															
Install. method		Core	Pole	31	Copper		Multicore			31	Copper		Multicore			31	Copper		Single Trefoil									
Length	1st equipit.	L. Max	65 m	122 m (IC)					58 m	84 m (DU)					85 m	180 m (DU)												
ΔU Max	ΔU Circuit	ΔU Total	2 %	0.49 %		1.00 %			2 %	1.02 %		1.53 %			3.5 %	1.41 %		1.92 %										
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60									
PROTECTION					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked													
Type	Prot. IC		MCCB	Basis Prot			MCCB		Basis Prot			MCCB		Basis Prot														
RESULTS FIXING																												
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	1	16 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1 X	35 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	2	120 mm <sup>2</sup>															
	N°	Neutral		1	16 mm <sup>2</sup>							1	120 mm <sup>2</sup>															
	N°	PE/PEN		1	16 mm <sup>2</sup>			1	35 mm <sup>2</sup>			1	120 mm <sup>2</sup>															
Harm. Rate	Loaded N		HR <= 15%			No						No		HR <= 15% No														
Protection			NSX100H TM63D 4P4T					NSX100H Micrologic 2.2 3P3T					NSX630H Micrologic 2.3 4P3T+N/2															
Rating	Ir	Im/Isd/IN Fus.	63 A	44.1 A		500 A		100 A	70 A		105 A		630 A	400 A		600 A												
K on rating.	Tr	Tempo	1	15 s				1	16 s		20 ms		1	16 s		20 ms												
Magnetic	Li off	IΔn	Standard (C)					Electronic					Electronic															
Downs.Ther.	Li	Δt	On circuit					On circuit	1500 A				On circuit	6930 A														
RESULTS																												
Cable	Neutral	PE/PEN	5G16				4G35				2X3X(1x120)	1x120		1x120														
Criteria		IB	IMPOS	12.15 A			IMPOS	60.77 A			IMPOS	360.84 A																
S Th.		Iz	9.740 mm <sup>2</sup>	60.08 A			21.761 mm <sup>2</sup>	94.75 A			97.517 mm <sup>2</sup>	458.98 A																
Im / Isd Max		Ik Up/Dn	932 A	55.1 kA / 3.3 kA			2407 A	55.1 kA / 7.9 kA			6123 A	55.1 kA / 24.2 kA																
Discrimination		Backup	Total	Without			Total	Without			Total	Without																
IK INFORMATIONS / PROTECTION																												
Icu / Icm	Icu Backup	Ip	70 kA	70 kA		5.01 kA		70 kA	70 kA		7.22 kA		70 kA	70 kA		25.73 kA												
Icu S-pole		Icu S-pole backup																										
Tmax. Prot.		Release	2 ms	4P4T			8 ms	3P3T			100 ms	4P3T+N/2																
Contactor		Thermal relay																										
Manufacturer					mg19in1.dug					mg19in1.dug					mg19in1.dug													
DISCRIMINATION																												
Limit	From																											
Thermal	Differential		With			Not Applicable			With			Not Applicable			With			Not Applicable										
Logical Discrim.			<input type="checkbox"/>						<input type="checkbox"/>						<input type="checkbox"/>													
T1	T2																											
IK END																												
Ik3 Max	Ik2 Min	If	3339 A	1954 A		1118 A		7869 A	4642 A		2648 A		24163 A	15237 A		6735 A												
Ik2 Max	Ik1 Min	Ik1 Max	2891.4 A	1132 A		1675 A		6814.6 A					20925.8 A	7261 A		10126 A												
LOGO Enterprise					MODIFICATIONS EA Caneco								Calculation sheet 3 circuits LV BUSBAR-1 00BTW01GS011..01CDC01GS011															
													PROJECT: 2304								Folio 2 3							
													DRAWING:															
Date: 11/08/2023					Standard: IEC364-17																							

NETWORK					Normal			Standby		CALCULATION SHEET 3C						
Earthing Syst		TN			I Total		1872.38 A									
Voltage		400 V			I installed		4546.63 A									
DISTRIBUTION					I Avail		2674.25 A									
Upstream N	TRANSFORMER-1			Ik3 max		55050 A										
Upstream S	LV BUSBAR-1			ΔU		0.51 %										
CIRCUIT		<b>Circuit OK</b>			<b>Circuit OK</b>											
		IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input type="checkbox"/>	DU <input type="checkbox"/>	IC <input type="checkbox"/>	SC <input type="checkbox"/>			
Upstream		LV BUSBAR-1			LV BUSBAR-1											
Ref mark		02CDC01GS011			00SGA10GH011											
Upstream BB		D.origin														
Style		Board			Board											
Content		ΔU Regulator			3P+N+PE			3P+N+PE								
Designation																
CABLES INFORMATIONS/EQUIPM.					EAP2			FPHP								
N°	Consump	K Coincid	Geog.location	1	225kW	1		1	186kW	1						
Downst BB			Modif.				A				A					
Cos φ	K Use	UL	0.9	1			0.94	1								
Cos φ Start.	ID/IN	ΔU Start														
η	Supply		1.00	Normal			1.00	Normal								
Equip. Pole	Type		3P+N				3P+N									
CABLE					02CDC01GS011			00SGA10GH011								
Type			N2XRH (90°C) Dca				N2XRH (90°C) Dca									
Install. method	Core	Pole	31	Copper		Single Trefoil	31	Copper		Single Trefoil						
Length	1st equipit.	L. Max	88 m	180 m (DU)			95 m	191 m (DU)								
ΔU Max	ΔU Circuit	ΔU Total	3.5 %	1.46 %		1.97 %	4 %	1.74 %		2.24 %						
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60	
PROTECTION					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked			
Type	Prot. IC		MCCB	Basis Prot		MCCB		Basis Prot								
RESULTS FIXING																
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	2	120 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1	185 mm <sup>2</sup>		fixed <input type="checkbox"/>					
N°		Neutral			1	120 mm <sup>2</sup>				1	185 mm <sup>2</sup>					
N°		PE/PEN			1	120 mm <sup>2</sup>				1	185 mm <sup>2</sup>					
Harm. Rate	Loaded N		HR <= 15%			No	HR <= 15%			No						
Protection			NSX630H Micrologic 2.3 4P3T+N/2					NSX400H Micrologic 2.3 4P4T								
Rating	Ir	Im/Isd/IN Fus.	630 A	400 A	600 A		400 A	288 A	2880 A							
K on rating.	Tr	Tempo	1	16 s	20 ms		1	16 s	20 ms							
Magnetic	Li off	IΔn	Electronic				Electronic									
Downs.Ther.	Li	Δt	On circuit	6930 A			On circuit	4800 A								
RESULTS																
Cable	Neutral		PE/PEN	2X3X(1x120)		1x120		1x120	3X(1x185)		1x185		1x185			
Criteria	IB		IMPOS			360.84 A			IMPOS			285.60 A				
S Th.	Iz		97.517 mm <sup>2</sup>			458.98 A			169.019 mm <sup>2</sup>			305.78 A				
Im / Isd Max	Ik Up/Dn		5950 A			55.1 kA / 23.6 kA			5744 A			55.1 kA / 16.3 kA				
Discrimination	Backup		Total			Without			Total			Without				
IK INFORMATIONS / PROTECTION																
Icu / Icm	Icu Backup		Ip	70 kA	70 kA	25.42 kA	70 kA	70 kA	17.90 kA							
Icu S-pole	Icu S-pole backup															
Tmax. Prot.	Release		100 ms			4P3T+N/2			231 ms			4P4T				
Contactor	Thermal relay															
Manufacturer	mg19in1.dug					mg19in1.dug										
DISCRIMINATION																
Limit	From															
Thermal	Differential		With			Not Applicable			With			Not Applicable				
Logical Discrim.			<input type="checkbox"/>				<input type="checkbox"/>				<input type="checkbox"/>					
T1	T2															
IK END																
Ik3 Max	Ik2 Min	If	23620 A	14885 A	6545 A	16252 A	10491 A	6318 A								
Ik2 Max	Ik1 Min	Ik1 Max	20455.4 A	7040 A	9823 A	14074.9 A	6773 A	9114 A								
LOGO Entreprise					Calculation sheet 3 circuits LV BUSBAR-1 02CDC01GS011..00SGA											
					PROJECT: 2304											
					DRAWING:											
Date: 11/08/2023			Standard: IEC364-17			Folio			3			3				

NETWORK					Normal			Standby		CALCULATION SHEET 3C									
Earthing Syst		TN			I Total		2363.78 A												
Voltage		400 V			I installed		4546.63 A												
DISTRIBUTION					I Avail		2182.85 A												
Upstream N	TRANSFORMER-2				Ik3 max		55494 A												
Upstream S					$\Delta U$		0.38 %												
Ref mark	LV BUSBAR-2																		
CIRCUIT			Circuit OK		Circuit OK			Circuit OK											
IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>					IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>				
Upstream			LV BUSBAR-2			LV BUSBAR-2			LV BUSBAR-2										
Ref mark			00BTW02GS011			00BRU02GS011			03CDC01GS011										
Upstream BB		D.origin																	
Style		Board					Board			Board									
Content		$\Delta U$ Regulator		3P+N+PE			3P+PE			3P+N+PE									
Designation																			
CABLES INFORMATIONS/EQUIPM.					DCDP	UPSDP-2			EAP3										
N°	Consump	K Coincid	Geog.location	1	8kW	1		1	40kW	1		1	225kW	1					
Downst BB			Modif.																
Cos φ	K Use	UL	0.95	1		A		0.95	1		A	0.9	1		A				
Cos φ Start.	ID/IN	$\Delta U$ Start																	
$\eta$	Supply		1.00	Normal				1.00	Normal				1.00	Normal					
Equip. Pole	Type		3P+N					3P					3P+N						
CABLE					00BTW02GS011	00BRU02GS011			03CDC01GS011										
Type			N2XRH (90°C) Dca				N2XRH (90°C) Dca				N2XRH (90°C) Dca								
Install. method	Core	Pole	31	Copper		Multicore	31	Copper		Multicore	31	Copper		Single Trefoil					
Length	1st equipit.	L. Max	55 m			122 m (IC)	58 m			92 m (DU)	97 m			187 m (DU)					
$\Delta U$ Max	$\Delta U$ Circuit	$\Delta U$ Total	2 %	0.41 %		0.79 %	2 %	1.02 %		1.40 %	3.5 %	1.61 %		1.99 %					
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60
PROTECTION					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked						
Type	Prot. IC		MCCB	Basis Prot			MCCB	Basis Prot			MCCB	Basis Prot							
RESULTS FIXING																			
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	1	16 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1 X	35 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	2	120 mm <sup>2</sup>						
N°		Neutral	1		16 mm <sup>2</sup>							1		120 mm <sup>2</sup>					
N°		PE/PEN	1		16 mm <sup>2</sup>		1			35 mm <sup>2</sup>		1		120 mm <sup>2</sup>					
Harm. Rate	Loaded N		HR <= 15%			No				No	HR <= 15%			No					
Protection				NSX100H TM63D 4P4T				NSX100H Micrologic 2.2 3P3T				NSX630H Micrologic 2.3 4P3T+N/2							
Rating	Ir	Im/Isd/IN Fus.	63 A	44.1 A		500 A	100 A	70 A		140 A	630 A	400 A		600 A					
K on rating.	Tr	Tempo	1	15 s			1	16 s		20 ms	1	16 s		20 ms					
Magnetic	Li off	$I_{\Delta n}$	Standard (C)				Electronic				Electronic								
Downs.Ther.	Li	$\Delta t$	On circuit				On circuit	1500 A			On circuit	6930 A							
RESULTS																			
Cable	Neutral		PE/PEN	5G16				4G35				2X3X(1x120)	1x120		1x120				
Criteria	IB		IMPOS			12.15 A		IMPOS			60.77 A		IMPOS		360.84 A				
S Th.	Iz		9.740 mm <sup>2</sup>			60.08 A		21.761 mm <sup>2</sup>			94.75 A		97.517 mm <sup>2</sup>		458.98 A				
Im / Isd Max	Ik Up/Dn		1103 A			55.5 kA / 3.9 kA		2428 A			55.5 kA / 7.9 kA		5603 A		55.5 kA / 22.2 kA				
Discrimination	Backup		Total			Without		Total			Without		Total		Without				
IK INFORMATIONS / PROTECTION																			
Icu / Icm	Icu Backup		Ip	70 kA	70 kA		5.91 kA	70 kA	70 kA		7.23 kA	70 kA	70 kA		24.58 kA				
Icu S-pole	Icu S-pole backup																		
Tmax. Prot.	Release		2 ms			4P4T		8 ms			3P3T		97 ms		4P3T+N/2				
Contactor	Thermal relay																		
Manufacturer	mg19in1.dug								mg19in1.dug					mg19in1.dug					
DISCRIMINATION																			
Limit	From																		
Thermal	Differential		With			Not Applicable			With			Not Applicable			With				
Logical Discrim.			<input type="checkbox"/>						<input type="checkbox"/>						<input type="checkbox"/>				
T1	T2																		
IK END																			
Ik3 Max	Ik2 Min	If	3940 A	2306 A		1324 A	7880 A	4649 A		2671 A	22218 A	13972 A		6163 A					
Ik2 Max	Ik1 Min	Ik1 Max	3412.2 A	1337 A		1979 A	6824.5 A				19241.0 A	6486 A		9059 A					
<b>LOGO</b> Enterprise			MODIFICATIONS								Calculation sheet 3 circuits LV BUSBAR-2 00BTW02GS011..03CDC01GS011								
			Ind.	EA Caneco								PROJECT:				2304			
			Date:	11/08/2023		Standard:	IEC364-17		DRAWING:										
																	Folio		
														1					
														4					

NETWORK								<b>CALCULATION SHEET 3C</b>																															
Earthing Syst		TN										I Total		Normal		Standby																							
Voltage		400 V										I installed		4546.63 A																									
DISTRIBUTION												I Avail		2182.85 A																									
Upstream N		TRANSFORMER-2										Ik3 max		55494 A																									
Upstream S		LV BUSBAR-2										$\Delta U$		0.38 %																									
CIRCUIT												IN <input checked="" type="checkbox"/>		DU <input checked="" type="checkbox"/>		IC <input checked="" type="checkbox"/>		SC <input checked="" type="checkbox"/>		Circuit OK		IN <input checked="" type="checkbox"/>		DU <input checked="" type="checkbox"/>		IC <input checked="" type="checkbox"/>		SC <input checked="" type="checkbox"/>		Circuit OK		IN <input checked="" type="checkbox"/>		DU <input checked="" type="checkbox"/>		IC <input checked="" type="checkbox"/>		SC <input checked="" type="checkbox"/>	
Upstream		LV BUSBAR-2						IN <input checked="" type="checkbox"/>		DU <input checked="" type="checkbox"/>		IC <input checked="" type="checkbox"/>		SC <input checked="" type="checkbox"/>		LV BUSBAR-2		IN <input checked="" type="checkbox"/>		DU <input checked="" type="checkbox"/>		IC <input checked="" type="checkbox"/>		SC <input checked="" type="checkbox"/>		LV BUSBAR-2		IN <input checked="" type="checkbox"/>		DU <input checked="" type="checkbox"/>		IC <input checked="" type="checkbox"/>		SC <input checked="" type="checkbox"/>		LV BUSBAR-2			
Ref mark								04CDC01GS011								05CDC01GS011								03CDG01GS011															
Upstream BB		D.origin																																					
Style		Board														Board																							
Content		3P+N+PE						3P+N+PE								3P+N+PE																							
Designation																																							
CABLES INFORMATIONS/EQUIPM.																EAP4				EAP5				ERP3															
N°	Consump	K Coincid	Geog.location	1	225kW		1			1		225kW		1			1		190kW		1																		
Downst BB				Modif.						A						A				A																			
Cos φ	K Use	UL	0.9	1				0.9		1		0.85		1				0.85		1																			
Cos φ Start.	ID/IN	ΔU Start																																					
η	Supply		1.00	Normal				1.00		Normal		1.00		Normal				1.00		Normal																			
Equip. Pole	Type		3P+N					3P+N				3P+N						3P+N																					
CABLE																04CDC01GS011				05CDC01GS011				03CDG01GS011															
Type				N2XRH (90°C) Dca								N2XRH (90°C) Dca								N2XRH (90°C) Dca																			
Install. method		Core		Pole	31		Copper		Single Trefoil		31		Copper		Single Trefoil		31		Copper		Single Trefoil																		
Length	1st equipit.	L. Max	107 m				187 m (DU)				117 m				187 m (DU)		135 m				171 m (DU)																		
ΔU Max	ΔU Circuit	ΔU Total	3.5 %		1.78 %		2.16 %		3.5 %		1.94 %		2.32 %		4 %		2.85 %		3.23 %																				
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	1.00	0.60	1.00 (30°C)	0.61	1.00	1.00	0.61																		
PROTECTION								<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked																							
Type	Prot. IC		MCCB		Basis Prot		MCCB		Basis Prot		MCCB		Basis Prot		MCCB		Basis Prot																						
RESULTS FIXING																																							
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	2	120 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	2 X	120 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1	185 mm <sup>2</sup>																										
N°		Neutral	1		120 mm <sup>2</sup>		1		120 mm <sup>2</sup>		1		185 mm <sup>2</sup>																										
N°		PE/PEN	1		120 mm <sup>2</sup>		1		120 mm <sup>2</sup>		1		185 mm <sup>2</sup>																										
Harm. Rate	Loaded N		HR <= 15%				No				HR <= 15%				No				HR <= 15%				No																
Protection				NSX630H Micrologic 2.3 4P3T+N/2								NSX400H Micrologic 2.3 4P3T+N/2								NSX630H Micrologic 2.3 4P4T																			
Rating	Ir	Im/Isd/IN Fus.	630 A	400 A		600 A		400 A	400 A		2400 A		630 A	325.5 A		1627.5 A																							
K on rating.	Tr	Tempo	1	16 s		20 ms		1	16 s		20 ms		1	16 s		20 ms																							
Magnetic	Li off	IΔn	Electronic					Electronic					Electronic																										
Downs.Ther.	Li	Δt	On circuit	6930 A				On circuit	4800 A				On circuit	6930 A																									
RESULTS																																							
Cable	Neutral	PE/PEN	2X3X(1x120)		1x120		1x120		2X3X(1x120)		1x120		1x120		3X(1x185)		1x185		1x185																				
Criteria		IB	IMPOS		360.84 A				IMPOS		360.84 A				IMPOS		322.64 A																						
S Th.	Iz		97.517 mm <sup>2</sup>		458.98 A				97.517 mm <sup>2</sup>		458.98 A				198.284 mm <sup>2</sup>		310.87 A																						
Im / Isd Max	Ik Up/Dn		5145 A		55.5 kA / 20.7 kA		4755 A		55.5 kA / 19.4 kA		4337 A		55.5 kA / 12.3 kA																										
Discrimination		Backup	Total		Without		Total		Without		Total		Without																										
IK INFORMATIONS / PROTECTION																																							
Icu / Icm	Icu Backup	Ip	70 kA	70 kA		23.67 kA		70 kA	70 kA		19.63 kA		70 kA	70 kA		17.81 kA																							
Icu S-pole		Icu S-pole backup																																					
Tmax. Prot.	Release		97 ms			4P3T+N/2		97 ms			4P3T+N/2		227 ms			4P4T																							
Contactor	Thermal relay																																						
Manufacturer			mg19in1.dug				mg19in1.dug								mg19in1.dug																								
DISCRIMINATION																																							
Limit	From																																						
Thermal	Differential		With				Not Applicable				With				Not Applicable																								
Logical Discrim.			<input type="checkbox"/>				<input type="checkbox"/>				<input type="checkbox"/>				<input type="checkbox"/>																								
T1	T2																																						
IK END																																							
Ik3 Max	Ik2 Min	If	20733 A	13016 A		5660 A		19425 A	12175 A		5231 A		12327 A	7930 A		4771 A																							
Ik2 Max	Ik1 Min	Ik1 Max	17955.2 A	5930 A		8295 A		16822.2 A	5462 A		7649 A		10675.1 A	4961 A		6698 A																							
<b>LOGO</b> Enterprise				Calculation sheet 3 circuits LV BUSBAR-2 04CDC01GS011..03CDG01GS011																																			
																Ind.		MODIFICATIONS																					
																		EA Caneco																					
				Date: 11/08/2023				Standard: IEC364-17				PROJECT: 2304				Folio																							
												DRAWING:								2		4																	

File : PRF Overall Caneco BB2.afr

©ALPI Caneco BT 5.12 Authorized user

# CALCULATION SHEET 3C

NETWORK				Normal		Standby		<b>CALCULATION SHEET 3C</b>																						
Earthing Syst		TN		I Total		2363.78 A																								
Voltage		400 V		I installed		4546.63 A																								
DISTRIBUTION				I Avail		2182.85 A																								
Upstream N	TRANSFORMER-2			Ik3 max		55494 A																								
Upstream S	LV BUSBAR-2			ΔU		0.38 %																								
<b>CIRCUIT</b>				<b>Circuit OK</b>		<b>Circuit OK</b>		<b>Circuit OK</b>																						
				IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>																			
Upstream		LV BUSBAR-2				LV BUSBAR-2				LV BUSBAR-2																				
Ref mark				00CDP02GS011				04CDG01GS011				05CDG01GS011																		
Upstream BB		D.origin																												
Style		Board						Board				Board																		
Content		ΔU Regulator		3P+N+PE				3P+N+PE				3P+N+PE																		
Designation																														
CABLES INFORMATIONS/EQUIPM.				CVP2				ERP4				ERP5																		
N°	Consump	K Coincid	Geog.location	1	125kW	1		1	190kW	1		1	190kW	1																
Downst BB		Modif.																												
Cos φ	K Use	UL	0.85	1			A	0.85	1			0.85	1		A															
Cos φ Start.	ID/IN	ΔU Start																												
η	Supply		1.00	Normal				1.00	Normal				1.00	Normal																
Equip. Pole	Type		3P+N					3P+N					3P+N																	
<b>CABLE</b>				00CDP02GS011				04CDG01GS011				05CDG01GS011																		
Type			N2XRH (90°C) Dca					N2XRH (90°C) Dca					N2XRH (90°C) Dca																	
Install. method	Core	Pole	31	Copper		Single Trefoil			31	Copper		Single Trefoil			31	Copper		Single Trefoil												
Length	1st equipit.	L. Max	80 m			446 m (DU)			145 m			171 m (DU)			155 m			171 m (DU)												
ΔU Max	ΔU Circuit	ΔU Total	4 %	0.65 %		1.03 %			4 %	3.06 %		3.44 %			4 %	3.27 %		3.65 %												
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.61	1.00	1.00	0.61	1.00 (30°C)	0.61	1.00	1.00	0.61											
<b>PROTECTION</b>					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked															
Type	Prot. IC		MCCB		Basis Prot			MCCB		Basis Prot			MCCB		Basis Prot															
<b>RESULTS FIXING</b>																														
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	2	150 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1 X	185 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1	185 mm <sup>2</sup>																	
	N°	Neutral		1	150 mm <sup>2</sup>			1	185 mm <sup>2</sup>			1	185 mm <sup>2</sup>																	
	N°	PE/PEN		1	150 mm <sup>2</sup>			1	185 mm <sup>2</sup>			1	185 mm <sup>2</sup>																	
Harm. Rate	Loaded N		HR <= 15%				No		HR <= 15%				No		HR <= 15% No															
Protection				NSX630H Micrologic 2.3 4P4T					NSX630H Micrologic 2.3 4P4T					NSX630H Micrologic 2.3 4P4T																
Rating	Ir	Im/Isd/IN Fus.	630 A	252 A	756 A	630 A	325.5 A	1627.5 A	630 A	325.5 A	1627.5 A																			
K on rating.	Tr	Tempo	1	16 s	20 ms	1	16 s	20 ms	1	16 s	20 ms	1	16 s	20 ms																
Magnetic	Li off	IΔn	Electronic			Electronic			Electronic			Electronic																		
Downs.Ther.	Li	Δt	On circuit	6930 A		On circuit	6930 A		On circuit	6930 A		On circuit	6930 A																	
<b>RESULTS</b>																														
Cable	Neutral	PE/PEN	2X3X(1x150)		1x150		1x150		3X(1x185)		1x185		1x185		3X(1x185)		1x185		1x185											
Criteria	IB		IMPOS			212.26 A			IMPOS			322.64 A			IMPOS			322.64 A												
S Th.	Iz		48.576 mm <sup>2</sup>			532.17 A			198.284 mm <sup>2</sup>			310.87 A			198.284 mm <sup>2</sup>			310.87 A												
Im / Isd Max	Ik Up/Dn		7588 A			55.5 kA / 27.2 kA			4071 A			55.5 kA / 11.6 kA			3835 A			55.5 kA / 11.0 kA												
Discrimination	Backup		Total			Without			Total			Without			Total			Without												
<b>IK INFORMATIONS / PROTECTION</b>																														
Icu / Icm	Icu Backup	Ip	70 kA	70 kA	27.48 kA	70 kA	70 kA	17.24 kA	70 kA	70 kA	16.72 kA																			
Icu S-pole	Icu S-pole backup																													
Tmax. Prot.	Release		151 ms		4P4T	227 ms		4P4T	227 ms		4P4T																			
Contactor	Thermal relay																													
Manufacturer	mg19in1.dug					mg19in1.dug					mg19in1.dug																			
<b>DISCRIMINATION</b>																														
Limit	From																													
Thermal	Differential		With			Not Applicable			With			Not Applicable			With			Not Applicable												
Logical Discrim.			<input type="checkbox"/>						<input type="checkbox"/>						<input type="checkbox"/>															
T1	T2																													
<b>IK END</b>																														
Ik3 Max	Ik2 Min	If	27238 A	17443 A	8347 A	11614 A	7467 A	4478 A	10979 A	7054 A	4219 A																			
Ik2 Max	Ik1 Min	Ik1 Max	23588.7 A	8945 A	12204 A	10058.1 A	4644 A	6275 A	9507.8 A	4366 A	5903 A																			
<b>LOGO</b> Enterprise				MODIFICATIONS								Calculation sheet 3 circuits LV BUSBAR-2 00CDP02GS011..05CDG01GS011																		
												EA Caneco								PROJECT: 2304					Folio					
																				DRAWING:					3			4		
Date: 11/08/2023	Standard: IEC364-17																													

NETWORK				Normal		Standby		CALCULATION SHEET 3C			
Earthing Syst	TN			I Total	2363.78 A						
Voltage	400 V			I installed	4546.63 A						
DISTRIBUTION				I Avail	2182.85 A						
Upstream N	TRANSFORMER-2			Ik3 max	55494 A						
Upstream S	LV BUSBAR-2			ΔU	0.38 %						
Ref mark											

CIRCUIT				Circuit OK											
IN	<input checked="" type="checkbox"/>	DU	<input checked="" type="checkbox"/>	IC	<input checked="" type="checkbox"/>	SC	<input checked="" type="checkbox"/>	IN	<input type="checkbox"/>	DU	<input type="checkbox"/>	IC	<input type="checkbox"/>	SC	<input type="checkbox"/>
Upstream				LV BUSBAR-2											
Ref mark				00SGA11GH011											
Upstream BB		D.origin													
Style		Board													
Content		ΔU Regulator		3P+N+PE											
Designation															

CABLES INFORMATIONS/EQUIPM.				FPHP											
N°	Consump	K Coincid	Geog.location	1	21.36kW	1									
Downst BB		Modif.					A								
Cos φ	K Use	UL	0.94		1										
Cos φ Start.	ID/IN	ΔU Start													
η	Supply	1.00	Normal												
Equip. Pole	Type	3P+N													

CABLE					00SGA11GH011										
Type		N2XRH (90°C) Dca													
Install. method	Core	Pole	31	Copper	Multicore										
Length	1st equipit.	L. Max	145 m		167 m (IC)										
ΔU Max	ΔU Circuit	ΔU Total	4 %	2.93 %	3.31 %										
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	0.60						

PROTECTION		<input type="checkbox"/> No check on Thermal stress	<input type="checkbox"/> No check on Thermal stress	<input type="checkbox"/> No check on Thermal stress
		<input checked="" type="checkbox"/> Icu CB checked	<input type="checkbox"/> Icu CB checked	<input type="checkbox"/> Icu CB checked

Type	Prot. IC	MCCB	Basis Prot				
------	----------	------	------------	--	--	--	--

RESULTS FIXING															
fixed	<input checked="" type="checkbox"/>	N°	Phase	fixed	<input checked="" type="checkbox"/>	1	16 mm²	fixed	<input type="checkbox"/>			fixed	<input type="checkbox"/>		
		Neutral				1	16 mm²								
		PE/PEN				1	16 mm²								
Harm. Rate	Loaded N			HR <= 15%		No									
Protection			NSX100H Micrologic 2.2 4P4T												
Rating	Ir	Im/Isd/IN Fus.	40 A		40 A		400 A								
K on rating.	Tr	Tempo	1		16 s		20 ms								
Magnetic	Li off	IΔn	Electronic												
Downs.Ther.	Li	Δt	On circuit		600 A										

RESULTS							
Cable	Neutral	PE/PEN	5G16				
Criteria	IB		IMPOS		32.80 A		
S Th.	Iz		8.328 mm²		60.08 A		
Im / Isd Max	Ik Up/Dn		461 A		55.5 kA / 1.5 kA		/
Discrimination	Backup		Total		Without		/

IK INFORMATIONS / PROTECTION							
Icu / Icm	Icu Backup	Ip	70 kA	70 kA	2.26 kA		
Icu S-pole	Icu S-pole backup						
Tmax. Prot.	Release	2 ms		4P4T			
Contactor	Thermal relay						
Manufacturer		mg19in1.dug					

DISCRIMINATION							
Limit	From						
Thermal	Differential	With		Not Applicable			
Logical Discrim.		<input type="checkbox"/>		<input type="checkbox"/>			
T1	T2						
IK END							
Ik3 Max	Ik2 Min	If	1505 A	881 A	507 A		
Ik2 Max	Ik1 Min	Ik1 Max	1303.8 A	509 A	754 A		

<b>LOGO</b> Enterprise		Calculation sheet 3 circuits LV BUSBAR-2 00SGA11GH011	
Ind.	MODIFICATIONS		
	EA Caneco		
Date:	11/08/2023	Standard:	IEC364-17
PROJECT: 2304		Folio	
		Drawing: 4 4	

# CALCULATION SHEET 3C

NETWORK				Normal		Standby		CALCULATION SHEET 3C											
Earthing Syst	TN			I Total	2644.61 A														
Voltage	400 V			I installed	4546.63 A														
DISTRIBUTION				I Avail	2346.99 A														
Upstream N	TRANSFORMER-1&2			Ik3 max	55050 A														
Upstream S	LV COMMON BUSBAR			$\Delta U$	0.51 %														
Ref mark																			
CIRCUIT				Circuit OK		Circuit OK		Circuit OK											
				IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>								
Upstream		LV COMMON BUSBAR		LV COMMON BUSBAR				LV COMMON BUSBAR											
Ref mark		LV COMMON BUSBAR_		00JB01GS011				00BJA01GS011											
Upstream BB		D.origin		LV COMMON BUSBAR_				LV COMMON BUSBAR_											
Style		Busbar		Board				Board											
Content		$\Delta U$ Regulator		3P+N+PE				3P+N+PE											
Designation																			
CABLES INFORMATIONS/EQUIPM.				LV COMMON BUSBAR_		ACDP		MCDP											
N°	Consump	K Coincid	Geog.location	1	1363.5kW	1		1	40kW	1		1	400kW	1					
Downst BB		Modif.		LV COMMON BUSBAR_			A				A				A				
Cos $\phi$	K Use	UL		0.87	1			0.85	1			0.9	1						
Cos $\phi$ Start.	ID/IN	$\Delta U$ Start																	
$\eta$	Supply			1.00	Normal			1.00	Normal			1.00	Normal						
Equip. Pole	Type			3P+N				3P+N				3P+N							
CABLE				00JB01GS011						00BJA01GS011									
Type	Dca			N2XRH (90°C) Dca						N2XRH (90°C) Dca									
Install. method	Core	Pole	31	Multi+PE			31	Copper			Single Trefoil	31	Copper			Single Trefoil			
Length	1st equipit.	L. Max		30 m				160 m (DU)	30 m				57 m (DU)						
$\Delta U$ Max	$\Delta U$ Circuit	$\Delta U$ Total		0 %	0.51 %			1.5 %	0.19 %			0.69 %	1.5 %	0.52 %			1.02 %		
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)		1.00	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60		
PROTECTION				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked			<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked			<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked									
Type	Prot. IC		MCCB	Basis Prot		MCCB	Basis Prot		MCCB	Basis Prot		MCCB	Basis Prot						
RESULTS FIXING																			
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	5	185 mm <sup>2</sup>	fixed <input checked="" type="checkbox"/>	1 X	120 mm <sup>2</sup>	fixed <input checked="" type="checkbox"/>	2	240 mm <sup>2</sup>								
	N°	Neutral		5	185 mm <sup>2</sup>		1	70 mm <sup>2</sup>		1	240 mm <sup>2</sup>								
	N°	PE/PEN		1	185 mm <sup>2</sup>		1	70 mm <sup>2</sup>		1	240 mm <sup>2</sup>								
Harm. Rate	Loaded N		HR <= 15%	No		HR <= 15%	No		HR <= 15%	No									
Protection			NS2500N Micrologic 2.0 4P4T			NSX250H Micrologic 2.2 4P4T			NS1250H Micrologic 2.0 4P3T+N/2										
Rating	Ir	Im/Isd/IN Fus.	2500 A	2375 A	23750 A	250 A	100 A	300 A	1250 A	750 A	1500 A								
K on rating.	Tr	Tempo	1	24 s	20 ms	1	16 s	20 ms	1	24 s	20 ms								
Magnetic	Li off	$I_{\Delta n}$	Electronic			Electronic			Electronic										
Downs.Ther.	Li	$\Delta t$	On circuit	25000 A		On circuit	3000 A		On circuit	12500 A									
RESULTS																			
Cable	Neutral		PE/PEN			3X(1x120)	1x70		1x70	2X3X(1x240)	1x240		1x240						
Criteria	IB			IMPOS	2256.38 A	IMPOS	67.92 A			IMPOS	641.50 A								
S Th.	Iz			197.196 mm <sup>2</sup>		34.280 mm <sup>2</sup>	229.49 A			251.678 mm <sup>2</sup>	726.74 A								
Im / Isd Max	Ik Up/Dn			28451 A	55.1 kA / 55.1 kA	9067 A	55.1 kA / 29.7 kA			16110 A	55.1 kA / 42.5 kA								
Discrimination	Backup		Total	Without		Total	Without		I<25.00kA	Without									
IK INFORMATIONS / PROTECTION																			
Icu / Icm	Icu Backup		Ip	70 kA	70 kA	121.11 kA	70 kA	70 kA	18.04 kA	70 kA	70 kA	89.25 kA							
Icu S-pole	Icu S-pole backup																		
Tmax. Prot.	Release			680 ms		4P4T	34 ms		4P4T	402 ms		4P3T+N/2							
Contactor	Thermal relay																		
Manufacturer				mg19in1.dug				mg19in1.dug				mg19in1.dug							
DISCRIMINATION																			
Limit	From									25000 A									
Thermal	Differential		With	Not Applicable	With	Not Applicable	With	Not Applicable	With	Not Applicable									
Logical Discrim.			<input type="checkbox"/>		<input type="checkbox"/>				<input type="checkbox"/>										
T1	T2																		
IK END																			
Ik3 Max	Ik2 Min	If	55050 A	34862 A	31296 A	29740 A	18862 A	9974 A	42502 A	27543 A	17721 A								
Ik2 Max	Ik1 Min	Ik1 Max	47675.0 A	41390 A	54137 A	25755.8 A	11173 A	15716 A	36807.6 A	21348 A	27657 A								
<b>LOGO Enterprise</b>				MODIFICATIONS								Calculation sheet 3 circuits LV COMMON BUSBAR							
												PROJECT: 2304						Folio	
Date: 11/08/2023				Standard: IEC364-17								DRAWING:							

©ALPI Caneco BT 5.12 Authorized user



# **CALCULATION SHEET 3C**

<b>NETWORK</b>				<b>Normal</b>				<b>Standby</b>		<b>CALCULATION SHEET 3C</b>													
Earthing Syst		TN		I Total		2644.61 A																	
Voltage		400 V		I installed		4546.63 A																	
<b>DISTRIBUTION</b>				I Avail		2346.99 A																	
Upstream N	TRANSFORMER-1&2			Ik3 max		55050 A																	
Upstream S	LV COMMON BUSBAR			$\Delta U$		0.51 %																	
<b>CIRCUIT</b>				<b>Circuit OK</b>				<b>Circuit OK</b>															
				IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>								
Upstream		LV COMMON BUSBAR				LV COMMON BUSBAR				LV COMMON BUSBAR													
Ref mark				00AEG01GH011				00AEG01GH012				00AEG01GH013											
Upstream BB	D.origin			LV COMMON BUSBAR_				LV COMMON BUSBAR_				LV COMMON BUSBAR_											
Style				Board				Board				Board											
Content	$\Delta U$ Regulator			3P+N+PE				3P+N+PE				3P+N+PE											
Designation																							
<b>CABLES INFORMATIONS/EQUIPM.</b>				HV SWITCH YARD PANEL-1				HV SWITCH YARD PANEL-2				110KV IPP COMPOUND											
N°	Consump	K Coincid	Geog.location	1	65kW	1		1	65kW	1		1	65kW	1									
Downst BB				Modif.				A				A											
Cos $\phi$	K Use	UL		0.9		1		0.9		1		0.9		1									
Cos $\phi$ Start.	ID/IN	$\Delta U$ Start																					
$\eta$	Supply			1.00	Normal			1.00	Normal			1.00	Normal										
Equip. Pole	Type			3P+N				3P+N				3P+N											
<b>CABLE</b>				00AEG01GH011				00AEG01GH012				00AEG01GH013											
<b>Type</b>				N2XRH (90°C) Dca				N2XRH (90°C) Dca				N2XRH (90°C) Dca											
Install. method	Core	Pole		31	Copper		Multi+PE	31	Copper		Multi+PE	31	Copper		Multi+PE								
Length	1st equipit.	L. Max		133 m			136 m (DU)	133 m			136 m (DU)	113 m			136 m (DU)								
$\Delta U$ Max	$\Delta U$ Circuit	$\Delta U$ Total		3.5 %	2.91 %		3.41 %	3.5 %	2.91 %		3.41 %	3.5 %	2.47 %		2.98 %								
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60				
<b>PROTECTION</b>					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked								<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked										
Type	Prot. IC		MCCB		Basis Prot				MCCB		Basis Prot				MCCB		Basis Prot						
<b>RESULTS FIXING</b>																							
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	1	50 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1 X	50 mm <sup>2</sup>		fixed <input checked="" type="checkbox"/>	1	50 mm <sup>2</sup>										
	N°	Neutral		1	50 mm <sup>2</sup>			1	50 mm <sup>2</sup>			1	50 mm <sup>2</sup>										
	N°	PE/PEN		1	50 mm <sup>2</sup>			1	50 mm <sup>2</sup>			1	50 mm <sup>2</sup>										
Harm. Rate	Loaded N		HR <= 15%				No				HR <= 15%				No								
Protection				NSXmH TM125D 4P4T				NSXmH TM125D 4P4T				NSXmH TM160D 4P4T											
Rating	Ir	Im/Isd/IN Fus.	125 A	112.5 A		1250 A	125 A	112.5 A		1250 A	160 A	112 A		1250 A									
K on rating.	Tr	Tempo	1	15 s			1	15 s			1	15 s											
Magnetic	Li off	$I\Delta n$	Standard (C)				Standard (C)				Standard (C)												
Downs.Ther.	Li	$\Delta t$	On circuit				On circuit				On circuit												
<b>RESULTS</b>																							
Cable	Neutral	PE/PEN	4X50				1X50	4X50				1X50	4X50				1X50						
Criteria	IB		IMPOS				104.24 A				IMPOS				104.24 A								
S Th.	Iz		45.831 mm <sup>2</sup>				115.09 A				45.831 mm <sup>2</sup>				115.09 A								
Im / Isd Max	Ik Up/Dn		1319 A				55.1 kA / 4.7 kA				1319 A				55.1 kA / 4.7 kA								
Discrimination	Backup		Total				Without				Total				Without								
<b>IK INFORMATIONS / PROTECTION</b>																							
Icu / Icm	Icu Backup		Ip	70 kA	70 kA		5.23 kA	70 kA	70 kA		5.23 kA	70 kA	70 kA		5.76 kA								
Icu S-pole	Icu S-pole backup																						
Tmax. Prot.	Release		15 ms				4P4T				15 ms				4P4T								
Contactor	Thermal relay																						
Manufacturer	mg19in1.dug							mg19in1.dug							mg19in1.dug								
<b>DISCRIMINATION</b>																							
Limit	From																						
Thermal	Differential		With				Not Applicable				With				Not Applicable								
Logical Discrим.			<input type="checkbox"/>				<input type="checkbox"/>				<input type="checkbox"/>				<input type="checkbox"/>								
T1	T2																						
<b>IK END</b>																							
Ik3 Max	Ik2 Min	If	4681 A	2767 A		1583 A	4681 A	2767 A		1583 A	5481 A	3242 A		1853 A									
Ik2 Max	Ik1 Min	Ik1 Max	4053.7 A	1612 A		2366 A	4053.7 A	1612 A		2366 A	4746.9 A	1892 A		2777 A									
<b>LOGO</b> <b>Entreprise</b>																Calculation sheet 3 circuits LV COMMON BUSBAR 00AEG01GH01  <b>PROJECT:</b> 2304 <b>DRAWING:</b> <span style="float: right;">Folio 3 6</span>							
Date: 11/08/2023	Standard: IEC364-17																						

# CALCULATION SHEET 3C

NETWORK				Normal			Standby		CALCULATION SHEET 3C																	
Earthing Syst		TN		I Total		2644.61 A																				
Voltage		400 V		I installed		4546.63 A																				
DISTRIBUTION				I Avail		2346.99 A																				
Upstream N	TRANSFORMER-1&2			Ik3 max		55050 A																				
Upstream S	LV COMMON BUSBAR			ΔU		0.51 %																				
CIRCUIT		Circuit OK			Circuit OK			Circuit OK																		
	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>					IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>										
Upstream		LV COMMON BUSBAR				LV COMMON BUSBAR				LV COMMON BUSBAR																
Ref mark		00GAF10GS011				00EGB01AC011				00EGB02AC011																
Upstream BB		D.origin		LV COMMON BUSBAR_				LV COMMON BUSBAR_				LV COMMON BUSBAR_														
Style		Board						Board				Board														
Content		3P+N+PE						3P+N+PE				3P+N+PE														
Designation																										
CABLES INFORMATIONS/EQUIPM.				RAW WATER STATION		TRACE HEATING-1			TRACE HEATING-2																	
N°	Consump	K Coincid	Geog.location	1	17kW	1		1	40kW	1		1	35kW	1												
Downst BB			Modif.								A					A										
Cos φ	K Use	UL	0.85	1				1	1			1	1													
Cos φ Start.	ID/IN	ΔU Start																								
η	Supply		1.00	Normal				1.00	Normal				1.00	Normal												
Equip. Pole	Type		3P+N					3P+N					3P+N													
CABLE				00GAF10GS011				00EGB01AC011				00EGB02AC011														
Type			N2XRH (90°C) Dca					N2XRH (90°C) Dca					N2XRH (90°C) Dca													
Install. method	Core	Pole	31	Copper		Multicore	31	Copper		Multicore	31	Copper		Multicore												
Length	1st equipit.	L. Max	105 m	122 m (IC)			80 m	126 m (DU)			80 m	92 m (DU)														
ΔU Max	ΔU Circuit	ΔU Total	4.5 %	1.71 %		2.22 %	3.5 %	1.9 %		2.40 %	3.5 %	2.59 %		3.10 %												
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	1.00	0.60	1.00 (30°C)	0.60	1.00	1.00	0.60											
PROTECTION				<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked												
Type	Prot. IC		MCCB	Basis Prot			MCCB	Basis Prot			MCCB	Basis Prot														
RESULTS FIXING																										
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	1	16 mm²		fixed <input checked="" type="checkbox"/>	1 X	25 mm²		fixed <input checked="" type="checkbox"/>	1	16 mm²													
	N°	Neutral		1	16 mm²			1	25 mm²			1	16 mm²													
	N°	PE/PEN		1	16 mm²			1	25 mm²			1	16 mm²													
Harm. Rate	Loaded N		HR <= 15%			No	HR <= 15%			No	HR <= 15%			No												
Protection			NSX100H TM63D 4P4T					NSX100H TM63D 4P4T					NSX100H TM63D 4P4T													
Rating	Ir	Im/Isd/IN Fus.	63 A	44.1 A		500 A	63 A	63 A		500 A	63 A	56.7 A		500 A												
K on rating.	Tr	Tempo	1	15 s			1	15 s			1	15 s														
Magnetic	Li off	IΔn	Standard (C)				Standard (C)				Standard (C)															
Downs.Ther.	Li	Δt	On circuit				On circuit				On circuit															
RESULTS																										
Cable	Neutral		PE/PEN	5G16			5G25			5G16																
Criteria	IB		IMPOS			28.87 A			IMPOS			57.74 A			IMPOS	50.52 A										
S Th.	Iz		9.740 mm²			60.08 A			18.444 mm²			76.47 A			14.580 mm²	60.08 A										
Im / Isd Max	Ik Up/Dn		581 A			55.1 kA / 2.1 kA			1174 A			55.1 kA / 4.2 kA			760 A	55.1 kA / 2.7 kA										
Discrimination	Backup		Total			Without			Total			Without			Total	Without										
IK INFORMATIONS / PROTECTION																										
Icu / Icm	Icu Backup	Ip	70 kA	70 kA		3.11 kA	70 kA	70 kA		5.13 kA	70 kA	70 kA		4.08 kA												
Icu S-pole	Icu S-pole backup																									
Tmax. Prot.	Release		2 ms			4P4T			4 ms			4P4T			2 ms	4P4T										
Contactor	Thermal relay																									
Manufacturer	mg19in1.dug						mg19in1.dug						mg19in1.dug													
DISCRIMINATION																										
Limit	From																									
Thermal	Differential		With			Not Applicable			With			Not Applicable			With	Not Applicable										
Logical Discrim.			<input type="checkbox"/>						<input type="checkbox"/>						<input type="checkbox"/>											
T1	T2																									
IK END																										
Ik3 Max	Ik2 Min	If	2075 A	1214 A		697 A	4199 A	2464 A		1409 A	2718 A	1590 A		912 A												
Ik2 Max	Ik1 Min	Ik1 Max	1797.1 A	702 A		1039 A	3636.4 A	1429 A		2112 A	2354.0 A	920 A		1362 A												
LOGO Enterprise												Calculation sheet 3 circuits LV COMMON BUSBAR 00GAF10GS011														
												Ind.		MODIFICATIONS								PROJECT: 2304				
														EA Caneco								DRAWING:				
		Date: 11/08/2023	Standard: IEC364-17											Folio												



NETWORK					Normal			Standby		CALCULATION SHEET 3C										
Earthing Syst		TN			I Total		2644.61 A													
Voltage		400 V			I installed		4546.63 A													
DISTRIBUTION					I Avail		2346.99 A													
Upstream N	TRANSFORMER-1&2			Ik3 max		55050 A														
Upstream S	LV COMMON BUSBAR			ΔU		0.51 %														
CIRCUIT					Circuit OK															
					IN <input checked="" type="checkbox"/>	DU <input checked="" type="checkbox"/>	IC <input checked="" type="checkbox"/>	SC <input checked="" type="checkbox"/>	IN <input type="checkbox"/>					DU <input type="checkbox"/>	IC <input type="checkbox"/>	SC <input type="checkbox"/>	IN <input type="checkbox"/>	DU <input type="checkbox"/>	IC <input type="checkbox"/>	SC <input type="checkbox"/>
Upstream		LV COMMON BUSBAR																		
Ref mark					00EKG20GH001															
Upstream BB		D.origin			LV COMMON BUSBAR_															
Style					Board															
Content		ΔU Regulator			3P+N+PE															
Designation																				
CABLES INFORMATIONS/EQUIPM.					GAS CONDITIONING STATION															
N°	Consump	K Coincid	Geog.location	1	50kW		1													
Downst BB				Modif.		A														
Cos φ	K Use	UL		0.9			1													
Cos φ Start.	ID/IN	ΔU Start																		
η	Supply			1.00	Normal															
Equip. Pole	Type			3P+N																
CABLE					00EKG20GH001															
Type			N2XRH (90°C) Dca																	
Install. method	Core	Pole	31	Copper		Multi+PE														
Length	1st equipit.	L. Max	215 m			237 m (DU)														
ΔU Max	ΔU Circuit	ΔU Total	4.5 %	3.62 %		4.12 %														
K T°	K prox	K Add	Fs	K Cumul	1.00 (30°C)	0.60	1.00	1.00	0.60											
PROTECTION					<input type="checkbox"/> No check on Thermal stress <input checked="" type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input type="checkbox"/> Icu CB checked				<input type="checkbox"/> No check on Thermal stress <input type="checkbox"/> Icu CB checked							
Type	Prot. IC		MCCB	Basis Prot																
RESULTS FIXING																				
fixed <input checked="" type="checkbox"/>	N°	Phase	fixed <input checked="" type="checkbox"/>	1	50 mm <sup>2</sup>		fixed <input type="checkbox"/>							fixed <input type="checkbox"/>						
	N°	Neutral		1	50 mm <sup>2</sup>															
	N°	PE/PEN		1	50 mm <sup>2</sup>															
Harm. Rate	Loaded N			HR <= 15%		No														
Protection				NSX250H Micrologic 2.2 4P4T																
Rating	Ir	Im/Isd/IN Fus.	250 A	100 A	300 A															
K on rating.	Tr	Tempo	1	16 s	20 ms															
Magnetic	Li off	IΔn	Electronic																	
Downs.Ther.	Li	Δt	On circuit	3000 A																
RESULTS																				
Cable	Neutral		PE/PEN	4X50			1X50													
Criteria	IB			IMPOS		80.19 A														
S Th.	Iz			38.094 mm <sup>2</sup>		115.09 A														
Im / Isd Max	Ik Up/Dn			900 A		55.1 kA / 2.9 kA														
Discrimination	Backup		Total	Without																
IK INFORMATIONS / PROTECTION																				
Icu / Icm	Icu Backup	Ip	70 kA	70 kA	4.39 kA															
Icu S-pole	Icu S-pole backup																			
Tmax. Prot.	Release		15 ms			4P4T														
Contactor	Thermal relay																			
Manufacturer			mg19in1.dug																	
DISCRIMINATION																				
Limit	From																			
Thermal	Differential		With	Not Applicable																
Logical Discrim.			<input type="checkbox"/>			<input type="checkbox"/>								<input type="checkbox"/>						
T1	T2																			
IK END																				
Ik3 Max	Ik2 Min	If	2926 A	1727 A	990 A															
Ik2 Max	Ik1 Min	Ik1 Max	2533.9 A	1002 A	1472 A															
LOGO Enterprise																				
A																				
Ind.			MODIFICATIONS																	
			EA Caneco																	
Date: 11/08/2023			Standard: IEC364-17																	
Calculation sheet 3 circuits LV COMMON BUSBAR 00EKG20GH001																				
PROJECT: 2304												Folio								
DRAWING:																				
								6												
								6												

CLIENT



CONTRACTOR



SITE / PROJECT

## 100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT

REV	DATE	DESCRIPTION	DONE	CHECKED	APPROVED
1	18.03.2024	For Construction	BS	AG	CK
0	16.06.2023	For Review	BS	AG	CK
STATUS	FOR INFORMATION FOR REVIEW FOR APPROVAL FOR TENDER FOR COORDINATION FOR CONSTRUCTION	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/>	ISSUE OWNER <b>YÜKSEL PROJE</b>	SIGN 18.03.2024	DATE
DOCUMENT NUMBER	PRF-EL-TS-00-YP-0005	DOCUMENT NAME	LIGHTING SYSTEM TECHNICAL SPECIFICATION		

## Table of Contents

<b>1.</b>	<b>INDRODUCTION .....</b>	<b>3</b>
1.1.	General.....	3
1.2.	Scope.....	3
1.3.	Definitions.....	3
1.4.	Abbreviations.....	3
<b>2.</b>	<b>CODES AND STANDARTS .....</b>	<b>5</b>
<b>3.</b>	<b>REFERENCE DOCUMENTS.....</b>	<b>7</b>
<b>4.</b>	<b>DESIGN CONDITIONS.....</b>	<b>8</b>
<b>5.</b>	<b>PROFILE PARK POWER PLANT UNIT LISTS .....</b>	<b>10</b>
<b>6.</b>	<b>LIGHTING REQUIREMENTS.....</b>	<b>11</b>
6.1.	General Requirements.....	11
6.2.	Indoor Lighting.....	12
6.3.	Outdoor lighting.....	12
6.4.	Emergency Lighting.....	13
6.5.	Illumination Levels .....	13
6.6.	Control of Lighting System .....	14
6.7.	Junction Boxes .....	15
6.8.	Electrical Protection.....	15
6.9.	Cable Requirements .....	15
6.10.	Cable Gland .....	15
<b>7.</b>	<b>TESTS.....</b>	<b>16</b>
7.1.	Workshop Tests .....	16
7.2.	Site Tests.....	16

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	<i>Lighting System Technical Specification</i>	Document No:	PRF-EL-TS-00-YP-0005		

## 1. INTRODUCTION

### 1.1. General

Centrica Business Solutions (CBS) is a provider of energy insights, optimisation and on-site generation solutions for its customers, as well as owning and operating energy solutions across the UK, Ireland and North America while continually in the process of identifying new sites for development.

CBS is currently in the process of supporting the development of a circa 100 MW dualfuel generation asset (Athlone Power Project) in Monksland, Athlone and Profile Park, Baldonnel, Ireland. CBS are delivering the project on an Engineering, Procurement and Construction (EPC) basis on behalf of Greener Ideas Ltd.

The Project will consist of five (5) gas reciprocating engines exporting power to the grid via an adjacent 110 kV connection. The Project will use natural gas as its primary fuel with gas oil as a back-up in the event of interruption to the gas supply.

### 1.2. Scope

The purpose of this Specification is to define the scope and minimum technical requirements for the Lighting System associated with the proposed 100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT to be located near Dublin, Ireland.

### 1.3. Definitions

Project	: 100 MW Profile Park Reciprocating Power Plant
Employer	: GIL
Contractor	: GCIL
Shall	: Indicates a mandatory requirement
Should	: Indicates a strong recommendation

### 1.4. Abbreviations

BS	: British Standards
CIBSE	: Chartered Institution of Building Services Engineers
RoI	: Return of Investment
LED	: Light Emitting Diode
UV	: Ultraviolet
EN	: European Norm
IEC	: International Electrotechnical Commission

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	Lighting System Technical Specification	Document No:	PRF-EL-TS-00-YP-0005		

---

MCB	: Miniature Circuit Breaker
LV	: Low Voltage
MV	: Medium Voltage
IP	: Ingress Protection
V	: Volt
K	: Kelvin
IIC	: The International Code Council
ISO	: International Organization for Standardization

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	Lighting System Technical Specification	Document No:	PRF-EL-TS-00-YP-0005		

## 2. CODES AND STANDARDS

As a minimum, the following codes and standards shall be considered:

I.S. 10101:2020	National Rules for Electrical Installations
EN 12464-1	Light and lighting - Lighting of work places - Part 1: Indoor work places
EN 12464-2	Light and lighting - Lighting of work places - Part 2: Outdoor work places
EN 50172	Emergency escape lighting systems
EN 60079	Electrical apparatus for explosive gas atmospheres
EN 15193	Energy performance of buildings - Energy requirements for lighting
EN 1838	Lighting applications- Emergency lighting
EN 50262	Metric cable glands for electrical installations
EN ISO 9001	Quality Management System
IEC 60529	Degrees of protection provided by enclosures (IP Code)
IEC 60598	Luminaires General requirements and tests
IEC 60079	Explosive atmospheres
IEC 62612	Self-ballasted LED lamps for general lighting services with supply voltages > 50 V - Performance requirements
IEC 60423	Conduit systems for cable management - Outside diameters of conduits for Electrical installations and threads for conduits and fittings
IEC 60502	Power cables with extruded insulation and their accessories for rated voltages from 1 kV (Um = 1,2 kV) up to 30 kV (Um = 36 kV)
IEC 60669	Switches for household and similar fixed electrical installations
IEC 60228	Conductor of insulated cables
BS EN 8138	Emergency Lighting Applications
BS 5266	Code of practice for the emergency lighting of premises
CIBSE codes	Chartered Institution of Building Services Engineers
ATEX certifications	Hazardous Area Classification
RoI standards	Return of Investment

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	Lighting System Technical Specification	Document No:	PRF-EL-TS-00-YP-0005		

Equipment shall be supplied in accordance with all applicable European Union Directives.  
Particular attention should be paid to:

- Safety
- Electromagnetic Compatibility
- Machinery
- CE marking

Therefore, the Supplier shall be responsible for supplying the product with its CE marking and all the corresponding documentation."

The units of measure shall be the SI unit of measure.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	<i>Lighting System Technical Specification</i>	Document No:	<b>PRF-EL-TS-00-YP-0005</b>		

### 3. REFERENCE DOCUMENTS

PRF-EL-DW-00-YP-0007	Outdoor Lighting Layout
PRF-EL-CR-00-YP-0006	Outdoor Lighting Calculation Report
PRF-EL-DW-00-YP-0011	Engine Hall and Electrical Annex Basement Lighting Plan
PRF-EL-DW-01-YP-0004	Engine Hall Lighting System Drawings
PRF-EL-DW-01-YP-0005	Engine Hall Lighting System Details
PRF-EL-CR-01-YP-0001	Engine Hall Lighting System Calculation Report
PRF-EL-DW-02-YP-0004	Electrical Annex Lighting System Drawings
PRF-EL-DW-02-YP-0005	Electrical Annex Lighting System Details
PRF-EL-CR-02-YP-0001	Electrical Annex Lighting System Calculation Report
PRF-EL-DW-05-YP-0003	Workshop & Store Room Lighting System Drawings
PRF-EL-DW-05-YP-0004	Workshop & Store Room Lighting System Details
PRF-EL-CR-05-YP-0001	Workshop & Store Room Lighting System Calculation Report
PRF-EL-DW-17-YP-0003	Tank Farm Building Lighting System Drawings
PRF-EL-DW-17-YP-0004	Tank Farm Building Lighting System Details
PRF-EL-CR-17-YP-0001	Tank Farm Building Lighting System Calculation Report
PRF-EL-DW-38-YP-0003	Security Hut Lighting System Drawings
PRF-EL-DW-38-YP-0004	Security Hut Lighting System Details
PRF-EL-CR-38-YP-0001	Security Hut Lighting System Calculation Report
0129074-P00-EP-XX-SP-E-1014	Lighting and Small Power Specification

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No.:	1
Document Name:	Lighting System Technical Specification	Document No.:	PRF-EL-TS-00-YP-0005		

#### 4. DESIGN CONDITIONS

##### Ambient Air Conditions: Statistical Data

Minimum Recorded (°C)	-7.6
Mean Recorded (°C)	10.0
Maximum Recorded (°C)	27.5
Mean Wet Bulb Temperature (°C)	8.6
Maximum Wet Bulb Temperature (°C)	21.5
Minimum Humidity	20%
Average Humidity	82%
Maximum Humidity	100%

##### Ambient Air Temperature: Design Data

Winterisation Temperature (°C)	-10 <sup>1</sup>
Max Ambient Design Temperature (°C)	30 <sup>1</sup>
Max Wet Bulb Temperature (°C)	22

##### Wind, Rainfall and Snowfall Data

Average Wind Velocity km/h (m/s)	18.1 (5.0)
Maximum Wind Velocity km/h (m/s)	74.1 (20.6)
Average Daily Rainfall (mm)	2.1
Maximum Daily Rainfall (mm)	45.4

##### Site Conditions

Parameter	Value [Ref 1]
Altitude above sea level (m)	69
Maximum wet bulb temperature (°C)	21.5
Minimum ambient air temperature (°C)	-10
Maximum ambient air temperature (°C)	30

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No.:	1
Document Name:	Lighting System Technical Specification	Document No.:	PRF-EL-TS-00-YP-0005		

Performance Data Reference Conditions

Parameter	Unit	Value
Air inlet temperature (before air inlet filter)	°C	15
Air inlet pressure (before air inlet filter)	mbar	1005 <sup>1</sup>
Wet Bulb Temperature	°C	7 <sup>2</sup>
Relative Humidity	%	28
Charge Air Temperature Before Cylinder:		
Gas Operation	°C	50
Diesel Operatin	°C	45
Exhaust Gas Bask Pressure	mbar	<=50
Intake Air Pressure Loss	mbar	<=20

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	Lighting System Technical Specification	Document No:	PRF-EL-TS-00-YP-0005		

## 5. PROFILE PARK POWER PLANT UNIT LISTS

- ENGINE HALL
- ELECTRICAL ANNEX
- WORKSHOP & STOREROOM
- TANK FARM BUILDING
- SECURITY HUT BUILDING

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	<i>Lighting System Technical Specification</i>	Document No:	<b>PRF-EL-TS-00-YP-0005</b>		

## 6. LIGHTING REQUIREMENTS

### 6.1. General Requirements

All lighting fittings shall be supplied ready for connection to the rated voltage, frequency, and prevailing environmental conditions as specified.

The design of lighting fittings shall be considered so that cleaning requirements are minimized. Lighting fixtures shall be easy to replace, and no loose parts which could be lost, shall be used.

The equipment shall be flame-retardant.

Special tools or equipment for installation and maintenance of the lighting equipment shall be avoided.

All lighting fittings for installation in non-classified areas shall be of the industrial type as required. These types of fittings shall be suitable for "two-pin" advanced and LED technology.

Depending on the application, safety glass covers (resistant to thermal shock) or special polycarbonate diffusers (increased thermal and mechanical resistance) with internal prism with light directing shall be used. The diffuser shall be made in one piece, with excellent UV stabilization against discoloration.

Any angular limitation upon the mounting position of the lighting fittings shall be stated. Floodlights shall be suitable for mounting at any angle.

Normal and emergency lighting shall be provided in all buildings and structures (plant areas, switchrooms, offices etc). All lighting fixtures and associated circuits shall be installed as indicated in the drawings. However, where necessary, the fixtures may be repositioned with the prior approval of the Employer, without affecting light distribution, and avoiding interference with other process equipment or station piping.

Lighting fixtures should generally be arranged to allow cables to be looped from one fixture to another. Junction boxes may be used to minimize the voltage drop in the circuits.

Normal indoor lighting shall not have any special duty. They shall be fed by the Sub-Distribution Panel. Also, all outdoor lighting shall be fed from the Sub-Distribution Panel in the Guard House.

Corrosion resistant LED fixture will be used in all over the plant.

The lighting design shall be provided with appropriate arrangements for maintenance and suitable access. Maintenance factors for all luminaries will be provided as part of the design. Interior lighting will be in accordance with national and local standards.

Normal and emergency lighting are switched on at the same time and must provide the required standard lighting.

Lighting system power supplies consisting of 400/230 Volt, three-phase / five wire, one-phase / three-wire or four-wire shall be acceptable. Four wire cable will be used for only lighting fixture with own battery kit for reference phase application. The choice of voltage and distribution

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	Lighting System Technical Specification	Document No:	PRF-EL-TS-00-YP-0005		

system for lighting installations shall depend on the area to be supplied and the required lighting load.

The elements of the lighting equipment should be ensured protection against the penetration of dust or humidity, which is characteristic for the environment in question. In a chemically hazardous environment, endurance against chemical effects will be ensured.

## 6.2. Indoor Lighting

The illumination level and the lay-out of the lighting fixture in the various rooms shall ensure correct and well distributed illumination according to the requirements and considering the equipment layout of the respective room.

All lighting fixtures shall be a light similar to daylight. LED fixtures for use in offices, control rooms, switchrooms, and similar rooms should be wall/ceiling/cable tray mounted.

Operating voltage level shall be between 220V and 240V.

The minimum power factor shall be greater than 0.95.

The color temperature shall be 4000K.

All lighting fixtures shall be supplied and fitted with the appropriate lamping, starters, louvres and covers. The selected lighting fixtures should have at least a guaranteed period before replacement of 5 years or at least 5000 hours of use. Suitable suppliers shall be approved by the Contractor.

Suitable lighting shall be provided on the roof floor of the electrical annex building.

The Atex zone class of the equipment in the battery room shall be Zone 2 IIC Eex d T6.

For technical area Luminaires selection shall have appropriate IP ratings, considering the environmental and hazardous area requirements. For non-tech areas lighting fixtures shall be IP20.

## 6.3. Outdoor lighting

All outdoor lighting fixtures shall be similar to daylight. The lighting sources shall be LED fixtures.

Operating voltage level shall be between 220V and 240V.

The color temperature shall be 4000K.

All lighting fixtures shall be supplied and fitted with the appropriate lamping, starters, louvres and covers. The selected lighting fixtures should have at least a guaranteed period before replacement of 5 years or at least 5000 hours of use. Suitable suppliers shall be approved by the Contractor.

Outdoor area lighting fixtures shall be installed on poles with a height of 4-6 m or building surface. The poles and all other steel construction elements provided for outdoor lighting shall be hot dip galvanized.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No.:	1
Document Name:	Lighting System Technical Specification	Document No.:	PRF-EL-TS-00-YP-0005		

Each outdoor lighting circuit shall be fed with a magnetic circuit breaker and can be triggered by a push button impulse current switch. Each pole shall have embedded junction boxes and MCB. The outdoor lighting circuit shall be 3-phase system and shall be controlled by a single photocell relay switch.

All lighting circuits and lines will have grounding wire.

There shall be wall-mounted lighting fixtures on the exterior doors of the buildings and shall be controlled by photocell relay switches.

Security cameras around the fence should have night vision capability. In this way, there will be no need for security lighting.

Outdoor luminaires shall be at least IP 65.

#### **6.4. Emergency Lighting**

Emergency (task area) lighting shall be provided throughout the plant where required. In order to reach the appropriate emergency lux value in the areas, sufficient number of fixtures should have own battery kit.

When the AC power line is energized, the batteries must be continuously charged and have a rated service capacity of at least 60 minutes when AC power is turned off.

#### **6.5. Illumination Levels**

General lighting values throughout the facilities should be designed according to the lighting (lux) values given in the table below. The lighting measurements of all rooms shall be at ground level except for meeting room, control room etc. In places such as meeting rooms and control rooms, the lighting measurements should be at the task/activity level. Illumination levels have been made according to the requirements of the EN 12464-1 / EN 12464-2 standards.

<b>Class</b>	<b>Areas</b>	<b>Lighting Level (Lux)</b>	
		<b>Normal</b>	<b>Emergency</b>
1	Control rooms, Desks	500	As per EN 12464
2	Engine Hall	200	As per EN 12464
3	Generator Room	200	As per EN 12464
4	MV Rooms	200	As per EN 12464
5	LV Rooms	200	As per EN 12464
6	Electrical Rooms	200	As per EN 12464

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No.:	1
Document Name:	Lighting System Technical Specification	Document No.:	PRF-EL-TS-00-YP-0005		

7	Transformer Area	200	As per EN 12464
8	Battery Room	200	As per EN 12464
9	Server Room	200	As per EN 12464
10	Gallery Room	100	As per EN 12464
11	Corridors and Stairwells	100	As per EN 12464
12	Offices, Desks	500	As per EN 12464
13	Meeting Room	500	As per EN 12464
14	Toilets, WC	200	As per EN 12464
15	Rest&Locker Room	200	As per EN 12464
16	Laboratories	500	As per EN 12464
17	First Aid	500	As per EN 12464
18	Workshop	300	As per EN 12464
19	Storehouse	100	As per EN 12464
20	Storage Room	200	As per EN 12464
21	Entrance Room	100	As per EN 12464
22	Changing Area and Facilities	200	As per EN 12464
23	Compressor Room	200	As per EN 12464
24	Road Lighting	10	NA
25	Car Parking	20	NA
26	General Outdoor Lighting	10	NA

## 6.6. Control of Lighting System

All normal indoor lighting in industrial areas shall be controlled by wall mounted pushbuttons located indoors, near the entrance doors.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No.:	1
Document Name:	Lighting System Technical Specification	Document No.:	PRF-EL-TS-00-YP-0005		

Outdoor lighting shall be controlled by photocell relay switches.

All outdoor lighting shall be remotely controlled from guard house or controlled from each dedicated panel and indoor lighting shall be controlled from each dedicated panel.

In rooms with multiple exits, the lighting shall be controlled by all wall mounted pushbuttons located near the entrance doors.

For technical area lighting switches selection shall have appropriate IP ratings, considering the environmental and hazardous area requirements. In non-technical areas, (Office, Rest&Locker Room etc.) IP20 shall be selected.

### 6.7. Junction Boxes

Junction boxes shall be installed at the locations shown in the drawings. Junction boxes shall be made of PVC with appropriate ingress protection (IP) levels as per installation type. For indoor and outdoor areas junction boxes shall have appropriate IP ratings, considering the environmental and hazardous area requirements.

The boxes shall be securely mounted and easily accessible.

### 6.8. Electrical Protection

All electrical equipment shall be protected against direct contact, indirect contact, over voltage, over current and short circuit in normal service and in case of a fault in accordance with the IEC.

Installations up to 1000 V shall be protected by use of protective multiple earthing and (neutral conductor and separate protective conductor). The connection between neutral conductor and the protective conductor is allowed in the main LV distribution boards only. Electric installations in housing compounds shall be protected by means of faulty current switches.

### 6.9. Cable Requirements

The power cables shall generally comply with the requirements of IEC 60502, IEC 60228, and IEC 60183. The indoor lighting cables shall have stranded copper conductors with XLPE insulation, armoured cable, and low smoke zero halogen. Some lighting circuit cable shall only be installed outdoor (they will not be accessed in building). They will be PVC insulated, armoured, and UV radiation resistant (for only outdoor cable). The conductor's cross section shall be adequate for carrying the prospective faults current. Thus, sizing calculations will be done to determine the cable size of each circuit.

### 6.10. Cable Gland

Cable glands shall be of the compression type with screwed ISO metric threads according to EN 50262. For metal enclosures, the glands shall be made of metallic type. For enclosures of nonconductive materials, the glands shall be of non-conductive materials.

Cable glands shall be selected according to related cable dimensions.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	Lighting System Technical Specification	Document No:	PRF-EL-TS-00-YP-0005		

## 7. TESTS

### 7.1. Workshop Tests

All electrical equipment and systems shall be tested completely and detailed in Contractor's workshop. All tests required by the codes and standards as well as all manufactures tests need to be performed.

Detailed test protocols of all tests performed should be submitted prior to installation.

### 7.2. Site Tests

The site tests include,

- pre-installation testing,
- pre-commissioning (including "Loop Testing"),
- commissioning with test on completion.

With the tests the proper and reliable function of the complete scope according to the requirements shall be proven.

Project:	100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT	Date:	18.03.2024	Rev. No:	1
Document Name:	<i>Lighting System Technical Specification</i>	Document No:	PRF-EL-TS-00-YP-0005		