



REFERENCE DRAWINGS:

Based on MAN P&ID 11830140113

- NOTES:
1. Radiator cooling for engines 02 to 05 is identical to Engine 01 with only the prefix 01 changing to 02, 03, 04, 05 depending on the engine.
 2. Flange pair for flushing.
 3. All drain to be routed by the operator to the closest drain location by hose if required.
 4. The connection type of any valves have been specified in relevant isometrics.

- LEGEND:
1. For general notes and P&ID symbology refer to Legend Sheets (P&ID PRF-PR-DW-00-YP-0101-SHT-1, 2 & 3)
 2. For piping classification, refer to document PRF-PR-TS-00-YP-0008)

CLIENT:

CONTRACTOR:

SITE / PROJECT: 100 MW PROFILE PARK RECIPROCATING POWER PLANT PROJECT

ISSUE OWNER:	4 19-07-24	FOR CONSTRUCTION	SV	SKO	CK
	3 15-03-24	FOR CONSTRUCTION	SV	SKO	CK
	2 03-11-23	FOR HAZOP STUDY	SV	SKO	CK
	1 19-07-23	FOR CONSTRUCTION	SV	SKO	CK
	0 13-06-23	FOR REVIEW	SV	SKO	CK

STATUS	FOR INFORMATION	<input type="checkbox"/>	FOR TENDER	<input type="checkbox"/>	ORIGINAL EDITION	SIZE	SCALE
	FOR REVIEW	<input type="checkbox"/>	FOR CONSTRUCTION	<input type="checkbox"/>	CHECKED	19-07-24	A1
	FOR APPROVAL	<input type="checkbox"/>	FOR COORDINATION	<input type="checkbox"/>	APPROVED	19-07-24	

DRAWING NUMBER: PRF-PR-DW-00-YP-0118

SHEET: 1 OF 1

DRAWING NAME: RADIATOR COOLING WATER P&ID