

User input indicated by **Orange fields**

User Input	
Zoning lookup	Minimum GI Score
Res	0.5

1. Enter Development Site Area m ² HERE ▶		48709	
Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m ²	Factor Values
1. Short Lawn	0.3	8112	2433.6
2. Tall Lawn (wild, not mown)	0.5	8122	4061
Permeable Paving	0.3	910	273
Vegetation		0	0
4a. Vegetation-Shrub below 3m	0.4	297	118.8
4b. Vegetation-Shrub / Hedgerow above 3m	0.5	1312	656
4c. Vegetation-Pollinator friendly perennial planting	0.5	714	357
4d. Vegetation-Preserved hedgerow	1.2	1982	2378.4
Trees		0	0
5a. New trees	0.6	20581	12348.6
5b. Preserved trees	1.2	896	1075.2
7. SuDS intervention (rain garden, bioswale)	0.6	2221	1332.6
Green Roof		0	0
9a. Green Roofs - Intensive green roof (substrate is 200-1200mm in depth)	0.7	0	0
9b. Green Roofs - Extensive green roof (substrate is 80-200mm in depth)	0.6	0	0
10. Green wall	0.4	0	0
11. Retained Open Water	2	0	0
12. New open water	1.5	0	0
Total Equivalent Surface Area of Greening Factors		45,147.00	
Green Factor Numerator		25034.20	
Minumum Required GI score	Final GI score	Result	
0.5	0.51	Pass	